

SHAHID ASIYAE, Iran, Islamic Republic of

WMO: 408120

Lat: 32.002N

Lon: 49.271E

Elev: 362

StdP: 97.05

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.2	5.8	-10.8	1.6	31.7	-7.8	2.0	32.3	7.4	14.4	6.2	14.7	0.5	330	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	47.0	20.7	46.0	20.4	45.1	20.3	23.9	40.5	22.7	41.3	21.8	41.6	3.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.9	30.3	17.1	12.7	26.6	15.9	11.8	24.1	73.8	40.9	69.0	41.1	65.6	41.7	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	6.1	5.4	1.8	49.1	1.5	1.0	0.6	49.8	-0.3	50.3	-1.1	50.9	-2.3	51.6		
			0.7	25.9	1.8	1.2	-0.6	26.7	-1.6	27.4	-2.6	28.1	-3.9	28.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	12.1	14.4	19.0	24.5	31.5	36.5	38.6	38.3	34.0	27.9	19.4	14.2
	DBStd	9.89	2.84	3.04	3.37	3.41	3.01	1.99	1.86	1.65	2.25	3.02	3.53	2.73
	HDD10.0	19	13	4	0	0	0	0	0	0	0	0	0	2
	HDD18.3	499	193	114	31	2	0	0	0	0	0	0	29	130
	CDD10.0	5832	78	126	278	436	667	795	888	877	719	553	282	133
	CDD18.3	3271	0	3	51	188	408	545	629	619	469	295	61	2
	CDH23.3	54201	1	23	482	2123	6488	9962	11753	11393	7798	3702	455	21
CDH26.7	38793	0	1	153	987	4255	7568	9273	8913	5464	2049	127	1	
Wind	WSAvg	1.8	1.2	1.5	1.7	2.1	2.3	2.4	2.4	2.2	1.9	1.7	1.3	1.1
Precipitation	PrecAvg	503	126	72	88	48	8	0	0	1	13	57	112	
	PrecMax	677	288	184	282	181	61	2	1	9	54	310	249	
	PrecMin	313	40	5	6	3	0	0	0	0	0	3	14	
	PrecStd	87	65	42	62	41	13	0	0	2	17	65	68	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	25.9	34.0	38.4	43.8	47.0	48.8	48.0	45.1	40.0	31.6	25.8
		MCWB	12.7	14.3	15.3	17.4	19.3	19.4	21.3	20.7	19.8	18.3	16.0	13.9
	2%	DB	20.2	23.8	30.5	35.7	42.1	45.9	47.2	46.8	43.5	38.1	29.9	23.0
		MCWB	12.9	13.6	15.0	17.0	18.7	19.5	20.9	20.9	19.9	18.3	15.4	14.0
	5%	DB	18.7	21.9	27.9	33.8	40.4	44.9	46.2	45.8	42.1	36.8	28.0	20.8
		MCWB	12.3	13.1	14.5	16.6	18.1	19.2	20.6	20.9	19.7	17.8	15.4	13.4
	10%	DB	17.1	20.1	25.8	31.9	39.0	43.9	45.2	44.9	41.0	35.1	25.9	19.0
		MCWB	12.1	12.6	13.8	16.1	17.9	19.1	20.3	20.9	19.3	17.4	14.8	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.0	17.1	18.6	19.9	21.5	21.8	24.8	25.9	25.2	21.7	19.7	17.7
		MCDB	18.7	21.0	23.4	27.5	37.8	43.1	40.1	39.1	36.9	34.8	24.1	19.7
	2%	WB	15.0	15.7	17.3	19.0	20.3	20.8	23.2	24.2	23.0	20.0	18.4	16.2
		MCDB	17.9	19.9	23.0	28.5	37.2	43.0	42.9	41.0	38.4	32.3	23.7	18.5
	5%	WB	14.0	14.6	16.4	18.3	19.5	20.2	22.2	23.0	21.4	19.0	17.4	15.1
		MCDB	16.7	19.3	23.2	28.6	36.0	42.6	43.5	41.2	39.0	31.9	23.2	18.3
	10%	WB	13.0	13.6	15.5	17.6	18.9	19.7	21.5	22.1	20.2	18.3	16.6	14.3
		MCDB	15.7	18.6	23.0	28.2	35.2	41.9	42.9	41.3	38.6	31.6	22.6	17.7
Mean Daily Temperature Range	5% DB	MDBR	8.9	9.9	11.3	12.0	12.5	13.6	12.6	13.0	13.6	12.8	10.5	9.5
		MCDBR	11.1	12.1	14.3	13.8	14.4	14.8	13.7	13.5	14.2	14.3	12.7	12.3
		MCWBR	5.6	5.2	4.9	4.3	4.6	4.6	4.3	4.5	5.0	5.2	4.7	5.5
	5% WB	MCDBR	8.5	9.4	11.0	11.7	12.4	13.8	12.8	12.4	12.5	11.7	8.9	8.8
		MCWBR	5.5	5.2	5.1	4.4	4.4	4.8	4.8	5.2	5.5	5.2	4.2	5.1
Clear-Sky Solar Irradiance	taub	0.406	0.449	0.506	0.599	0.571	0.530	0.599	0.548	0.474	0.489	0.437	0.401	
	taud	2.075	1.960	1.815	1.663	1.722	1.789	1.671	1.772	1.913	1.886	2.014	2.101	
	Ebn at Noon	785	788	773	721	747	775	720	752	792	737	743	766	
	Edh at Noon	133	165	205	248	236	220	246	220	183	175	141	124	
All-Sky Solar Radiation	RadAvg	2.97	3.86	5.08	5.85	7.08	8.27	7.75	7.30	6.44	4.84	3.45	2.81	
	RadStd	0.23	0.34	0.36	0.45	0.38	0.23	0.21	0.23	0.20	0.27	0.30	0.31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page