

ABADEH, Iran, Islamic Republic of

WMO: 408180

Lat: 31.1981N

Lon: 52.6161E

Elev: 6660

StdP: 11.49

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 17.9	(c) 21.3	(d) -7.5	(e) 4.7	(f) 46.3	(g) -2.6	(h) 6.1	(i) 45.2	(j) 30.8	(k) 50.1	(l) 26.9	(m) 48.1	(n) 2.8	(o) 330	(p) 0.478

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 25.8	(c) 95.5	(d) 57.9	(e) 94.0	(f) 57.3	(g) 92.0	(h) 56.4	(i) 60.4	(j) 90.3	(k) 59.0	(l) 89.6	(m) 57.7	(n) 88.2	(o) 7.4	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
48.4	64.5	67.4	45.8	58.3	66.9	43.2	52.9	65.3	30.0	90.7	28.8	89.8	27.9	88.8	69.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.9	21.7	18.1	9.6	97.9	6.6	1.2	4.9	98.8	1.0	99.5	-2.7	100.2	-7.5	101.0
			7.6	62.5	5.7	2.9	3.5	64.6	0.1	66.3	-3.1	68.0	-7.3	70.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.4	37.7	41.2	49.5	57.0	66.3	75.8	79.2	75.6	69.9	59.8	47.2	40.9
	DBStd	15.25	6.76	6.53	5.94	5.09	4.77	3.89	3.62	3.85	3.64	4.62	6.24	6.24
	HDD50	1134	383	252	81	7	0	0	0	0	0	1	123	287
	HDD65	3736	847	667	480	244	43	0	0	0	6	170	533	746
	CDD50	4216	1	5	66	216	506	774	906	793	597	305	41	6
	CDD65	1341	0	0	0	2	84	324	441	328	153	9	0	0
	CDH74	18990	0	0	12	66	1139	4563	6145	4575	2228	262	0	0
	CDH80	8758	0	0	0	2	260	2263	3304	2172	741	16	0	0
Wind	WSAvg	6.0	6.0	7.1	7.5	7.4	6.5	6.3	6.3	6.3	5.0	4.8	4.6	4.8
Precipitation	PrecAvg	6.5	1.2	0.8	1.4	0.7	0.2	0.0	0.0	0.0	0.0	0.2	0.6	1.2
	PrecMax	14.8	5.1	2.0	3.2	2.8	1.5	0.4	0.3	0.1	0.2	1.1	2.6	4.2
	PrecMin	2.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.4	1.1	0.6	0.8	0.7	0.4	0.1	0.1	0.0	0.0	0.3	0.7	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.6	64.8	75.5	79.1	88.0	96.4	98.3	97.2	91.5	82.2	71.4	64.8
		MCWB	40.6	42.6	47.0	50.3	53.2	57.9	58.6	58.9	54.3	50.9	45.1	43.9
	2%	DB	57.0	60.4	69.9	75.6	84.8	94.6	96.6	94.1	88.2	79.3	67.8	60.1
		MCWB	40.1	40.8	45.6	49.4	52.7	57.0	58.2	57.7	53.6	50.2	44.7	41.2
	5%	DB	53.7	57.0	66.0	73.1	82.8	92.8	94.9	91.7	86.4	77.0	64.4	57.0
		MCWB	38.4	39.6	43.4	47.9	52.2	56.0	57.9	56.4	53.1	49.4	44.2	40.0
	10%	DB	50.3	53.8	62.6	70.0	80.6	90.5	93.1	89.6	84.4	74.4	60.9	53.6
		MCWB	37.2	38.4	42.0	46.9	51.6	55.1	57.3	55.5	52.4	48.4	42.8	38.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.5	45.6	49.4	52.5	56.1	62.2	62.3	62.2	56.4	53.0	49.6	46.4
		MCDB	54.1	57.4	63.2	73.4	79.4	88.5	92.1	89.9	85.5	76.1	63.8	59.8
	2%	WB	42.4	43.2	47.6	51.1	54.6	59.4	60.5	59.5	54.9	51.4	47.3	43.6
		MCDB	52.4	55.4	63.1	70.8	78.8	88.1	91.6	89.4	85.0	76.0	61.5	55.7
	5%	WB	40.4	41.4	46.0	49.8	53.6	57.6	59.4	57.9	54.0	50.2	45.5	41.8
		MCDB	50.2	53.2	61.1	67.7	77.9	88.4	90.6	88.4	83.9	73.7	60.0	52.3
	10%	WB	38.4	39.9	44.1	48.6	52.6	56.2	58.3	56.6	53.0	49.1	44.0	40.3
		MCDB	48.4	51.2	59.0	65.9	76.3	87.3	89.2	87.2	82.6	71.5	58.2	50.1
Mean Daily Temperature Range	5% DB	MDBR	21.7	21.9	23.1	22.9	25.4	28.1	25.8	27.5	28.9	27.6	24.6	23.3
		MCDBR	25.5	26.3	27.3	26.6	28.0	29.6	28.0	28.6	30.4	29.8	28.4	27.8
		MCWBR	14.1	13.6	12.6	10.9	10.6	11.4	10.7	11.3	12.6	13.5	13.8	14.6
	5% WB	MCDBR	20.1	20.2	21.8	22.1	25.8	28.0	25.7	27.1	28.7	27.4	23.2	21.9
		MCWBR	12.5	11.7	11.6	9.6	9.8	11.1	10.0	10.9	12.3	13.0	11.7	12.5
Clear-Sky Solar Irradiance	taub	0.265	0.305	0.365	0.445	0.450	0.443	0.469	0.425	0.370	0.354	0.302	0.268	
	taud	2.471	2.346	2.128	1.923	1.934	1.966	1.916	2.036	2.179	2.209	2.393	2.482	
	Ebn at Noon	310	304	290	270	268	269	261	272	284	281	291	303	
	Edh at Noon	28	36	48	61	61	58	61	54	44	40	30	27	
All-Sky Solar Radiation	RadAvg	1111	1409	1824	2041	2369	2640	2498	2383	2095	1676	1238	1056	
	RadStd	91	97	103	118	113	88	82	75	58	70	88	88	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	-1.76	N/A	N/A	+169	-182

Nomenclature: See separate page