

YAZD SADOOGHI INTL, Iran, Islamic Republic of

WMO: 408210

Lat: 31.9036N

Lon: 54.2890E

Elev: 1237

StdP: 87.32

Time Zone: 3.50 (IRN)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.1	(c) -1.1	(d) -20.1	(e) 0.7	(f) 15.5	(g) -17.8	(h) 0.9	(i) 14.2	(j) 9.6	(k) 13.1	(l) 7.9	(m) 12.2	(n) 1.9	(o) 120	(p) 0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 12.9	(c) 41.9	(d) 17.1	(e) 40.9	(f) 16.7	(g) 39.8	(h) 16.3	(i) 18.6	(j) 38.2	(k) 17.9	(l) 37.4	(m) 17.2	(n) 36.7	(o) 2.9	(p) 120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.3	9.7	22.1	10.0	8.9	23.0	8.9	8.2	22.9	58.0	38.2	55.4	37.5	53.1	36.8	22.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.3	6.8	5.8	-5.7	43.3	2.3	0.6	-7.3	43.7	-8.7	44.1	-10.0	44.4	-11.7	44.8
			-7.6	19.4	1.7	1.0	-8.8	20.1	-9.8	20.7	-10.7	21.3	-12.0	22.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	7.4	10.3	15.3	20.5	26.2	31.3	33.2	30.9	27.4	21.3	13.1	8.8
	DBStd	9.56	4.31	4.42	4.10	3.48	3.04	2.52	2.40	2.39	2.33	3.07	3.90	3.60
	HDD10.0	234	103	44	6	0	0	0	0	0	0	0	14	66
	HDD18.3	1158	338	227	108	18	0	0	0	0	0	9	159	297
	CDD10.0	4077	23	52	172	314	503	638	718	649	522	350	108	28
	CDD18.3	1958	0	2	16	82	244	388	459	391	272	101	3	0
	CDH23.3	28811	1	13	196	871	3067	6116	7680	6113	3612	1081	56	6
CDH26.7	17578	0	1	44	284	1581	3972	5302	3955	2034	400	6	1	
Wind	WSAvg	2.6	2.3	2.7	2.9	2.9	3.1	3.0	3.1	2.9	2.4	2.2	2.1	2.1
Precipitation	PrecAvg	72	16	9	15	7	3	1	0	0	0	2	6	12
	PrecMax	133	45	29	66	21	15	4	2	1	0	7	33	40
	PrecMin	23	3	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	26	11	8	15	6	4	1	1	0	0	2	9	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.1	25.2	30.9	33.2	38.0	42.1	43.2	42.2	38.7	34.1	27.2	23.2
		MCWB	9.0	10.1	11.4	13.2	14.9	16.9	17.7	17.3	15.3	13.7	11.2	9.2
	2%	DB	19.9	22.2	27.2	31.4	36.2	41.0	42.2	40.7	37.2	32.2	24.9	20.2
		MCWB	7.9	9.0	10.6	12.8	14.6	16.4	17.2	16.8	15.0	13.3	10.5	8.0
	5%	DB	17.5	20.2	25.2	29.9	35.0	39.9	41.2	39.2	36.1	30.6	22.9	18.1
		MCWB	7.0	8.3	9.8	12.6	14.5	16.0	16.9	16.3	14.7	12.8	10.1	7.2
	10%	DB	15.1	18.2	23.2	28.1	33.8	38.3	40.2	38.1	35.0	29.0	20.8	15.9
		MCWB	5.8	7.5	9.4	11.8	14.3	15.5	16.6	15.8	14.2	12.3	9.2	6.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	11.7	13.5	14.9	17.1	19.3	19.7	19.1	16.7	14.7	12.6	10.6
		MCDB	17.9	20.1	21.4	24.8	32.9	35.8	39.3	38.5	35.8	30.2	22.7	19.6
	2%	WB	9.0	10.3	12.3	14.1	16.0	18.0	18.8	18.1	16.0	13.9	11.6	9.0
		MCDB	17.3	19.3	21.8	26.2	32.1	36.5	39.2	37.6	34.8	29.4	21.3	18.0
	5%	WB	7.7	9.3	11.3	13.5	15.3	17.2	18.1	17.4	15.3	13.3	10.7	8.0
		MCDB	15.7	18.2	22.3	25.9	31.4	36.3	38.2	36.7	34.0	28.4	20.2	16.1
	10%	WB	6.4	8.3	10.3	12.9	14.7	16.4	17.5	16.6	14.7	12.7	10.0	7.0
		MCDB	14.0	17.3	21.9	25.5	30.6	35.9	37.5	36.0	33.2	27.3	19.0	14.3
Mean Daily Temperature Range	5% DB	MDBR	11.9	12.3	12.8	12.6	12.6	13.2	12.9	13.8	14.4	13.9	12.3	12.3
		MCDBR	14.5	14.2	14.8	14.0	13.7	14.1	13.6	14.1	15.3	15.4	15.0	15.5
		MCWBR	7.6	6.8	6.3	5.3	4.7	5.0	4.7	5.1	6.0	6.4	7.1	7.9
	5% WB	MCDBR	12.8	12.2	12.4	12.4	12.8	12.8	12.3	12.9	14.2	13.9	12.7	13.1
		MCWBR	7.1	6.3	5.9	4.7	4.5	4.9	4.7	5.0	5.7	6.1	6.2	7.0
Clear-Sky Solar Irradiance	taub	0.304	0.344	0.408	0.488	0.498	0.488	0.490	0.446	0.401	0.393	0.340	0.303	
	taud	2.409	2.267	2.045	1.869	1.863	1.895	1.911	2.028	2.130	2.133	2.310	2.428	
	Ebn at Noon	920	907	867	811	804	809	805	837	863	838	864	902	
	Edh at Noon	94	121	162	202	205	198	194	170	147	136	104	88	
All-Sky Solar Radiation	RadAvg	3.48	4.36	5.58	6.41	7.35	8.24	7.93	7.53	6.50	5.16	3.83	3.25	
	RadStd	0.26	0.31	0.26	0.35	0.31	0.26	0.19	0.21	0.16	0.18	0.24	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.53	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		+0.53	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page