

NEHBANDAN, Iran, Islamic Republic of

WMO: 408270

Lat: 31.5416N

Lon: 60.0377E

Elev: 1211

StdP: 87.60

Time Zone: 3.50 (IRN)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.3	-26.2	0.4	19.4	-22.3	0.6	18.3	8.2	11.4	7.2	10.3	0.4	90	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	40.8	16.6	39.6	16.4	38.5	15.9	18.9	36.6	18.0	36.5	17.2	35.5	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
11.9	10.1	26.1	10.5	9.1	22.3	9.2	8.4	21.8	59.0	36.5	55.6	36.4	53.1	35.8	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	10.2	8.7	-6.8	43.0	2.1	0.7	-8.3	43.5	-9.5	43.9	-10.7	44.3	-12.2	44.8
			-8.7	19.2	1.8	1.8	-10.0	20.5	-11.0	21.6	-12.0	22.6	-13.3	23.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	6.7	9.7	15.8	21.8	27.3	31.6	33.0	30.8	26.9	21.1	13.5	8.1	(6)
(7)		DBStd	9.70	3.71	4.33	4.28	3.41	2.81	2.11	2.09	2.20	2.56	3.33	3.83	3.20	(7)
(8)		HDD10.0	256	113	51	6	0	0	0	0	0	0	0	11	75	(8)
(9)		HDD18.3	1189	360	241	99	9	0	0	0	0	0	12	152	317	(9)
(10)		CDD10.0	4117	11	44	187	354	536	647	712	645	506	343	115	17	(10)
(11)		CDD18.3	2008	0	1	22	113	278	397	454	387	256	96	6	0	(11)
(12)		CDH23.3	27879	0	11	257	1238	3628	5979	6993	5388	3121	1173	90	1	(12)
(13)		CDH26.7	16290	0	0	64	474	2022	3785	4598	3184	1677	472	13	0	(13)
(14)	Wind	WSAvg	3.3	1.9	2.3	2.7	2.6	3.5	4.9	6.2	5.8	3.6	2.2	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	123	27	27	35	12	2	0	1	0	2	3	13		(15)
(16)		PrecMax	293	60	95	129	52	19	6	3	1	5	18	24	75	(16)
(17)		PrecMin	16	3	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	63	15	27	37	14	4	1	1	0	1	4	5	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.0	25.3	31.9	34.8	39.6	42.1	42.2	40.9	38.0	35.4	28.6	22.3	(19)
(20)		MCWB	9.0	10.5	11.7	13.7	15.4	16.9	17.0	16.8	14.1	14.6	12.7	9.3		(20)
(21)		2%	DB	18.0	22.0	28.1	33.0	37.8	40.7	41.0	39.0	36.6	33.2	25.8	19.3	(21)
(22)		MCWB	7.4	9.9	11.5	13.7	16.0	16.8	16.4	16.2	14.2	14.5	11.7	7.9		(22)
(23)		5%	DB	16.4	19.7	26.0	31.2	36.3	39.4	39.9	37.6	35.3	31.2	23.6	17.7	(23)
(24)		MCWB	6.7	9.0	11.1	13.5	16.0	16.5	16.5	15.9	14.1	13.6	10.9	7.1		(24)
(25)		10%	DB	14.5	17.7	24.1	29.5	34.8	38.1	38.7	36.3	34.0	29.4	21.5	15.7	(25)
(26)		MCWB	6.1	8.2	10.7	12.9	15.4	15.8	15.9	15.2	13.9	12.9	9.9	6.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	12.4	14.2	15.8	20.5	19.6	19.7	20.2	16.5	16.1	14.1	10.2	(27)
(28)		MCDWB	15.6	19.7	23.6	30.0	34.4	37.4	39.3	35.4	34.5	31.8	24.5	19.4		(28)
(29)		2%	WB	9.3	11.2	13.3	14.9	17.8	18.7	18.6	18.1	15.7	15.1	12.9	8.9	(29)
(30)		MCDWB	15.9	18.5	22.8	29.1	33.7	36.6	38.0	36.1	33.7	31.4	23.0	17.8		(30)
(31)		5%	WB	8.1	10.3	12.4	14.2	16.7	17.8	17.7	17.1	15.1	14.3	11.8	7.9	(31)
(32)		MCDWB	14.3	17.4	22.2	28.1	33.7	36.2	37.3	35.4	32.9	30.0	21.4	15.8		(32)
(33)		10%	WB	6.8	9.2	11.6	13.6	15.9	17.0	16.9	16.1	14.4	13.4	10.9	6.7	(33)
(34)		MCDWB	12.8	16.1	21.5	26.9	32.6	35.1	36.0	34.5	32.1	27.7	19.7	14.3		(34)
(35)	Mean Daily Temperature Range		MDBR	12.6	12.4	13.0	12.9	13.4	12.4	11.0	11.1	14.4	15.2	14.1	14.3	(35)
(36)		5% DB	MCDBR	14.9	14.3	15.2	14.4	15.0	14.0	11.9	11.7	15.4	16.3	15.9	16.1	(36)
(37)		MCWBR	8.0	6.5	6.0	4.9	5.1	4.4	3.8	3.8	5.6	6.6	7.3	8.4	(37)	
(38)		5% WB	MCDBR	12.3	11.1	11.9	12.7	13.5	13.0	12.0	11.0	14.5	15.3	13.7	14.3	(38)
(39)		MCWBR	7.1	5.5	4.9	4.3	4.8	4.5	4.3	4.1	5.7	6.3	6.5	7.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.324	0.373	0.435	0.496	0.509	0.474	0.445	0.412	0.383	0.391	0.351	0.315	(40)	
(41)		taud	2.341	2.165	1.970	1.846	1.832	1.918	2.008	2.100	2.160	2.122	2.259	2.379	(41)	
(42)		Ebn at Noon	895	875	842	805	796	821	843	868	882	841	851	886	(42)	
(43)		Edh at Noon	102	134	176	207	211	193	176	158	143	138	110	93	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.56	4.33	5.49	6.50	7.36	8.18	8.03	7.61	6.62	5.23	3.96	3.40	(44)	
(45)		RadStd	0.26	0.29	0.31	0.29	0.31	0.23	0.16	0.19	0.14	0.16	0.18	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	+0.42	N/A	-3.50	+0.71	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page