

ABADAN, Iran, Islamic Republic of

WMO: 408310

Lat: 30.3772N

Lon: 48.2143E

Elev: 6

StdP: 101.25

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.1	5.8	-6.8	2.1	18.9	-4.3	2.6	19.7	10.1	16.9	8.7	16.4	1.3	270	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	48.2	22.6	47.2	22.6	46.1	22.2	29.0	35.2	27.7	35.1	26.2	35.9	4.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.8	32.5	25.9	21.2	32.4	23.8	18.7	31.7	94.9	34.9	88.9	34.3	81.6	35.5	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.4	9.1	8.0	DB	1.9	50.2	2.0	1.0	0.4	50.9	-0.8	51.5	-1.9	52.0	-3.4	52.7
			WB	0.3	30.3	2.1	1.4	-1.2	31.4	-2.4	32.2	-3.6	33.0	-5.1	34.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	13.2	15.8	20.7	26.1	32.7	36.5	38.0	37.7	33.9	28.5	19.9	14.9
	DBStd	9.36	3.03	3.16	3.03	3.12	2.75	1.98	1.83	1.66	2.39	2.97	3.66	3.25
	HDD10.0	12	8	2	0	0	0	0	0	0	0	0	0	3
	HDD18.3	389	160	79	12	1	0	0	0	0	0	0	24	114
	CDD10.0	6051	107	165	331	483	703	796	867	858	717	573	298	153
	CDD18.3	3386	1	9	84	233	445	546	609	600	467	314	72	6
	CDH23.3	53443	2	52	744	2650	7036	9579	10871	10499	7405	3945	627	33
CDH26.7	37692	0	4	241	1331	4756	7198	8396	8026	5213	2328	197	2	
Wind	WSAvg	3.2	2.5	3.0	3.2	3.3	3.5	4.7	4.4	3.5	3.2	2.5	2.2	2.4
Precipitation	PrecAvg	155	36	16	19	12	3	1	1	0	0	6	20	37
	PrecMax	287	119	64	84	68	25	28	13	1	0	77	89	118
	PrecMin	70	3	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	52	26	15	22	17	5	5	3	0	0	16	24	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	27.1	35.0	39.8	45.9	48.9	50.0	49.2	47.2	42.0	33.2	26.1
		MCWB	15.1	15.3	17.6	19.0	21.9	22.1	23.0	22.9	22.4	20.8	19.3	15.4
	2%	DB	21.5	24.9	31.2	36.9	43.8	47.1	48.5	48.1	45.2	39.9	31.0	24.1
		MCWB	14.6	14.4	16.3	18.7	21.0	21.8	22.7	22.9	22.0	20.7	18.0	15.8
	5%	DB	20.0	23.1	29.0	35.0	42.1	46.0	47.1	47.1	44.0	38.2	29.0	22.4
		MCWB	14.2	13.8	15.6	18.3	20.5	21.4	22.5	23.0	21.6	20.1	17.7	15.6
	10%	DB	18.8	21.8	27.2	33.1	40.6	44.8	46.0	46.0	42.3	36.7	27.0	20.9
		MCWB	13.6	13.4	15.1	17.9	20.3	21.1	22.3	22.7	21.1	19.9	17.7	15.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.3	18.2	20.1	22.7	24.4	26.7	29.4	30.7	29.5	27.2	24.1	20.1
		MCDB	20.7	22.3	26.5	31.4	34.8	36.6	35.6	35.1	34.2	31.4	27.1	22.7
	2%	WB	17.1	17.2	18.9	21.3	23.2	24.6	28.0	29.4	27.8	25.7	22.3	18.7
		MCDB	19.4	20.9	25.4	30.1	36.0	38.9	35.1	35.3	33.5	30.0	26.9	21.3
	5%	WB	15.8	16.2	17.9	20.4	22.4	23.2	26.2	28.3	26.1	24.7	20.6	17.5
		MCDB	18.4	20.0	24.9	29.4	36.0	40.6	37.5	35.7	34.4	29.4	25.8	20.2
	10%	WB	14.7	15.1	16.9	19.6	21.6	22.2	24.5	26.8	23.9	23.3	18.8	16.2
		MCDB	17.3	19.2	24.2	28.9	35.7	41.0	40.6	37.3	36.2	29.3	24.6	19.5
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.6	12.2	12.5	14.2	16.3	16.5	17.4	17.6	15.4	12.5	10.5
		MCDBR	10.8	12.0	14.7	14.9	16.2	17.5	17.6	18.3	18.6	17.4	14.5	12.4
		MCWBR	5.7	4.9	4.6	4.2	4.6	4.9	5.2	5.7	5.6	5.7	6.0	6.4
	5% WB	MCDBR	7.7	8.4	11.1	11.6	14.0	16.6	16.3	16.3	16.1	12.7	10.4	8.1
		MCWBR	5.4	5.0	4.9	4.5	4.8	5.4	6.4	6.9	6.9	6.2	5.7	5.7
Clear-Sky Solar Irradiance	taub		0.490	0.529	0.587	0.681	0.674	0.612	0.662	0.612	0.548	0.568	0.525	0.491
	taud		1.879	1.793	1.661	1.537	1.541	1.617	1.554	1.642	1.757	1.735	1.823	1.889
	Ebn at Noon		704	720	711	665	674	715	677	706	733	675	663	677
	Edh at Noon		167	198	242	283	284	262	278	252	216	207	175	158
All-Sky Solar Radiation	RadAvg		3.33	4.28	5.49	6.05	7.08	7.97	7.58	7.15	6.31	4.90	3.62	3.12
	RadStd		0.23	0.25	0.24	0.32	0.34	0.20	0.20	0.18	0.18	0.20	0.28	0.29

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.75	N/A	N/A	+0.96	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	+0.29	N/A	N/A	+0.44	N/A	N/A	N/A	N/A	+85	+83

Nomenclature: See separate page