

GACHSARAN, Iran, Islamic Republic ofWMO: **408350**Lat: **30.3466N**Lon: **50.8198E**Elev: **699**StdP: **93.20**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.7	3.0	-14.9	1.1	25.0	-11.6	1.5	29.3	7.3	12.3	6.2	12.8	0.2	270	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	44.4	18.5	43.5	18.4	42.4	18.3	23.5	35.4	22.3	35.6	21.2	36.0	3.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	15.9	31.6	17.8	13.9	31.0	15.9	12.3	28.2	74.4	34.8	69.2	35.5	65.0	35.8	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.5	5.7	-0.8	46.4	1.1	1.1	-1.6	47.2	-2.3	47.9	-2.9	48.5	-3.7	49.3		
			-2.0	25.4	1.3	1.2	-3.0	26.3	-3.8	27.0	-4.5	27.7	-5.4	28.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.2	10.8	12.8	16.8	21.7	28.4	32.7	34.7	34.3	30.6	25.0	17.4	12.9
	DBStd	8.94	2.94	3.20	3.28	3.16	2.67	1.84	1.73	1.53	2.06	2.54	3.21	2.67
	HDD10.0	43	26	10	1	0	0	0	0	0	0	0	0	6
	HDD18.3	691	235	156	68	7	0	0	0	0	0	0	55	170
	CDD10.0	4872	49	88	212	352	571	681	766	752	617	464	223	94
	CDD18.3	2478	0	1	21	109	313	431	508	494	367	206	28	1
	CDH23.3	40177	2	16	319	1359	4695	7508	9036	8563	5681	2645	331	22
	CDH26.7	26847	0	1	89	569	2904	5293	6592	6153	3759	1410	74	2
Wind	WSAvg	1.4	1.0	1.2	1.3	1.5	1.8	2.0	1.9	1.7	1.5	1.1	0.9	0.8
Precipitation	PrecAvg	732	195	102	103	53	8	0	2	2	3	7	75	168
	PrecMax	1084	509	258	302	113	50	4	8	13	25	38	317	522
	PrecMin	421	47	2	4	0	0	0	0	0	0	0	0	1
	PrecStd	143	86	62	69	31	12	1	2	4	6	11	72	110
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.8	25.2	32.5	36.2	41.9	44.6	46.1	45.4	42.9	37.8	30.5	25.9
		MCWB	10.7	12.6	14.0	15.7	17.2	18.1	19.1	18.2	17.8	16.4	14.0	12.2
	2%	DB	20.2	23.0	29.1	33.9	39.8	43.3	44.9	44.2	41.1	36.1	28.8	23.0
		MCWB	10.2	12.2	13.7	15.7	17.0	17.7	19.0	18.2	18.0	15.9	13.4	11.2
	5%	DB	18.5	21.2	26.8	31.9	38.1	42.1	43.8	43.1	39.9	34.9	27.1	21.0
		MCWB	10.0	11.3	13.2	15.0	16.5	17.6	18.8	18.3	17.7	15.8	13.0	10.8
	10%	DB	16.9	19.8	24.8	30.0	36.8	41.1	42.6	42.1	38.8	33.2	25.0	19.0
		MCWB	9.8	11.1	12.6	14.6	16.2	17.4	18.8	18.6	17.5	15.5	12.8	10.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	15.1	17.0	18.2	19.8	21.9	24.6	25.0	24.9	21.0	17.6	15.6
		MCDB	17.0	19.7	20.9	27.1	35.3	36.8	37.9	34.6	31.9	28.3	22.1	18.7
	2%	WB	13.1	13.8	15.7	17.1	18.4	20.2	23.1	23.6	22.7	19.1	16.5	14.1
		MCDB	16.1	18.6	21.1	26.6	34.4	37.9	37.8	35.2	32.4	29.7	21.6	18.5
	5%	WB	12.2	13.1	14.9	16.5	17.7	19.1	21.8	22.3	21.1	17.9	15.4	13.1
		MCDB	15.4	18.2	21.7	26.5	34.1	38.8	38.2	35.1	32.7	28.8	21.2	17.4
	10%	WB	11.1	12.2	14.0	15.9	17.1	18.3	20.7	21.2	19.7	16.9	14.5	12.2
		MCDB	15.1	17.5	22.4	26.3	33.4	38.6	38.0	36.0	33.9	29.0	21.1	16.5
Mean Daily Temperature Range	5% DB	MDBR	11.2	11.8	13.9	14.4	15.2	16.6	15.7	16.2	16.6	15.9	13.2	12.4
		MCDBR	14.0	14.5	17.0	16.7	16.8	18.1	17.1	17.3	17.3	17.2	15.9	15.7
		MCWBR	6.5	6.2	6.7	5.3	5.0	5.5	5.2	5.1	5.7	5.9	5.8	6.5
	5% WB	MCDBR	9.4	10.7	12.5	13.1	15.2	16.9	15.5	15.0	15.3	15.0	10.7	10.7
		MCWBR	5.6	5.5	6.2	5.0	4.7	5.8	6.1	5.8	6.5	5.9	5.1	5.3
Clear-Sky Solar Irradiance	taub	0.373	0.422	0.482	0.566	0.544	0.511	0.578	0.535	0.452	0.438	0.400	0.369	
	taud	2.176	2.024	1.857	1.708	1.762	1.831	1.716	1.807	1.976	2.001	2.112	2.201	
	Ebn at Noon	838	826	801	750	770	791	738	765	818	797	798	821	
	Edh at Noon	123	157	198	238	227	211	236	213	173	158	130	114	
All-Sky Solar Radiation	RadAvg	3.28	4.16	5.49	6.17	7.56	8.39	7.88	7.47	6.65	5.30	3.76	3.15	
	RadStd	0.24	0.33	0.38	0.44	0.25	0.17	0.19	0.20	0.14	0.21	0.32	0.34	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	-1.25	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page