

YASOGE, Iran, Islamic Republic of

WMO: 408360

Lat: 30.6979N

Lon: 51.5545E

Elev: 1837

StdP: 81.12

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.8	-3.9	-19.2	0.9	16.7	-16.2	1.1	14.6	8.2	7.0	6.7	8.0	0.4	90	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.2	36.2	15.1	35.2	14.6	34.2	14.2	18.0	31.2	16.7	30.9	15.7	30.2	3.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.0	11.7	25.3	11.1	10.3	22.8	9.9	9.5	20.2	58.5	31.5	54.1	30.8	50.8	30.2	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	8.1	6.7	5.7	DB	-9.0	38.4	2.7	1.0	-10.9	39.2	-12.5	39.8	-14.0	40.3	-16.0	41.1
(5)				WB	-10.2	19.8	2.3	1.5	-11.9	20.9	-13.2	21.8	-14.6	22.6	-16.2	23.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	3.7	5.7	9.7	13.5	19.1	24.3	26.9	25.9	22.1	16.7	9.7	5.7	(6)
		DBStd	8.44	3.18	2.95	2.99	2.70	2.59	1.88	1.65	1.54	1.82	2.33	3.01	3.02	
		HDD10.0	542	194	123	41	4	0	0	0	0	0	42	137	(8)	
		HDD18.3	1954	452	354	267	147	23	0	0	0	61	258	393	(9)	
		CDD10.0	2479	1	2	32	108	281	429	525	494	364	207	34	3	
		CDD18.3	851	0	0	0	1	45	179	267	236	114	9	0	0	
		CDH23.3	11430	0	0	7	41	751	2457	3426	2985	1482	281	1	0	
		CDH26.7	5831	0	0	0	2	220	1322	1955	1652	643	37	0	0	
(14)	Wind	WSAvg	1.6	1.3	1.8	2.0	2.0	1.9	1.7	1.8	1.7	1.6	1.6	1.3	1.1	(14)
(15)	Precipitation	PrecAvg	917	202	155	158	83	13	1	2	2	1	10	89	202	(15)
(16)		PrecMax	1369	527	337	387	202	55	8	9	18	10	75	379	776	(16)
(17)		PrecMin	451	64	21	22	1	0	0	0	0	0	0	2	(17)	(18)
(18)		PrecStd	212	95	94	101	55	18	2	2	4	2	17	87	150	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	16.3	18.1	24.1	26.9	32.2	36.6	38.1	37.0	34.1	29.1	22.8	18.6	(19)	
(20)		MCWB	6.0	7.1	10.1	10.7	12.6	14.6	16.3	16.2	13.5	12.2	8.3	6.8	(20)	
(21)		DB	14.0	15.9	21.1	24.2	30.7	35.2	37.0	35.9	32.9	27.8	20.9	15.8	(21)	
(22)		MCWB	5.2	5.8	8.6	10.6	12.4	14.1	15.3	15.2	13.2	11.6	8.3	5.6	(22)	
(23)		DB	11.9	13.8	18.9	22.8	29.1	34.1	35.9	34.9	31.8	26.3	19.0	13.8	(23)	
(24)		MCWB	4.4	5.1	7.5	10.1	11.8	13.7	14.9	14.6	13.0	10.8	7.6	5.1	(24)	
(25)		DB	9.9	12.0	16.9	20.9	27.7	33.0	34.8	33.9	30.5	24.9	16.9	11.9	(25)	
(26)		MCWB	3.5	4.6	6.5	9.3	11.5	13.4	14.6	14.2	12.6	10.2	6.9	4.4	(26)	
(27)		WB	8.0	8.8	11.6	13.2	14.8	17.6	20.2	19.5	17.6	14.7	11.0	9.0	(27)	
(28)		MCDB	13.4	14.6	20.2	20.0	26.7	32.4	32.8	33.9	30.9	26.9	17.6	12.7	(28)	
(29)		WB	6.6	7.6	9.9	12.1	13.7	16.2	18.3	17.8	15.2	12.9	10.0	7.4	(29)	
(30)		MCDB	10.4	12.3	16.0	20.1	25.9	31.9	31.3	30.9	27.9	24.9	15.4	11.8	(30)	
(31)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	5.7	6.7	8.9	11.3	13.0	15.0	16.7	16.7	14.1	11.5	9.1	6.5	(31)	
(32)		MCDB	9.3	11.1	15.4	18.9	25.5	31.0	31.5	30.0	27.7	23.1	15.0	10.7	(32)	
(33)		WB	4.6	5.7	8.0	10.6	12.4	14.1	15.8	15.6	13.2	10.7	8.1	5.6	(33)	
(34)		MCDB	8.5	9.7	13.7	17.8	24.6	30.5	30.8	29.5	27.7	21.8	14.4	10.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.5	11.6	13.0	13.2	15.8	17.7	16.2	16.8	17.5	16.1	13.4	12.3	(35)	
(36)		5% DB	14.6	14.9	16.6	16.2	17.8	18.6	17.6	17.8	18.1	17.6	16.5	15.5	(36)	
(37)		MCWBR	8.0	7.3	7.5	6.2	6.1	6.1	5.5	6.1	6.3	6.9	7.2	7.6	(37)	
(38)		5% WB	11.4	10.9	12.7	12.8	15.6	17.7	16.9	17.0	17.7	16.3	12.7	11.6	(38)	
(39)		MCWBR	7.2	6.1	6.9	5.8	5.7	6.7	6.3	6.8	7.3	7.1	6.1	6.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.293	0.344	0.408	0.492	0.479	0.453	0.507	0.464	0.391	0.374	0.330	0.293	(40)	
(41)		taud	2.370	2.203	1.995	1.814	1.872	1.946	1.834	1.934	2.118	2.146	2.291	2.395	(41)	
(42)		Ebn at Noon	939	911	870	809	822	839	792	823	876	864	882	920	(42)	
(43)		Edh at Noon	99	130	172	214	204	188	210	187	150	135	107	93	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.17	4.03	5.47	6.20	7.57	8.40	7.85	7.46	6.71	5.37	3.79	3.09	(44)	
(45)		RadStd	0.29	0.36	0.41	0.46	0.31	0.22	0.28	0.26	0.18	0.24	0.35	0.36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	-1.25	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page