

KERMAN, Iran, Islamic Republic of

WMO: 408410

Lat: 30.2496N

Lon: 56.9657E

Elev: 1748

StdP: 82.01

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -5.1	(d) -24.2	(e) 0.5	(f) 12.4	(g) -21.2	(h) 0.7	(i) 10.7	(j) 12.5	(k) 12.8	(l) 10.5	(m) 13.5	(n) 1.0	(o) 120	(p) 0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 16.5	(c) 38.1	(d) 15.7	(e) 37.0	(f) 15.2	(g) 36.0	(h) 14.9	(i) 17.5	(j) 34.4	(k) 16.7	(l) 34.0	(m) 16.0	(n) 33.6	(o) 4.3	(p) 60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
11.0	10.1	21.9	9.4	9.1	21.2	8.1	8.3	19.9	56.4	34.2	53.6	33.9	51.1	33.6	21.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.4	8.8	7.5	-11.6	39.7	2.9	1.1	-13.7	40.5	-15.4	41.1	-17.1	41.7	-19.2	42.5
			-12.8	18.7	2.3	1.5	-14.5	19.7	-15.8	20.6	-17.1	21.4	-18.7	22.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	5.4	8.0	12.3	17.2	22.2	26.5	27.8	25.1	22.3	17.3	10.5	6.5
	DBStd	8.31	3.93	3.92	3.41	3.07	2.79	2.54	2.20	2.46	2.28	2.60	3.51	3.42
	HDD10.0	395	147	78	17	1	0	0	0	0	0	0	37	116
	HDD18.3	1594	400	290	188	57	3	0	0	0	2	52	235	367
	CDD10.0	2877	6	21	88	215	377	494	551	469	370	226	52	8
	CDD18.3	1034	0	0	1	22	122	244	292	211	122	19	0	0
	CDH23.3	16879	0	3	62	427	1854	3849	4550	3387	2110	608	27	1
	CDH26.7	9054	0	0	11	92	838	2272	2769	1899	1019	153	1	0
(14) Wind	WSAvg	3.0	2.6	3.2	3.6	3.5	3.4	3.4	3.5	3.3	2.8	2.4	2.2	2.1
(15) Precipitation	PrecAvg	131	23	28	27	14	5	1	2	2	0	2	8	18
	PrecMax	222	58	90	68	39	50	4	25	15	3	25	29	67
	PrecMin	28	0	1	0	0	0	0	0	0	0	0	0	0
	PrecStd	44	14	24	20	12	11	1	5	3	1	5	9	21
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	23.1	28.0	30.8	36.1	39.0	39.2	38.8	35.3	31.2	25.9	22.5
		MCWB	6.5	8.8	10.3	12.1	14.3	15.2	16.3	16.1	14.4	12.7	9.7	7.8
	2%	DB	18.1	20.2	24.9	29.1	34.1	37.9	38.2	36.9	34.1	29.9	23.9	19.1
		MCWB	6.2	7.8	9.3	11.7	13.6	15.2	16.0	15.6	13.7	12.4	9.6	6.6
	5%	DB	16.1	18.1	22.9	27.8	32.9	36.8	37.2	35.2	33.1	28.3	22.0	17.2
		MCWB	5.6	7.0	8.7	11.4	13.2	14.8	15.5	14.9	13.5	11.7	8.9	6.1
	10%	DB	14.1	16.2	21.0	26.1	31.1	35.3	36.2	34.1	32.0	27.0	20.0	15.6
		MCWB	4.9	6.0	7.9	10.8	12.8	14.3	15.3	14.5	13.2	11.2	8.2	5.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	10.3	11.9	13.9	15.8	17.2	19.0	18.4	16.6	14.3	12.0	9.6
		MCDB	15.1	18.2	21.0	25.3	31.6	34.3	35.8	34.0	33.1	28.5	22.8	16.5
	2%	WB	7.8	9.2	10.8	13.0	14.8	16.6	17.9	17.1	15.4	13.4	10.7	8.3
		MCDB	13.9	16.1	20.6	24.9	31.5	34.5	34.9	33.2	32.0	28.1	20.3	15.2
	5%	WB	6.8	8.2	9.9	12.2	14.1	15.8	17.1	16.2	14.5	12.5	9.7	7.4
		MCDB	13.4	14.8	19.4	24.4	30.2	34.1	34.5	33.1	31.2	27.1	19.3	14.5
	10%	WB	5.8	7.3	9.1	11.5	13.4	15.1	16.2	15.4	13.7	11.7	8.8	6.4
		MCDB	12.8	14.3	18.3	23.5	28.9	33.5	34.0	32.5	30.3	25.5	17.9	13.6
(35) Mean Daily Temperature Range	MDBR		15.2	14.4	15.2	15.4	16.7	17.1	16.5	18.2	19.2	18.8	17.5	16.7
	5% DB	MCDBR	18.7	17.3	18.3	17.7	18.6	18.1	17.8	18.4	20.1	20.1	20.2	20.4
		MCWBR	10.0	8.6	8.4	7.2	7.1	7.0	7.1	7.5	9.1	9.6	10.4	11.1
	5% WB	MCDBR	14.0	13.1	14.7	15.1	17.1	16.8	15.8	17.3	18.7	19.0	16.8	15.4
		MCWBR	8.2	7.2	7.1	6.4	7.0	6.9	6.9	7.8	9.3	9.6	9.1	8.8
(40) Clear-Sky Solar Irradiance	taub		0.281	0.326	0.378	0.450	0.475	0.473	0.456	0.416	0.387	0.377	0.315	0.282
	taud		2.494	2.347	2.149	1.962	1.914	1.928	1.998	2.107	2.167	2.176	2.408	2.507
	Ebn at Noon		962	937	904	847	825	822	835	867	882	864	909	943
	Edh at Noon		89	113	148	185	195	192	178	158	143	132	96	84
(44) All-Sky Solar Radiation	RadAvg		3.65	4.38	5.64	6.50	7.30	8.02	7.83	7.58	6.63	5.39	4.12	3.52
	RadStd		0.29	0.34	0.36	0.37	0.35	0.33	0.23	0.29	0.21	0.22	0.23	0.29

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page