

SHIRAZ SHAHID DASTGHAIB INTL, Iran, Islamic Republic of

WMO: 408480

Lat: 29.539N Lon: 52.589E Elev: 4920 StdP: 12.26 Time Zone: 3.50 (IRN) Period: 94-19 WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.1	30.4	3.2	7.8	64.9	8.2	10.1	62.3	21.1	52.1	18.0	52.7	0.7	300	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.4	102.6	63.0	100.8	62.1	99.1	61.5	68.2	94.7	66.5	93.9	64.8	92.9	6.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.8	89.0	86.2	55.6	79.0	82.0	53.4	72.8	78.3	35.6	94.1	34.0	93.9	32.6	92.6	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.5	16.5	13.6	DB	23.7	105.5	3.0	1.9	21.5	106.9	19.8	108.0	18.1	109.0	15.9	110.4	(4)
(5)			WB	20.8	70.0	2.6	3.9	18.9	72.9	17.3	75.2	15.8	77.4	13.9	80.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	44.0	48.3	55.1	63.6	74.0	82.3	86.5	84.3	77.3	67.6	54.5	46.7	(6)	
	DBStd	15.46	4.98	5.12	4.93	5.23	4.62	3.16	3.02	2.92	3.64	4.06	5.28	4.56	(7)	
	HDD50	426	193	83	12	0	0	0	0	0	0	0	18	120	(8)	
	HDD65	2417	651	467	307	87	3	0	0	0	0	21	315	566	(9)	
	CDD50	6071	7	36	171	409	745	969	1132	1064	820	546	153	19	(10)	
	CDD65	2588	0	0	1	46	283	519	667	599	370	102	1	0	(11)	
	CDH74	39601	0	0	73	647	3831	8128	10785	9297	5228	1573	39	0	(12)	
	CDH80	22782	0	0	8	126	1761	4910	6974	5773	2758	472	0	0	(13)	
(14) Wind	WSAvg	4.1	3.1	4.0	5.1	5.2	5.6	5.1	4.8	4.2	3.8	3.3	2.8	2.4	(14)	
(15) Precipitation	PrecAvg	14.3	3.7	2.7	2.2	1.1	0.2	0.0	0.0	0.0	0.0	0.2	1.3	2.7	(15)	
	PrecMax	26.1	9.8	8.3	5.8	4.5	1.6	0.1	0.1	0.4	0.0	1.2	4.3	11.8	(16)	
	PrecMin	5.4	0.5	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
	PrecStd	4.4	2.2	2.1	1.6	1.1	0.4	0.0	0.0	0.1	0.0	0.3	1.5	2.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.9	70.1	80.6	86.3	97.2	102.6	105.7	104.0	98.6	89.6	77.4	69.4	(19)	
		MCWB	45.7	48.5	52.9	56.2	59.8	61.9	64.4	65.0	59.7	56.1	51.9	48.5	(20)	
	2%	DB	61.2	66.2	75.3	83.8	93.6	100.6	103.9	101.8	96.5	87.5	75.0	64.5	(21)	
		MCWB	44.0	47.0	50.7	55.6	58.6	60.8	63.7	62.9	59.6	55.6	50.6	46.6	(22)	
	5%	DB	58.8	62.9	71.6	80.7	91.5	98.8	102.2	100.1	94.7	85.4	71.7	61.1	(23)	
		MCWB	43.7	45.5	49.4	54.4	57.8	60.3	62.9	62.0	59.0	54.8	50.5	45.3	(24)	
	10%	DB	55.4	60.4	68.1	77.4	89.3	97.0	100.5	98.3	92.8	82.5	68.0	58.7	(25)	
		MCWB	42.3	44.7	48.2	53.3	57.0	59.7	62.3	61.6	58.4	54.1	49.1	44.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.2	52.6	56.6	59.4	62.4	68.7	70.7	70.6	65.5	58.5	55.7	52.3	(27)	
		MCDB	56.4	61.4	67.9	77.5	90.1	97.2	96.8	94.3	91.8	82.3	69.3	60.8	(28)	
	2%	WB	47.6	50.5	54.3	57.7	60.7	64.6	68.2	68.3	62.9	57.2	53.9	50.1	(29)	
		MCDB	55.7	58.9	65.1	76.2	88.4	94.2	95.9	93.5	89.7	81.6	66.4	57.6	(30)	
	5%	WB	45.9	48.9	52.5	56.4	59.4	62.6	66.6	66.6	61.2	56.2	52.2	48.5	(31)	
		MCDB	53.3	57.3	63.8	74.4	86.5	93.3	95.2	92.7	87.9	79.9	65.3	56.8	(32)	
	10%	WB	44.4	47.3	50.7	55.2	58.2	61.1	65.0	64.8	59.8	55.2	50.8	46.7	(33)	
		MCDB	52.0	55.9	63.4	72.4	84.7	92.2	94.5	91.0	86.9	78.3	63.7	55.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	22.1	24.2	25.0	27.7	29.8	28.4	29.0	30.7	29.8	25.2	23.1	(35)	
		MCDBR	26.8	26.9	29.8	28.7	31.1	31.8	30.2	30.2	31.6	31.7	29.7	27.7	(36)	
	5% WB	MCWBR	14.1	12.8	12.7	10.7	10.9	10.4	9.4	9.4	10.4	11.1	12.6	14.0	(37)	
		MCWBR	20.1	19.5	23.3	25.2	28.5	30.1	28.0	28.6	30.3	29.4	23.9	21.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.314	0.366	0.421	0.495	0.482	0.470	0.524	0.481	0.412	0.382	0.342	0.310	(40)	
		taud	2.362	2.180	1.990	1.834	1.876	1.911	1.809	1.904	2.064	2.142	2.282	2.388	(41)	
	Ebn at Noon		292	283	273	257	260	262	247	257	272	273	278	288	(42)	
		Edh at Noon	32	43	55	67	64	62	69	62	50	44	35	30	(43)	
(44) All-Sky Solar Radiation	RadAvg		1150	1399	1814	2054	2432	2617	2454	2341	2087	1738	1275	1102	(44)	
	RadStd		90	111	130	121	93	67	63	70	57	67	93	95	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	-2.25	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	-2.25	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A