

BAFT, Iran, Islamic Republic ofWMO: **408530**Lat: **29.233N**Lon: **56.583E**Elev: **7480**StdP: **11.13**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.1	27.0	-4.4	5.7	45.0	-0.8	6.9	43.5	30.2	36.9	26.1	46.4	5.9	0	0.481

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	91.7	57.5	89.9	56.9	88.2	56.3	62.0	81.8	60.6	81.4	59.3	81.7	10.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.1	85.7	72.6	52.2	76.8	74.6	49.3	69.0	74.8	31.9	81.6	30.7	80.8	29.6	81.2	68.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	27.4	23.0	20.4	DB	17.6	95.2	4.3	1.9	14.5	96.6	12.0	97.8	9.6	98.8	6.5	100.2
(5)				WB	14.1	63.4	3.4	2.3	11.6	65.1	9.7	66.4	7.8	67.7	5.3	69.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.2	39.9	42.6	50.1	58.7	68.3	77.5	79.4	76.9	71.9	62.1	50.1	43.9
	DBStd	14.73	5.69	5.95	5.40	5.30	4.88	3.31	2.97	3.10	3.32	4.30	5.26	5.31
	HDD50	862	313	216	65	5	0	0	0	0	0	0	64	199
	HDD65	3299	778	628	461	198	24	0	0	0	1	110	446	653
	CDD50	4590	1	9	69	264	567	826	913	832	656	374	69	10
	CDD65	1551	0	0	0	7	126	376	448	367	208	19	0	0
	CDH74	14427	0	0	4	40	977	3865	4569	3261	1576	135	0	0
	CDH80	5187	0	0	0	0	183	1581	1959	1140	321	3	0	0
Wind	WSAvg	8.2	7.4	8.6	8.2	8.7	9.2	8.6	9.8	10.5	8.1	6.7	6.2	6.5
Precipitation	PrecAvg	10.0	2.2	1.9	2.0	1.0	0.3	0.1	0.2	0.3	0.1	0.2	0.5	1.2
	PrecMax	16.1	4.2	7.8	6.7	3.7	2.2	0.9	0.7	2.2	0.4	1.1	2.5	5.9
	PrecMin	5.0	0.5	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.5	1.1	1.6	1.5	0.9	0.5	0.2	0.2	0.5	0.1	0.3	0.6	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.7	65.0	73.0	77.3	87.2	92.9	94.4	92.5	87.4	80.1	70.5	66.0
		MCWB	39.4	44.4	46.7	50.5	54.2	57.1	59.1	57.5	55.0	52.2	46.4	43.8
	2%	DB	56.9	60.3	67.5	75.1	84.2	90.9	92.3	89.8	85.4	77.3	67.7	61.2
		MCWB	38.8	41.7	44.5	49.8	53.7	56.9	58.2	56.5	54.7	51.3	45.6	40.8
	5%	DB	53.7	56.8	64.5	72.7	82.0	89.3	90.5	87.7	83.6	75.2	64.7	58.1
		MCWB	37.7	40.2	43.6	48.7	53.2	56.4	57.5	55.8	53.9	50.4	44.8	39.2
	10%	DB	50.5	53.4	61.3	70.0	79.8	87.6	88.7	85.8	81.8	72.9	61.8	55.0
		MCWB	36.4	38.2	42.3	47.6	52.3	55.9	57.0	55.0	53.2	49.6	43.6	38.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.6	46.1	49.2	52.8	57.1	63.8	64.2	63.3	59.7	55.4	51.2	45.1
		MCDB	50.5	58.6	61.4	72.7	80.1	87.0	83.8	76.5	81.2	74.3	65.5	60.7
	2%	WB	41.8	44.2	47.1	51.3	55.7	61.1	62.2	61.2	57.8	53.9	48.0	42.8
		MCDB	48.7	53.9	58.8	70.2	79.7	81.1	82.7	79.7	79.7	72.4	60.0	55.3
	5%	WB	39.9	42.6	45.7	50.2	54.5	59.4	61.0	59.5	56.5	52.5	46.3	41.4
		MCDB	48.3	51.6	57.5	68.2	78.5	82.3	82.4	80.2	78.6	71.1	59.6	52.6
	10%	WB	38.4	41.0	44.4	48.9	53.2	57.7	59.8	58.2	55.1	51.0	44.8	39.8
		MCDB	47.8	49.1	56.3	65.8	76.8	83.4	82.3	80.2	77.7	69.6	59.0	50.8
Mean Daily Temperature Range	5% DB	MDBR	18.0	18.1	19.0	18.2	19.7	19.7	18.5	18.7	19.9	20.7	20.0	19.6
		MCDBR	21.9	22.6	22.9	20.3	21.1	20.9	20.4	19.9	20.9	21.5	23.0	23.3
		MCWBR	11.5	10.9	10.0	8.2	8.0	7.3	6.9	7.2	7.6	8.8	10.8	11.5
	5% WB	MCDBR	15.9	16.0	17.2	18.3	20.4	19.6	18.7	19.5	20.3	20.5	19.2	18.4
		MCWBR	9.8	8.6	8.4	7.8	8.3	7.6	7.3	7.4	8.3	9.4	10.0	10.2
Clear-Sky Solar Irradiance	taub	0.261	0.305	0.351	0.411	0.430	0.460	0.476	0.438	0.393	0.354	0.289	0.261	
	taud	2.538	2.403	2.228	2.059	2.021	1.952	1.937	2.037	2.139	2.244	2.481	2.557	
	Ebn at Noon	315	306	296	280	274	265	260	269	279	284	301	311	
	Edh at Noon	27	34	43	53	56	59	60	54	47	39	29	25	
All-Sky Solar Radiation	RadAvg	1193	1412	1821	2103	2335	2449	2320	2290	2026	1725	1352	1164	
	RadStd	102	125	134	119	122	136	106	122	93	75	75	98	

Historical Trends

	DBAvg	Heating		Cooling
--	-------	---------	--	---------