

BANDAR BUSHEHR, Iran, Islamic Republic of

WMO: 408570

Lat: 28.9036N

Lon: 50.8208E

Elev: 8

StdP: 101.23

Time Zone: 3.50 (IRN)

Period: 97-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	10.5	1.0	4.1	11.6	3.1	4.7	13.0	14.5	17.1	12.0	16.8	3.1	30	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	38.2	29.8	37.4	29.8	36.7	29.6	32.0	36.2	31.5	35.7	31.0	35.3	4.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
31.0	28.9	35.3	30.5	28.0	35.0	30.0	27.2	34.8	111.2	36.3	108.6	35.8	106.2	35.3	34.2

Extreme Annual Design Conditions

Extreme Annual WS							Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature											
							Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years					
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max						
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)							
12.1	10.3	9.0	DB	6.6	40.9	1.7	1.8	5.4	42.2	4.4	43.2	3.5	44.2	2.3	45.5							
			WB	4.1	32.9	1.9	0.7	2.7	33.4	1.6	33.8	0.6	34.2	-0.8	34.7							

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.5	15.4	16.6	20.3	24.8	29.8	31.4	33.5	33.9	31.9	28.2	22.4	17.7
	DBStd	6.94	2.69	2.67	2.44	2.77	2.06	1.56	1.36	1.33	1.71	1.93	2.82	2.77
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	217	97	61	8	0	0	0	0	0	0	0	4	47
	CDD10.0	5672	168	184	318	445	614	642	729	742	658	564	371	237
	CDD18.3	2847	6	11	68	195	356	392	471	483	408	306	124	26
	CDH23.3	38996	5	18	192	1500	4759	5832	7592	8004	6428	3849	775	42
CDH26.7	22793	0	1	16	397	2391	3437	5112	5524	4038	1732	144	2	
Wind	WSAvg	3.5	3.5	4.0	3.7	3.6	3.7	3.8	3.7	3.5	3.4	3.1	3.4	3.3
Precipitation	PrecAvg	265	84	29	20	5	1	0	0	1	0	7	46	64
	PrecMax	609	234	84	138	19	14	0	2	12	1	77	214	248
	PrecMin	129	2	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	107	65	26	27	5	3	0	0	2	0	16	55	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	25.3	28.4	35.0	37.5	37.6	39.8	39.2	38.2	35.8	30.9	26.2
		MCWB	18.2	17.7	19.5	21.6	23.5	27.2	29.7	30.5	29.8	27.6	24.2	20.1
	2%	DB	22.1	23.2	26.5	32.2	35.3	36.1	38.1	38.2	37.0	34.3	29.3	24.4
		MCWB	17.8	17.3	19.5	22.0	24.6	27.4	29.8	30.7	29.4	26.8	23.3	19.5
	5%	DB	20.8	21.6	25.3	30.2	34.1	35.1	37.1	37.6	36.2	33.2	28.3	23.3
		MCWB	17.1	17.0	19.2	21.9	24.8	27.6	29.9	30.5	29.1	26.3	22.5	19.0
	10%	DB	19.7	20.5	24.2	28.8	33.1	34.2	36.2	36.8	35.5	32.2	27.3	22.4
		MCWB	16.2	16.6	18.9	21.8	24.7	27.3	29.6	30.4	28.8	26.0	21.6	18.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	19.5	21.9	25.2	28.4	30.2	32.3	33.1	31.8	29.7	25.8	21.6
		MCDB	22.0	22.8	25.6	30.1	33.2	34.4	36.6	37.1	36.4	33.5	29.4	24.6
	2%	WB	18.6	18.6	20.8	24.4	27.3	29.5	31.7	32.2	31.1	28.6	24.6	20.7
		MCDB	21.2	21.4	24.9	29.1	32.6	33.9	35.8	36.4	35.7	32.8	28.4	23.6
	5%	WB	17.6	17.9	20.1	23.6	26.6	28.9	31.2	31.7	30.5	27.8	23.6	19.7
		MCDB	20.4	20.6	24.2	28.4	32.0	33.4	35.3	36.0	35.0	32.0	27.4	22.7
	10%	WB	16.6	17.1	19.5	22.7	26.0	28.2	30.7	31.3	29.9	27.1	22.3	18.6
		MCDB	19.2	20.0	23.3	27.6	31.5	32.9	34.8	35.5	34.4	31.4	26.4	21.7
Mean Daily Temperature Range	5% DB	MDBR	6.0	5.6	5.8	6.1	5.7	4.8	4.9	5.3	6.4	7.3	7.0	6.7
		MCDBR	6.8	6.6	7.2	8.0	7.6	6.6	6.7	6.4	6.8	7.9	7.8	7.5
		MCWBR	5.2	4.7	5.0	5.5	5.8	5.1	5.1	4.2	4.7	5.8	5.8	5.5
	5% WB	MCDBR	6.2	5.8	6.4	6.6	6.1	5.9	5.9	5.7	6.4	7.1	7.0	6.6
		MCWBR	5.3	4.6	5.0	5.9	5.8	5.4	4.6	3.9	4.6	5.5	5.8	5.4
Clear-Sky Solar Irradiance	taub		0.461	0.507	0.564	0.640	0.627	0.594	0.664	0.625	0.539	0.512	0.480	0.450
	taud		2.016	1.903	1.762	1.655	1.678	1.747	1.654	1.742	1.887	1.931	2.005	2.056
	Ebn at Noon		750	751	736	698	709	729	678	700	748	736	724	739
	Edh at Noon		148	180	220	253	248	230	252	229	192	172	149	137
All-Sky Solar Radiation	RadAvg		3.56	4.38	5.62	6.36	7.57	8.28	7.78	7.39	6.62	5.35	3.86	3.35
	RadStd		0.26	0.33	0.36	0.39	0.22	0.18	0.19	0.17	0.13	0.19	0.32	0.33

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	-1.25	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A