

BANDAR BUSHEHR AP, Iran, Islamic Republic ofWMO: **408580**Lat: **28.9625N**Lon: **50.8194E**Elev: **21**StdP: **101.08**Time Zone: **3.50 (IRN)**Period: **05-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.8	10.0	-0.2	3.7	15.0	1.2	4.1	15.4	12.7	18.4	11.2	17.5	2.2	30	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	39.2	26.4	38.2	27.2	37.8	27.4	31.0	35.9	30.4	35.4	29.7	35.0	5.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
29.9	27.2	35.0	29.1	25.8	34.4	28.2	24.5	34.0	105.3	35.8	101.8	35.4	98.7	35.2	33.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.2	8.1	DB	6.0	42.7	1.2	1.7	5.2	44.0	4.5	44.9	3.8	45.9	2.9	47.1	(4)
(5)			WB	3.7	31.9	1.6	0.8	2.6	32.5	1.6	33.0	0.7	33.5	-0.5	34.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	15.4	16.9	20.4	25.1	30.0	32.0	33.6	34.1	32.1	28.2	21.9	17.1	
	DBStd	7.11	3.00	3.17	2.81	2.98	2.10	1.74	1.47	1.20	1.67	2.27	2.89	2.57	
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	228	99	59	11	0	0	0	0	0	0	0	4	55	
	CDD10.0	5699	168	193	323	454	620	660	732	747	662	563	356	220	
	CDD18.3	2885	9	19	76	204	362	410	473	488	412	305	110	17	
	CDH23.3	40526	19	68	359	1791	4959	6358	7719	8077	6483	3888	763	42	
CDH26.7	24311	1	11	83	600	2632	3978	5240	5597	4116	1881	168	4		
Wind	WSAvg	3.4	3.6	3.8	3.8	3.5	3.7	3.8	3.5	3.0	2.9	2.6	3.1	3.3	
Precipitation	PrecAvg	265	84	29	20	5	1	0	0	1	0	7	46	64	
	PrecMax	609	234	84	138	19	14	0	2	12	1	77	214	248	
	PrecMin	129	2	0	0	0	0	0	0	0	0	0	0	0	
	PrecStd	107	65	26	27	5	3	0	0	2	0	16	55	59	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	28.1	31.6	36.1	39.8	40.0	41.2	40.1	39.0	36.2	31.9	26.2	
		MCWB	15.5	16.1	17.0	18.4	21.9	24.4	24.3	27.4	27.1	24.9	22.2	18.0	
	2%	DB	23.2	25.2	29.0	33.8	37.0	38.0	39.1	39.1	37.9	35.0	30.1	24.2	
		MCWB	16.1	15.7	17.1	19.0	21.6	25.0	26.4	27.7	27.7	25.0	21.8	17.5	
	5%	DB	21.9	23.1	26.9	31.8	35.1	36.8	38.0	38.2	37.0	34.0	28.6	23.0	
		MCWB	16.3	16.1	17.1	19.6	22.8	25.6	27.1	28.5	27.5	25.2	21.1	17.1	
	10%	DB	20.2	21.8	25.1	29.9	34.0	35.8	37.0	37.8	36.2	32.9	27.2	21.8	
		MCWB	15.4	15.9	17.3	20.0	23.1	25.7	27.5	28.6	27.2	24.5	20.3	16.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.6	19.6	20.6	23.8	28.0	30.0	31.2	32.1	31.0	28.2	25.1	20.4
			MCDB	21.9	22.6	25.6	29.2	33.3	35.3	36.1	36.8	36.2	33.1	29.9	24.2
2%		WB	17.6	18.3	19.6	22.7	26.6	28.9	30.3	31.3	30.1	27.3	23.4	19.1	
		MCDB	21.2	22.0	24.8	28.1	32.6	34.6	35.4	36.2	35.6	32.4	28.2	22.6	
5%		WB	16.9	17.4	18.9	22.0	25.8	28.0	29.6	30.7	29.3	26.7	22.3	18.0	
		MCDB	20.2	21.1	24.1	27.6	32.0	33.7	34.9	35.7	34.9	31.9	27.2	21.9	
10%		WB	15.9	16.5	18.3	21.2	24.9	27.2	28.9	30.2	28.7	26.1	21.1	17.1	
		MCDB	19.4	20.3	23.5	27.2	31.3	33.4	34.6	35.2	34.4	31.4	26.2	20.7	
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.3	8.0	8.4	8.0	7.3	7.2	7.5	8.5	9.1	8.1	7.5	
		MCDBR	9.1	9.4	10.8	11.0	10.3	9.4	8.9	8.2	8.7	9.5	9.8	9.6	
		MCWBR	5.7	5.0	5.4	5.3	6.1	6.1	5.6	5.0	5.4	5.9	6.4	5.9	
	5% WB	MCDBR	7.9	7.6	8.7	8.5	8.2	8.3	7.7	7.4	8.5	9.0	9.0	8.0	
		MCWBR	5.6	4.9	5.5	5.5	6.1	6.0	5.4	4.9	5.7	6.1	6.4	5.5	
Clear-Sky Solar Irradiance	taub	0.459	0.505	0.562	0.638	0.624	0.592	0.662	0.623	0.536	0.510	0.478	0.447		
	taud	2.019	1.906	1.765	1.656	1.680	1.748	1.654	1.743	1.888	1.931	2.006	2.059		
	Ebn at Noon	752	753	738	699	711	730	679	701	750	737	726	741		
	Edh at Noon	148	179	220	252	247	230	252	229	191	172	148	136		
All-Sky Solar Radiation	RadAvg	3.56	4.38	5.62	6.36	7.58	8.29	7.79	7.40	6.62	5.35	3.85	3.35		
	RadStd	0.26	0.32	0.36	0.39	0.21	0.18	0.18	0.17	0.13	0.19	0.32	0.33		