

BANDAR UDARA FASA, Iran, Islamic Republic of

WMO: 408590

Lat: 28.8989N

Lon: 53.7195E

Elev: 1288

StdP: 86.78

Time Zone: 3.50 (IRN)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.2	-0.2	-15.1	1.2	12.0	-12.2	1.5	12.0	9.0	12.1	7.7	13.6	0.7	330	0.437

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	40.9	18.1	40.0	17.8	39.1	17.7	21.1	35.1	20.0	35.4	19.2	35.4	3.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	13.5	29.8	14.2	11.8	28.9	12.8	10.8	25.6	67.8	35.7	63.7	35.1	60.4	35.3	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.2	6.1	-3.9	42.6	1.2	0.7	-4.7	43.1	-5.5	43.6	-6.2	44.0	-7.0	44.5		
(5)			-5.8	22.3	1.4	1.8	-6.8	23.6	-7.6	24.7	-8.4	25.7	-9.4	27.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	8.0	10.0	13.9	18.4	24.6	29.3	31.3	29.9	26.2	20.7	13.8	9.8
	DBStd	8.48	2.42	2.63	2.60	2.82	2.61	1.86	1.58	1.60	1.96	2.27	2.87	2.44
	HDD10.0	139	71	29	2	0	0	0	0	0	0	0	3	33
	HDD18.3	1131	321	233	138	33	1	0	0	0	0	4	137	263
	CDD10.0	3686	9	29	124	252	453	579	659	617	486	332	117	28
	CDD18.3	1637	0	0	2	36	196	329	401	358	236	79	1	0
	CDH23.3	26053	1	2	119	677	2939	5368	6515	5577	3424	1330	98	3
	CDH26.7	16273	0	0	23	213	1667	3638	4442	3691	2067	528	5	0
Wind	WSAvg	1.9	1.3	1.7	2.0	2.2	2.6	2.2	2.3	2.2	1.8	1.6	1.3	1.2
Precipitation	PrecAvg	291	83	51	50	18	3	0	1	2	1	1	18	54
	PrecMax	580	257	167	149	95	30	6	7	8	7	14	86	248
	PrecMin	110	8	2	2	0	0	0	0	0	0	0	0	0
	PrecStd	111	57	46	39	23	7	1	2	3	1	3	23	71
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.2	23.0	29.2	32.2	38.2	41.2	42.2	41.2	38.2	34.0	27.2	23.1
		MCWB	9.1	10.9	13.2	14.8	16.0	17.8	18.2	17.9	16.5	14.6	12.2	10.5
	2%	DB	18.2	20.9	26.2	30.7	36.9	40.2	41.1	40.1	37.1	32.4	25.9	20.9
		MCWB	7.9	9.9	12.0	14.3	15.8	17.4	18.4	17.6	16.5	14.4	12.0	9.9
	5%	DB	16.8	19.1	24.1	29.1	35.5	39.6	40.2	39.1	36.1	31.2	24.2	19.0
		MCWB	7.4	9.2	11.1	13.7	15.4	17.3	18.2	17.5	16.2	14.1	11.7	8.8
	10%	DB	14.9	17.2	22.1	27.4	34.1	38.5	39.4	38.1	35.1	29.9	22.2	17.1
		MCWB	7.1	8.4	10.4	13.3	15.0	17.0	18.2	17.4	15.9	13.9	10.7	8.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	12.5	14.9	16.5	17.4	21.1	23.5	22.5	19.1	16.7	14.3	12.7
		MCDB	14.7	18.8	22.3	27.0	34.3	37.8	37.6	34.5	34.2	29.2	21.4	18.0
	2%	WB	10.4	11.5	13.8	15.6	16.6	19.7	21.2	21.2	18.1	15.6	13.3	11.2
		MCDB	14.1	16.8	20.2	26.1	33.5	36.3	35.8	33.6	34.1	29.6	21.9	16.4
	5%	WB	9.4	10.7	12.9	14.9	16.1	18.7	20.2	19.9	17.2	14.8	12.5	10.5
		MCDB	13.3	15.7	19.6	25.6	32.7	35.9	36.2	33.5	33.9	29.0	21.0	15.7
	10%	WB	8.4	9.8	12.1	14.2	15.6	17.7	19.4	18.9	16.5	14.2	11.7	9.7
		MCDB	13.0	14.9	18.8	24.4	31.9	36.3	36.1	34.6	33.4	28.3	19.8	14.9
Mean Daily Temperature Range	5% DB	MDBR	13.5	13.9	15.5	16.3	17.7	18.5	16.5	16.9	18.2	17.9	15.7	14.7
		MCDBR	16.6	16.6	18.9	18.4	18.9	19.2	17.6	17.8	18.5	18.8	18.0	17.2
		MCWBR	8.7	8.1	8.3	6.9	6.9	7.0	6.3	6.5	7.2	8.0	8.7	8.5
	5% WB	MCDDBR	11.9	12.3	13.7	16.1	18.0	18.1	16.2	16.4	17.7	17.8	15.2	13.6
		MCWBR	7.0	6.8	7.0	6.4	6.6	7.4	6.4	6.4	7.3	7.9	7.7	7.3
Clear-Sky Solar Irradiance	taub		0.314	0.366	0.414	0.475	0.466	0.471	0.527	0.485	0.420	0.381	0.336	0.309
	taud		2.381	2.202	2.031	1.894	1.922	1.918	1.813	1.912	2.056	2.160	2.318	2.404
	Ebn at Noon		925	896	871	828	834	825	778	809	853	866	888	913
	Edh at Noon		101	132	168	199	194	194	215	193	161	136	107	95
All-Sky Solar Radiation	RadAvg		3.84	4.58	5.77	6.59	7.61	8.04	7.52	7.20	6.48	5.49	4.17	3.62
	RadStd		0.24	0.35	0.43	0.36	0.25	0.22	0.17	0.23	0.17	0.18	0.24	0.26

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	-1.25	N/A	+0.52	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page