

BANDAR ABBASS INTL, Iran, Islamic Republic ofWMO: **408750**Lat: **27.2154N**Lon: **56.3732E**Elev: **33**StdP: **14.68**Time Zone: **3.50 (IRN)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.4	51.5	14.1	11.3	69.6	22.4	16.9	66.4	22.1	68.3	18.9	68.0	4.2	0	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	107.7	75.9	104.4	78.1	102.3	79.0	88.2	96.0	87.3	95.2	86.9	94.8	10.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
86.3	192.7	93.6	85.8	189.6	93.3	84.6	181.9	93.0	53.9	96.9	52.7	94.8	52.0	95.4	96.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.7	17.1	15.4	43.1	113.4	2.3	1.9	41.5	114.8	40.2	115.9	38.9	117.0	37.3	118.4		
			DB													
			WB	36.5	90.0	3.4	1.3	34.0	90.9	32.0	91.6	30.0	92.3	27.5	93.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.9	63.9	67.4	72.7	80.6	88.2	92.6	94.1	93.0	90.1	84.9	75.3	67.3
	DBStd	11.20	4.04	4.16	3.90	3.96	3.03	2.73	2.14	2.28	2.14	3.15	4.40	4.17
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	117	69	21	1	0	0	0	0	0	0	0	0	26
	CDD50	11277	431	487	705	918	1183	1277	1367	1332	1202	1082	758	535
	CDD65	5919	35	88	241	468	718	827	902	867	752	617	308	96
	CDH74	84979	171	457	1876	5535	10903	13568	14877	14094	11627	8199	2907	765
	CDH80	52093	3	54	500	2628	6668	9256	10413	9631	7346	4466	1029	99
Wind	WSAvg	7.6	6.4	7.2	7.6	8.0	8.2	8.3	8.8	8.6	7.8	6.9	6.9	6.5
Precipitation	PrecAvg	6.5	1.9	1.2	1.4	0.2	0.0	0.0	0.1	0.0	0.0	0.2	0.3	1.1
	PrecMax	15.1	5.8	7.2	6.7	3.0	0.0	0.4	1.8	0.1	0.3	2.6	2.0	6.8
	PrecMin	1.3	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.6	1.7	1.6	2.0	0.6	0.0	0.1	0.4	0.0	0.0	0.6	0.4	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.0	84.6	91.7	100.4	107.7	111.5	110.9	109.5	105.8	102.2	93.3	85.9
		MCWB	61.7	65.6	68.4	70.5	73.9	75.1	73.7	76.0	73.4	70.2	65.8	61.9
	2%	DB	77.3	81.0	87.8	96.7	103.0	107.5	106.0	105.6	102.2	98.5	89.8	82.5
		MCWB	64.1	65.9	67.4	71.3	74.4	75.7	78.1	78.6	74.9	72.1	69.8	62.9
	5%	DB	75.6	78.7	84.6	93.6	100.5	104.2	102.6	102.1	99.4	96.1	87.9	80.5
		MCWB	63.2	65.5	67.8	71.7	75.5	78.5	82.1	82.5	79.4	75.8	71.2	64.3
	10%	DB	73.9	76.8	82.4	91.4	98.5	101.8	100.3	99.0	97.1	93.6	85.9	78.6
		MCWB	62.0	65.1	68.2	72.3	76.0	79.5	83.5	84.5	81.8	77.6	70.7	63.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.0	71.8	74.7	79.6	84.5	88.1	89.2	89.7	87.3	85.3	82.1	72.8
		MCDB	75.5	78.0	83.4	88.4	93.9	96.8	97.3	97.1	95.4	93.3	86.7	79.3
	2%	WB	68.5	70.0	72.9	77.7	82.9	86.8	88.2	88.2	86.5	83.8	77.9	70.6
		MCDB	74.7	76.6	81.1	87.5	92.2	95.2	96.1	95.8	94.4	91.7	84.9	77.3
	5%	WB	66.9	68.9	71.7	76.4	81.7	85.7	87.5	87.3	85.5	82.6	76.0	68.9
		MCDB	73.3	75.6	80.0	86.5	91.2	94.2	95.4	95.1	93.3	90.6	83.7	75.7
	10%	WB	65.1	67.5	70.5	75.2	80.6	84.9	87.0	86.8	84.8	81.3	74.4	67.0
		MCDB	71.5	74.2	78.7	85.6	90.6	93.8	94.9	94.5	92.8	89.5	82.0	74.4
Mean Daily Temperature Range	5% DB	MDBR	19.7	18.2	17.9	19.2	19.8	17.2	12.6	12.4	14.9	18.6	20.3	21.9
		MCDBR	20.6	19.7	21.9	23.7	24.0	23.5	18.7	19.4	20.4	22.1	21.6	23.6
		MCWBR	11.8	10.4	10.3	10.0	10.2	11.1	10.1	10.0	10.5	11.3	11.4	12.6
	5% WB	MCDBR	16.7	16.0	17.8	19.2	18.9	15.2	12.1	12.6	14.0	16.0	16.5	18.6
		MCWBR	10.8	9.6	9.8	9.5	8.9	8.4	6.6	6.8	7.5	8.8	9.9	11.5
Clear-Sky Solar Irradiance	taub	0.422	0.487	0.543	0.576	0.582	0.638	0.716	0.678	0.597	0.509	0.434	0.409	
	taud	2.146	1.964	1.825	1.777	1.773	1.700	1.599	1.667	1.785	1.943	2.134	2.189	
	Ebn at Noon	256	247	241	238	236	222	205	211	224	237	249	254	
	Edh at Noon	42	55	66	71	72	77	85	79	68	55	42	39	
All-Sky Solar Radiation	RadAvg	1236	1470	1823	2149	2416	2461	2282	2181	1985	1718	1362	1185	
	RadStd	80	116	122	102	50	60	64	73	41	34	44	74	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days		
--	-------	---------	--	--	---------	--	--	-------------	--	--