

SARAVAN, Iran, Islamic Republic ofWMO: **408780**Lat: **27.3898N**Lon: **62.3184E**Elev: **3921**StdP: **12.73**Time Zone: **3.50 (IRN)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.2	35.1	-12.3	3.3	52.8	-6.3	4.5	51.1	23.2	61.7	20.5	56.7	6.6	320	0.447

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	105.3	63.3	103.6	63.0	101.8	62.3	72.2	86.8	71.1	86.4	69.8	86.8	9.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.1	119.6	81.9	66.1	111.4	83.2	63.5	101.6	84.1	38.9	86.2	37.9	86.0	36.6	86.3	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	18.8	16.8	25.9	108.3	2.5	2.0	24.2	109.7	22.7	110.8	21.3	111.9	19.5	113.4		
(5)			18.6	74.2	2.0	1.4	17.2	75.2	16.1	76.0	15.0	76.7	13.6	77.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.7	51.3	56.0	65.4	75.4	84.0	89.8	91.4	88.3	82.0	73.4	61.6	52.9
	DBStd	15.08	5.96	7.49	5.94	5.51	4.29	3.79	2.71	2.83	3.69	4.68	6.27	5.72
	HDD50	125	57	28	0	0	0	0	0	0	0	0	3	37
	HDD65	1273	424	262	69	5	0	0	0	0	0	2	135	376
	CDD50	8409	97	195	477	761	1055	1193	1283	1188	960	724	350	126
	CDD65	4084	0	9	81	316	590	743	818	723	510	262	32	0
	CDH74	59224	6	124	924	3627	8413	11804	12932	10932	6944	3040	444	34
	CDH80	35267	0	15	246	1621	4968	7743	8574	6873	3927	1238	60	2
Wind	WSAvg	7.2	7.0	7.8	7.2	7.4	7.4	8.2	7.4	6.8	6.6	6.3	6.4	7.4
Precipitation	PrecAvg	4.3	0.7	0.7	0.8	0.3	0.2	0.3	0.2	0.2	0.0	0.2	0.2	0.4
	PrecMax	11.1	3.6	2.8	2.4	1.9	0.9	4.6	1.8	2.3	0.3	1.5	1.8	2.7
	PrecMin	0.6	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.3	0.8	0.8	0.7	0.5	0.2	0.9	0.5	0.5	0.1	0.4	0.4	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.3	82.1	89.6	97.5	104.3	107.9	107.2	105.0	100.2	95.1	84.7	78.6
		MCWB	50.2	54.5	55.6	59.2	61.9	63.7	64.6	62.9	60.3	58.4	53.8	51.2
	2%	DB	71.1	78.0	85.7	94.1	101.3	105.5	105.2	102.5	98.4	92.5	81.6	73.6
		MCWB	49.9	53.2	55.2	58.3	61.2	62.8	64.1	61.8	59.6	58.0	53.8	49.7
	5%	DB	68.2	73.9	82.5	91.6	98.9	103.8	103.7	100.8	96.6	89.6	79.1	70.2
		MCWB	48.5	51.8	54.1	57.7	60.7	62.7	63.6	61.3	58.9	57.4	53.3	48.7
	10%	DB	65.1	70.1	79.1	88.8	96.9	101.6	101.9	99.1	94.6	86.8	76.2	67.1
		MCWB	47.3	50.0	52.8	57.0	60.0	61.9	63.2	60.9	58.2	56.1	52.5	47.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.9	56.8	60.4	62.1	67.2	73.0	73.7	73.2	68.6	65.6	60.5	54.6
		MCDB	65.2	73.3	77.7	84.4	85.6	87.5	88.9	86.8	83.9	80.0	72.6	66.1
	2%	WB	52.9	55.5	58.5	60.8	64.6	71.1	72.4	71.7	66.1	62.7	58.7	52.7
		MCDB	64.6	69.8	75.9	83.6	87.9	86.2	87.8	84.5	83.0	80.9	71.4	66.0
	5%	WB	51.3	54.0	56.9	59.8	63.1	69.5	71.5	70.0	64.0	60.4	56.7	51.0
		MCDB	62.9	68.3	74.5	83.9	89.8	87.0	86.9	85.1	84.1	79.5	71.9	66.1
	10%	WB	49.8	52.4	55.5	58.7	62.0	67.4	70.5	67.8	61.6	58.6	54.6	49.2
		MCDB	61.7	66.5	71.7	83.9	90.4	88.8	87.2	86.6	87.3	81.4	71.9	64.8
Mean Daily Temperature Range	5% DB	MDBR	23.4	23.1	23.1	22.5	22.9	22.3	21.8	22.5	25.1	25.1	24.6	25.8
		MCDBR	29.1	27.9	27.8	26.2	25.5	25.2	23.8	23.9	26.6	27.3	28.6	31.6
		MCWBR	15.0	12.5	10.2	9.5	8.6	8.4	8.2	8.7	9.9	11.4	13.2	16.0
	5% WB	MCDBR	21.4	21.1	22.0	22.3	23.7	22.7	22.1	22.1	25.4	23.8	21.9	26.1
		MCWBR	12.1	9.8	8.8	8.3	8.0	8.7	7.8	7.7	9.6	9.2	9.4	13.5
Clear-Sky Solar Irradiance	taub	0.323	0.370	0.422	0.482	0.520	0.520	0.554	0.494	0.425	0.396	0.338	0.310	
	taud	2.398	2.234	2.047	1.917	1.834	1.838	1.785	1.903	2.048	2.127	2.338	2.427	
	Ebn at Noon	292	285	275	262	251	249	241	255	271	272	284	292	
	Edh at Noon	32	41	53	62	67	67	70	62	52	45	34	30	
All-Sky Solar Radiation	RadAvg	1327	1560	1914	2204	2360	2462	2340	2290	2120	1800	1478	1285	
	RadStd	83	105	94	100	75	100	82	76	48	41	43	67	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page