

IRAN SHAHR, Iran, Islamic Republic of

WMO: 408790

Lat: 27.2298N

Lon: 60.7181E

Elev: 1939

StdP: 13.70

Time Zone: 3.50 (IRN)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	40.7	44.1	-3.8	4.8	57.4	1.8	6.5	60.9	20.4	64.5	16.4	67.1	3.6	0	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	114.5	69.0	112.8	68.8	111.2	68.5	77.4	98.1	76.5	97.7	75.4	97.9	10.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	126.0	91.4	69.7	117.6	94.5	67.6	109.2	95.1	42.7	97.9	41.7	97.0	40.5	97.7	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.2	16.8	14.3	34.4	117.9	3.6	1.1	31.8	118.7	29.7	119.4	27.7	120.0	25.1	120.8		
			26.2	79.1	3.2	1.1	23.9	79.9	22.1	80.6	20.3	81.2	18.0	82.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	59.3	64.0	72.5	82.6	92.8	99.2	100.3	97.3	92.1	83.0	70.4	61.7	(6)
(7)		DBStd	15.40	5.47	6.60	5.69	5.57	4.18	3.65	2.93	3.05	3.54	4.64	5.98	5.62	(7)
(8)		HDD50	12	5	3	0	0	0	0	0	0	0	0	0	4	(8)
(9)		HDD65	432	187	88	8	0	0	0	0	0	0	0	21	128	(9)
(10)		CDD50	11455	293	394	698	977	1325	1477	1561	1465	1264	1023	612	366	(10)
(11)		CDD65	6398	9	59	240	527	860	1027	1096	1000	814	558	183	25	(11)
(12)		CDH74	105039	129	602	2689	7431	14790	18624	19740	17700	13513	7591	1905	325	(12)
(13)		CDH80	73487	10	153	1149	4358	10462	14321	15278	13252	9369	4419	675	41	(13)
(14)	Wind	WSAvg	5.9	4.5	5.2	5.3	6.1	6.6	7.4	7.6	7.2	6.4	5.2	4.6	4.4	(14)
(15)	Precipitation	PrecAvg	4.6	0.9	0.9	0.9	0.2	0.1	0.2	0.3	0.4	0.0	0.1	0.1	0.6	(15)
(16)		PrecMax	9.6	6.5	3.5	3.0	0.9	0.2	3.3	3.0	1.8	0.5	1.2	0.8	3.9	(16)
(17)		PrecMin	0.9	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.4	1.2	1.0	0.8	0.2	0.1	0.6	0.6	0.4	0.1	0.3	0.2	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.7	88.5	97.0	104.3	113.0	116.7	116.4	114.4	109.8	103.9	91.8	84.4	(19)
(20)		MCWB	55.0	59.2	60.6	64.7	67.0	69.0	69.4	68.5	67.5	65.4	60.5	57.2	(20)	
(21)		2%	DB	77.1	84.5	93.0	101.8	110.3	114.7	114.3	111.6	107.6	100.8	89.5	80.5	(21)
(22)		MCWB	55.6	58.1	59.9	64.0	66.9	69.1	69.1	68.2	66.4	64.8	60.0	55.8	(22)	
(23)		5%	DB	74.9	80.8	89.7	98.9	107.9	112.9	112.8	110.1	105.9	98.5	87.1	77.4	(23)
(24)		MCWB	54.3	56.8	59.2	63.5	66.6	68.9	69.0	67.8	65.8	63.7	59.4	54.8	(24)	
(25)		10%	DB	71.9	77.2	86.3	96.6	105.9	111.1	111.1	108.7	104.0	95.7	84.2	75.1	(25)
(26)		MCWB	53.2	55.3	58.3	62.9	66.2	68.5	69.1	67.5	65.5	62.8	58.4	54.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.4	63.3	65.7	70.6	74.7	78.2	78.9	78.2	76.0	71.1	65.8	61.7	(27)
(28)		MCDWB	72.9	75.1	78.7	92.9	100.3	97.8	100.0	98.6	98.1	91.7	82.6	71.6	(28)	
(29)		2%	WB	58.5	61.0	64.1	67.0	70.3	76.3	77.6	77.0	73.7	68.7	63.8	59.7	(29)
(30)		MCDWB	70.9	75.7	79.1	93.4	101.3	97.3	98.6	96.7	96.1	91.8	82.1	73.0	(30)	
(31)		5%	WB	57.1	59.3	62.6	65.4	68.5	74.8	76.8	75.8	72.1	66.7	62.1	57.9	(31)
(32)		MCDWB	69.5	73.9	76.9	92.8	101.1	98.2	98.0	96.7	95.4	91.5	80.9	72.9	(32)	
(33)		10%	WB	55.4	57.8	61.2	64.2	67.3	73.2	75.8	74.5	70.5	65.0	60.3	56.2	(33)
(34)		MCDWB	68.7	73.0	77.1	91.4	100.7	101.3	98.6	97.2	95.2	91.0	79.4	71.6	(34)	
(35)	Mean Daily Temperature Range		MDBR	22.7	22.7	23.5	24.3	24.8	23.6	22.1	23.8	24.8	25.2	24.4	24.5	(35)
(36)		5% DB	MCDBR	26.0	26.2	27.8	26.6	26.2	25.0	23.3	24.5	25.5	26.2	25.7	26.8	(36)
(37)			MCWBR	13.4	11.8	11.0	10.1	9.3	9.8	9.6	10.2	10.6	11.3	12.4	14.0	(37)
(38)			MCDBR	19.8	20.3	20.8	24.0	24.2	21.6	20.1	20.8	21.8	22.8	21.4	21.2	(38)
(39)		5% WB	MCWBR	11.4	9.7	8.4	9.7	9.3	9.0	8.1	8.3	8.7	10.3	10.7	11.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.348	0.400	0.455	0.507	0.536	0.557	0.585	0.535	0.469	0.427	0.361	0.332	(40)	
(41)		taud	2.365	2.185	1.997	1.889	1.835	1.807	1.775	1.867	1.988	2.092	2.316	2.407	(41)	
(42)		Ebn at Noon	283	275	266	255	247	240	233	245	258	262	276	284	(42)	
(43)		Edh at Noon	34	43	56	64	67	69	71	64	55	47	35	31	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1308	1534	1900	2213	2402	2470	2347	2282	2082	1785	1461	1271	(44)	
(45)		RadStd	85	110	109	96	65	85	80	81	49	39	43	67	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page