

KISH INTL, Iran, Islamic Republic ofWMO: **408820**Lat: **26.5316N**Lon: **53.9603E**Elev: **98**StdP: **14.64**Time Zone: **3.50 (IRN)**Period: **03-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	58.7	60.4	33.8	28.5	67.7	38.8	34.8	69.8	27.6	65.0	25.1	65.3	7.7	300	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	103.6	78.2	101.1	80.3	100.1	81.1	88.7	94.4	87.8	93.9	87.1	93.3	10.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
87.8	202.8	92.0	86.4	193.4	91.1	86.0	190.9	90.9	54.6	93.9	53.4	94.1	52.4	92.9	94.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.8	21.6	18.6	DB	55.7	108.4	3.0	2.2	53.6	109.9	51.9	111.2	50.2	112.4	48.1	114.0	
(5)			WB	45.9	90.4	2.8	1.5	43.9	91.5	42.3	92.3	40.7	93.2	38.7	94.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	67.2	68.8	73.3	80.4	87.3	90.6	93.5	94.0	91.3	86.8	78.7	71.2
	DBStd	9.98	3.21	3.50	3.45	4.02	3.35	2.70	2.10	1.69	1.87	2.41	3.89	3.41
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	23	15	6	0	0	0	0	0	0	0	0	0	2
	CDD50	11676	534	525	723	911	1155	1219	1348	1365	1238	1140	862	656
	CDD65	6226	85	112	258	461	690	769	883	900	788	675	412	193
	CDH74	80890	99	264	1224	4370	9281	11497	14159	14545	12140	9130	3573	608
	CDH80	47585	1	22	216	1667	5040	7188	9695	10081	7820	4765	1048	42
(14) Wind	WSAvg	8.6	8.4	9.5	10.5	10.3	9.9	8.9	8.2	7.8	7.4	7.1	7.4	7.6
(15) Precipitation	PrecAvg	7.8	1.8	1.3	1.4	0.3	0.1	0.1	0.2	0.1	0.1	0.1	0.7	1.7
	PrecMax	19.2	5.5	6.4	5.6	1.3	0.3	0.4	1.7	0.4	0.3	0.6	3.8	7.7
	PrecMin	2.7	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.7	1.3	1.3	1.6	0.3	0.1	0.1	0.3	0.1	0.0	0.2	0.9	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.6	82.6	88.0	96.8	103.8	105.6	106.0	106.0	102.1	98.7	91.1	82.8
		MCWB	67.4	64.8	66.4	69.9	71.4	74.2	76.9	77.2	77.0	76.2	72.1	68.0
	2%	DB	76.7	79.2	84.5	93.4	100.0	102.0	102.5	102.4	100.1	95.7	89.3	80.8
		MCWB	65.7	65.8	67.2	69.4	72.5	78.0	80.5	81.3	80.1	78.2	72.3	67.5
	5%	DB	75.1	77.1	82.4	91.1	97.0	99.0	100.7	100.6	98.4	94.6	87.6	79.0
		MCWB	64.6	65.4	68.1	70.4	74.3	79.7	82.2	82.7	82.2	78.6	72.6	66.1
	10%	DB	73.4	75.1	80.3	88.0	95.0	97.2	98.9	98.9	96.8	93.0	85.9	77.3
		MCWB	63.1	64.5	67.7	70.8	75.2	80.3	83.2	83.9	83.3	78.9	72.2	65.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.3	71.1	74.1	78.6	84.1	87.5	89.1	90.0	90.6	87.5	78.5	73.8
		MCDB	75.2	76.0	81.1	85.6	90.7	95.2	95.9	95.5	94.8	91.4	86.0	79.3
	2%	WB	68.4	69.3	72.3	76.5	82.3	86.2	88.0	88.8	88.2	84.5	77.0	71.3
		MCDB	73.3	74.5	78.5	84.3	88.7	92.7	94.5	94.4	93.8	90.7	84.8	77.2
	5%	WB	66.9	68.1	71.0	75.0	81.1	85.2	87.3	87.9	86.9	82.9	75.8	69.7
		MCDB	72.3	73.3	77.0	83.2	87.8	91.7	93.6	93.9	93.0	89.3	83.4	75.7
	10%	WB	65.5	66.9	69.9	73.8	79.9	84.4	86.7	87.2	85.9	81.7	74.5	68.3
		MCDB	71.2	72.3	75.7	81.8	87.2	91.1	93.1	93.4	92.0	88.5	82.3	74.0
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	11.2	12.4	14.3	16.0	14.8	12.4	11.6	11.9	12.6	11.3	10.8
		MCDBR	11.7	13.0	15.3	17.9	18.9	16.9	14.9	13.7	13.6	14.0	12.4	12.3
		MCWBR	6.7	7.2	7.6	8.1	8.9	8.8	8.6	7.9	7.3	7.2	6.3	6.5
	5% WB	MCDBR	10.9	11.7	13.1	15.4	16.1	14.7	12.6	11.8	11.7	12.5	11.7	11.1
		MCWBR	7.4	7.3	7.4	8.1	8.0	7.6	7.1	6.5	6.6	6.9	6.2	6.8
(40) Clear-Sky Solar Irradiance	taub	0.434	0.498	0.557	0.598	0.584	0.609	0.701	0.668	0.582	0.503	0.447	0.429	
	taud	2.138	1.957	1.813	1.757	1.781	1.766	1.640	1.713	1.841	1.991	2.139	2.158	
	Ebn at Noon	253	245	238	233	236	228	208	214	229	240	246	248	
	Edh at Noon	43	55	67	73	71	72	81	75	64	53	43	40	
(44) All-Sky Solar Radiation	RadAvg	1273	1539	1861	2177	2490	2557	2412	2245	2069	1775	1376	1195	
(45)	RadStd	88	123	148	137	63	46	57	43	28	33	68	97	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	+1.62	+2.36	N/A	+0.99	N/A	N/A	N/A	-9	+623	+617