

FUJAIRAH INTL, United Arab Emirates

WMO: 411980

Lat: 25.112N

Lon: 56.324E

Elev: 152

StdP: 14.62

Time Zone: 4.00 (E04)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	60.4	62.3	28.4	22.4	87.1	33.5	28.2	86.8	28.0	71.7	24.6	71.3	8.2	300	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.4	109.2	71.4	105.8	72.5	102.6	73.6	89.1	93.9	88.1	93.6	87.2	93.3	14.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
88.1	205.3	92.1	87.4	200.4	91.9	86.0	191.2	92.1	55.0	94.1	53.9	92.6	52.4	93.1	94.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.0	21.1	17.8	55.9	115.7	2.6	2.8	54.1	117.7	52.6	119.3	51.1	120.8	49.2	122.9		
(5)			46.4	90.1	2.4	1.7	44.7	91.4	43.3	92.4	42.0	93.4	40.3	94.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.0	69.8	71.7	76.5	85.0	93.2	95.3	94.0	92.2	90.4	87.0	79.3	72.9
	DBStd	9.80	3.23	3.58	4.18	5.22	4.82	4.03	3.35	3.25	2.48	3.18	3.55	3.41
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	7	4	2	0	0	0	0	0	0	0	0	0	1
	CDD50	12410	613	607	823	1051	1338	1359	1364	1308	1211	1146	879	711
	CDD65	6941	151	189	358	601	873	909	899	843	761	681	429	247
	CDH74	94816	403	740	2690	7835	14045	15038	14515	13181	11448	9625	4100	1196
	CDH80	57789	26	96	720	4051	9596	10718	10051	8717	7128	5282	1268	136
(14) Wind	WSAvg	7.2	7.9	8.1	8.3	8.7	9.1	7.4	6.7	6.1	5.6	5.7	6.4	7.1
(15) Precipitation	PrecAvg	4.8	0.7	0.9	1.1	0.3	0.1	0.0	0.2	0.0	0.1	0.2	0.3	0.7
	PrecMax	17.6	3.8	3.2	5.8	1.9	0.7	0.2	2.4	0.1	0.3	2.2	2.4	9.7
	PrecMin	1.5	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.7	0.9	0.6	1.5	0.4	0.2	0.0	0.4	0.0	0.1	0.4	0.5	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.1	86.4	95.4	104.1	111.5	114.6	111.3	108.1	104.3	100.8	92.9	86.0
		MCWB	64.0	63.9	66.6	67.8	70.3	71.5	73.1	74.5	74.2	70.7	69.1	65.5
	2%	DB	79.2	82.6	89.5	100.1	107.8	109.3	105.8	103.8	100.1	97.2	89.6	82.8
		MCWB	65.2	65.3	64.7	67.6	69.9	71.9	75.8	76.3	76.2	73.3	71.7	66.8
	5%	DB	77.3	80.3	86.1	96.8	104.3	105.7	102.1	100.2	97.1	95.0	87.7	81.0
		MCWB	65.1	66.1	65.8	68.6	69.2	73.2	77.8	80.5	78.3	74.5	72.6	67.5
	10%	DB	75.9	78.2	83.9	93.5	100.8	102.4	98.9	97.1	95.1	93.1	86.0	79.2
		MCWB	64.6	66.4	66.8	69.0	70.2	74.4	81.7	83.2	80.3	76.1	72.7	67.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.5	74.4	78.2	81.5	87.0	90.4	90.9	89.7	89.6	84.9	79.2	74.7
		MCDB	75.8	77.8	81.6	86.7	91.9	95.0	95.1	94.0	93.2	90.4	85.7	79.2
	2%	WB	70.2	72.5	76.1	79.3	84.9	88.3	89.3	88.2	87.3	83.3	77.7	72.4
		MCDB	75.8	77.1	80.6	86.6	92.3	94.3	94.0	93.7	91.9	90.0	85.4	78.7
	5%	WB	68.8	71.0	74.1	77.7	83.5	87.0	88.3	87.3	85.8	81.9	76.0	71.0
		MCDB	75.0	76.4	79.6	86.0	91.7	94.0	93.7	93.4	91.4	89.4	84.5	77.7
	10%	WB	67.1	69.6	72.5	76.2	82.2	85.9	87.4	86.6	84.6	80.6	74.5	69.4
		MCDB	74.1	75.6	78.6	85.4	90.7	93.6	93.4	93.0	90.9	88.9	83.4	76.6
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	12.4	13.1	14.4	14.7	12.4	9.1	9.0	10.2	12.1	12.3	12.6
		MCDBR	13.3	14.7	16.5	18.0	18.8	18.5	14.9	14.5	14.3	14.7	13.3	13.5
		MCWBR	8.3	10.1	12.1	13.1	14.8	16.1	14.1	12.6	12.3	14.0	9.9	8.3
	5% WB	MCDBR	11.7	11.6	12.2	14.2	13.6	12.2	9.4	9.7	10.2	10.6	11.2	11.8
		MCWBR	8.9	10.1	12.0	13.9	14.8	13.1	8.7	8.2	8.8	11.3	9.3	8.3
(40) Clear-Sky Solar Irradiance	taub		0.443	0.504	0.563	0.599	0.599	0.662	0.745	0.703	0.609	0.519	0.461	0.444
	taud		2.130	1.952	1.807	1.751	1.749	1.657	1.561	1.631	1.772	1.945	2.101	2.121
	Ebn at Noon		253	245	238	233	232	217	199	207	223	237	245	246
	Edh at Noon		44	56	68	74	74	80	88	82	69	56	45	43
(44) All-Sky Solar Radiation	RadAvg		1300	1541	1830	2094	2334	2359	2178	2082	1949	1719	1397	1231
	RadStd		89	113	126	136	61	65	68	64	35	37	37	76

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	+0.85	+1.26	N/A	N/A	N/A	N/A	N/A	N/A	+270	+268

Nomenclature: See separate page