

DIBBA, Oman

WMO: 412420

Lat: 25.6157N

Lon: 56.2473E

Elev: 33

StdP: 14.68

Time Zone: 4.00 (E04)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.0	57.6	33.0	27.6	82.5	37.4	32.8	82.8	22.0	69.6	18.8	72.0	1.9	220	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.6	107.4	73.8	104.3	74.6	101.8	75.5	89.3	95.0	88.2	93.8	87.3	93.2	10.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
88.0	204.0	93.2	87.0	197.1	92.6	85.9	190.3	92.2	55.3	95.2	53.8	93.9	52.6	93.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.6	16.7	14.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			45.6	88.3	3.0	2.4	43.4	90.0	41.7	91.4	40.0	92.7	37.8	94.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	68.0	69.8	75.1	83.0	91.6	94.1	93.8	91.9	89.5	85.1	76.9	70.8		
	DBStd	10.15	3.30	3.97	3.91	4.62	4.45	3.56	2.73	2.76	2.38	3.37	3.60	3.71		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	21	11	8	0	0	0	0	0	0	0	0	0	2		
	CDD50	11876	558	554	779	989	1289	1323	1357	1300	1186	1088	808	645		
	CDD65	6423	104	142	314	539	824	873	892	835	736	623	358	183		
	CDH74	88562	294	607	2509	6749	13136	14355	14453	13005	10939	8315	3248	952		
	CDH80	53584	6	71	653	3339	8732	10035	9989	8541	6648	4438	1047	85		
(14) Wind	WSAvg	5.4	5.3	6.0	6.6	6.7	6.6	6.0	5.3	5.3	4.5	4.0	4.0	4.5		
(15) Precipitation	PrecAvg	5.2	1.0	1.0	1.3	0.2	0.0	0.0	0.1	0.0	0.0	0.2	0.3	0.9		
	PrecMax	12.4	3.9	4.7	5.9	1.1	0.1	0.2	1.5	0.1	0.5	1.9	2.4	6.6		
	PrecMin	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	3.4	1.1	1.0	1.4	0.4	0.0	0.0	0.3	0.0	0.1	0.4	0.6	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.0	85.9	91.9	101.7	110.7	113.2	110.5	108.0	104.2	100.3	90.9	84.4		
		MCWB	65.8	65.6	66.7	69.1	71.6	75.5	75.2	74.9	72.1	72.2	71.5	66.7		
	2%	DB	78.7	81.9	87.8	96.9	105.2	107.5	105.0	103.5	100.2	96.7	88.8	82.2		
		MCWB	66.4	65.5	66.1	68.9	69.5	73.4	77.5	78.3	75.4	74.5	72.8	68.2		
	5%	DB	77.1	79.4	85.5	94.5	102.5	104.1	101.2	99.9	97.6	94.7	87.3	80.6		
		MCWB	65.0	66.6	66.8	68.4	70.3	76.2	80.4	80.7	77.9	76.2	72.9	68.9		
	10%	DB	75.6	77.5	83.6	92.0	100.1	101.3	98.8	97.3	95.4	93.0	85.8	79.0		
		MCWB	63.7	65.9	67.7	68.8	71.2	77.5	82.9	83.1	80.4	77.2	72.4	67.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.6	73.0	77.7	80.3	87.0	90.3	89.9	89.4	87.8	85.3	78.6	75.0		
		MCDB	77.2	77.7	81.6	88.4	93.4	96.2	96.5	95.5	93.0	91.5	85.8	80.2		
	2%	WB	69.5	71.4	75.9	78.3	85.1	89.0	89.8	88.0	86.5	83.5	77.0	73.2		
		MCDB	76.0	76.8	80.4	86.6	91.9	95.0	95.3	93.4	91.8	90.1	85.4	78.5		
	5%	WB	67.7	70.0	73.8	76.4	83.4	87.9	88.6	87.1	85.4	82.1	75.5	71.3		
		MCDB	74.9	75.8	79.7	85.6	91.0	94.0	94.1	92.8	90.8	89.3	84.5	77.0		
	10%	WB	65.8	68.4	72.1	74.6	81.8	86.6	87.5	86.0	84.5	80.8	74.1	69.5		
		MCDB	73.5	75.1	79.2	84.7	90.6	93.6	93.2	92.3	90.1	88.7	82.9	75.8		
(35) Mean Daily Temperature Range	MDBR		14.2	14.5	15.6	14.9	15.9	13.6	10.3	10.4	12.5	16.1	16.4	15.3		
	5% DB	MCDBR	15.8	16.6	17.9	17.8	19.4	18.9	15.6	16.5	17.2	17.3	17.0	16.1		
		MCWBR	8.4	9.3	10.0	10.1	12.0	12.5	9.8	9.7	10.1	10.3	9.3	8.4		
	5% WB	MCDBR	15.2	14.3	15.5	15.7	14.6	13.0	10.6	11.0	11.4	14.3	16.2	14.2		
		MCWBR	9.3	9.6	11.5	11.0	12.2	10.4	5.3	6.2	6.4	8.9	10.0	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.478	0.552	0.617	0.649	0.647	0.711	0.796	0.755	0.662	0.569	0.495	0.475		
	taud		2.014	1.830	1.689	1.648	1.651	1.573	1.486	1.547	1.667	1.824	1.995	2.019		
	Ebn at Noon		240	231	224	221	221	206	189	196	210	223	232	234		
	Edh at Noon		49	63	76	82	81	87	95	89	77	62	49	47		
(44) All-Sky Solar Radiation	RadAvg		1258	1502	1801	2082	2328	2356	2174	2072	1927	1693	1365	1192		
	RadStd		91	119	128	128	56	56	58	62	32	33	40	79		

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days				
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (13 neighbors)	+0.72	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	+216	+209	(47)

Nomenclature: See separate page