

NIZWA, Oman

WMO: 412550

Lat: 22.8591N

Lon: 57.5463E

Elev: 1516

StdP: 13.91

Time Zone: 4.00 (E04)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 52.0	(c) 54.8	(d) 16.0	(e) 13.1	(f) 86.7	(g) 19.8	(h) 15.7	(i) 86.9	(j) 17.9	(k) 77.3	(l) 15.1	(m) 73.6	(n) 1.4	(o) 30	(p) 0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 23.4	(c) 112.6	(d) 68.3	(e) 110.8	(f) 68.2	(g) 109.0	(h) 68.1	(i) 76.1	(j) 91.9	(k) 75.3	(l) 92.1	(m) 74.6	(n) 91.9	(o) 7.6	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.3	126.3	83.4	70.9	120.6	83.4	69.7	115.7	83.3	40.8	92.1	40.0	91.8	39.3	92.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 17.3	(b) 14.4	(c) 12.0	(e) 45.9	(f) 116.8	(g) 3.3	(h) 0.8	(i) 43.5	(j) 117.4	(k) 41.5	(l) 117.8	(m) 39.7	(n) 118.3	(o) 37.2	(p) 118.8		
(a) 17.3	(b) 14.4	(c) 12.0	(e) 38.4	(f) 77.7	(g) 3.1	(h) 0.9	(i) 36.2	(j) 78.3	(k) 34.4	(l) 78.8	(m) 32.6	(n) 79.3	(o) 30.4	(p) 80.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.7	66.9	70.7	77.7	86.1	93.3	96.6	96.6	94.2	90.8	84.6	76.3	69.4
	DBStd	11.22	3.56	4.56	4.20	4.28	3.34	3.55	4.21	4.12	3.34	3.17	3.37	3.49
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	39	22	9	0	0	0	0	0	0	0	0	0	8
	CDD50	12293	525	580	858	1083	1344	1397	1445	1371	1225	1074	789	602
	CDD65	6858	83	169	393	633	879	947	980	906	775	609	339	145
	CDH74	103101	632	1626	4716	9130	14570	16165	16600	14470	11971	8483	3514	1224
	CDH80	67217	73	476	2287	5572	10175	11860	12172	10112	7884	4979	1402	225
(14) Wind	WSAvg	4.8	3.6	4.4	5.0	5.5	5.9	5.9	5.7	5.2	5.0	4.2	3.7	3.5
(15) Precipitation	PrecAvg	6.9	0.4	0.7	1.0	0.7	0.5	0.4	1.0	1.0	0.4	0.2	0.2	0.2
	PrecMax	19.6	3.1	4.3	11.5	3.5	2.5	1.6	4.0	2.0	1.2	2.2	1.7	1.1
	PrecMin	2.8	0.0	0.2	0.0	0.0	0.0	0.0	0.3	0.1	0.0	0.0	0.0	0.0
	PrecStd	3.5	0.8	0.9	2.2	0.9	0.5	0.4	0.9	0.6	0.3	0.5	0.4	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.4	91.6	98.4	104.1	112.3	115.1	115.4	112.6	109.3	102.1	93.8	87.2
		MCWB	58.2	60.3	61.0	64.4	67.4	67.4	68.7	69.0	67.2	64.2	62.7	58.7
	2%	DB	82.2	88.2	95.7	102.1	108.8	112.7	112.6	110.4	106.6	100.3	91.2	84.6
		MCWB	58.7	59.6	60.7	63.7	66.4	67.5	69.1	69.2	67.0	63.8	62.0	58.7
	5%	DB	79.9	85.4	93.0	100.4	106.5	110.8	110.6	108.4	104.6	98.5	89.4	82.6
		MCWB	58.4	59.4	60.4	63.2	66.1	66.8	69.3	69.2	67.0	63.8	62.2	58.9
	10%	DB	77.8	82.9	90.4	98.5	104.5	108.5	108.6	106.2	102.6	96.4	87.4	80.5
		MCWB	58.0	58.9	59.9	62.7	65.8	67.0	69.3	69.7	67.3	63.2	61.8	59.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.9	67.3	69.3	71.7	75.5	77.4	76.4	76.5	75.5	73.0	71.1	66.6
		MCDB	74.0	77.4	77.7	81.6	88.8	90.8	95.5	92.9	91.6	83.7	78.5	73.4
	2%	WB	62.8	65.1	67.6	70.4	74.3	76.4	75.5	75.5	74.2	71.3	69.1	65.3
		MCDB	73.1	76.8	78.0	81.8	88.4	90.1	95.0	93.0	90.3	83.7	79.0	74.0
	5%	WB	61.7	63.7	65.9	69.0	73.2	75.4	74.8	74.6	73.2	69.8	67.3	63.9
		MCDB	72.7	76.2	78.8	83.1	88.6	89.9	94.2	92.8	89.0	84.4	78.9	73.7
	10%	WB	60.5	62.3	64.0	67.4	71.9	74.4	74.2	73.8	72.4	68.5	65.8	62.6
		MCDB	72.4	75.6	80.2	85.4	89.8	90.3	93.4	92.5	88.6	84.6	78.5	73.5
(35) Mean Daily Temperature Range	5% DB	MDBR	22.5	23.4	24.6	22.6	22.7	23.4	22.7	23.3	23.6	23.7	21.7	22.6
		MCDBR	24.7	26.6	27.6	24.3	24.4	25.5	24.5	24.8	24.9	25.0	23.6	25.9
		MCWBR	8.6	9.0	8.4	6.9	7.1	7.3	6.2	5.6	6.6	6.7	7.4	8.9
	5% WB	MCDBR	20.0	20.4	19.1	19.7	22.2	22.9	22.5	22.9	23.4	21.0	19.0	18.7
		MCWBR	7.4	7.6	7.9	7.6	8.2	7.3	5.1	4.9	5.8	6.7	7.2	7.1
(40) Clear-Sky Solar Irradiance	taub		0.394	0.439	0.504	0.569	0.607	0.686	0.769	0.718	0.599	0.469	0.420	0.392
	taud		2.221	2.059	1.872	1.759	1.686	1.568	1.474	1.545	1.726	1.995	2.151	2.219
	Ebn at Noon		273	267	255	241	231	211	195	205	227	254	262	269
	Edh at Noon		41	51	64	73	78	88	96	89	73	54	43	39
(44) All-Sky Solar Radiation	RadAvg		1507	1758	2031	2240	2417	2351	2176	2153	2051	1875	1570	1427
	RadStd		61	73	104	111	46	85	90	52	38	50	39	59

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	+0.41	N/A	N/A	N/A	N/A	+0.70	+0.81	N/A	N/A	+173

Nomenclature: See separate page