

ADAM, Oman

WMO: 412640

Lat: 22.4997N

Lon: 57.3700E

Elev: 1076

StdP: 14.13

Time Zone: 4.00 (E04)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	54.4	57.1	19.2	15.0	82.3	23.1	18.1	84.4	26.9	72.9	23.0	70.0	5.7	330	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	25.4	114.2	70.7	112.2	70.8	110.3	70.9	80.0	95.2	78.9	94.7	78.1	94.1	9.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.9	145.8	85.3	75.4	138.7	85.5	74.2	132.7	85.4	44.6	95.3	43.5	94.7	42.5	93.9	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.1	21.4	18.1	48.8	118.9	2.4	1.7	47.1	120.1	45.7	121.1	44.4	122.0	42.6	123.2		
			40.2	80.8	4.2	1.7	37.1	81.9	34.7	82.9	32.3	83.8	29.3	85.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.9	69.1	72.7	79.6	87.3	94.5	97.6	96.4	94.0	90.9	86.0	78.0	71.5
	DBStd	10.52	3.20	4.44	4.03	4.04	3.24	3.56	4.11	4.29	3.24	3.08	3.03	3.56
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	13	6	4	0	0	0	0	0	0	0	0	0	3
	CDD50	12722	591	635	918	1118	1378	1428	1438	1365	1228	1116	841	666
	CDD65	7260	132	219	453	668	913	978	973	900	778	651	391	204
	CDH74	106737	830	2012	5425	9703	15122	16734	16290	14279	11890	9009	3970	1473
	CDH80	70062	110	677	2832	6073	10711	12419	11891	10026	7884	5399	1709	331
(14) Wind	WSAvg	8.2	6.9	7.9	8.1	8.6	9.4	9.6	9.7	10.1	8.8	6.9	6.2	6.3
(15) Precipitation	PrecAvg	4.6	0.2	0.4	0.9	0.6	0.2	0.3	0.6	0.7	0.2	0.2	0.2	0.1
	PrecMax	14.6	2.1	3.3	10.1	2.6	1.7	1.5	3.0	3.0	0.7	0.9	1.1	0.7
	PrecMin	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.1	0.5	0.7	2.0	0.8	0.4	0.4	0.7	0.7	0.2	0.3	0.3	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.8	93.1	99.3	106.0	114.9	117.3	116.0	113.8	109.6	104.5	95.6	89.2
		MCWB	60.2	63.6	63.1	66.8	71.0	70.7	71.9	71.7	69.9	66.7	65.5	63.0
	2%	DB	82.9	89.8	96.8	103.5	110.7	115.0	113.5	111.5	107.2	102.2	92.8	85.7
		MCWB	61.2	62.5	62.8	66.0	69.7	69.9	71.8	72.0	69.9	66.6	64.5	62.7
	5%	DB	80.7	86.9	94.7	101.7	108.2	112.7	111.4	109.5	105.4	100.2	90.8	83.6
		MCWB	61.3	62.6	63.2	65.9	69.2	69.5	71.9	72.4	69.9	66.3	64.9	63.0
	10%	DB	78.7	84.3	92.3	99.7	106.0	110.3	109.4	107.5	103.4	97.8	88.6	81.5
		MCWB	60.8	62.0	63.0	65.4	68.6	69.6	71.9	72.9	70.2	65.8	64.5	63.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.0	70.8	73.8	76.4	79.9	81.7	80.1	80.8	79.2	75.1	74.5	70.3
		MCDB	76.2	80.4	81.7	84.0	91.8	96.8	100.1	97.8	94.4	88.9	84.0	76.4
	2%	WB	66.0	68.8	72.3	74.0	78.4	80.1	79.1	79.2	77.3	73.4	71.2	68.0
		MCDB	74.5	78.1	81.4	83.6	89.6	92.6	98.7	97.6	93.3	86.4	79.9	76.0
	5%	WB	64.7	67.1	70.4	72.5	77.3	79.0	78.2	78.0	76.1	72.1	69.6	66.7
		MCDB	74.3	78.1	81.6	84.9	89.6	91.9	97.1	96.3	92.1	85.5	78.9	76.2
	10%	WB	63.4	65.5	68.3	70.9	76.0	77.9	77.3	77.0	75.1	70.9	68.2	65.6
		MCDB	73.3	77.8	81.2	86.8	90.3	92.2	95.4	94.6	90.8	85.4	79.5	76.0
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	23.5	25.1	24.1	24.3	25.4	25.5	26.4	25.4	24.7	22.2	21.3
		MCDBR	22.8	26.0	27.7	26.1	26.5	27.7	26.9	27.3	26.6	26.4	24.2	23.3
		MCWBR	8.6	9.4	9.0	8.6	8.3	8.5	6.7	5.4	6.4	7.8	8.4	8.6
	5% WB	MCDBR	19.0	21.3	20.8	22.8	24.8	25.3	26.1	26.2	25.8	23.2	20.9	19.5
		MCWBR	8.0	8.5	7.7	8.2	8.8	7.3	5.8	5.5	5.7	7.7	8.7	7.7
(40) Clear-Sky Solar Irradiance	taub		0.391	0.435	0.495	0.558	0.603	0.688	0.774	0.727	0.603	0.464	0.417	0.389
	taud		2.203	2.046	1.872	1.761	1.676	1.550	1.453	1.518	1.704	1.989	2.139	2.202
	Ebn at Noon		274	269	258	244	232	211	193	203	226	256	263	270
	Edh at Noon		42	52	64	73	79	89	98	92	75	54	44	40
(44) All-Sky Solar Radiation	RadAvg		1533	1782	2054	2262	2426	2343	2152	2152	2066	1896	1597	1453
	RadStd		53	65	99	101	39	86	92	51	35	46	33	51

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.41	N/A	N/A	N/A	N/A	+0.70	+0.81	N/A	N/A	+173

Nomenclature: See separate page