

DROSH, Pakistan

WMO: 415150

Lat: 35.567N

Lon: 71.783E

Elev: 4806

StdP: 12.32

Time Zone: 5.00 (E05)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.1	32.8	-4.9	5.1	51.9	0.3	6.6	52.4	18.9	46.0	18.4	45.9	0.4	N/A	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	100.7	66.6	98.4	66.3	96.3	65.5	71.9	92.1	70.6	90.9	69.3	89.7	10.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	115.6	82.0	64.1	107.2	83.4	62.2	100.1	83.8	39.1	92.4	37.9	91.1	36.6	89.5	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.5	17.2	15.6	DB	29.7	105.1	1.6	2.0	28.5	106.6	27.6	107.7	26.6	108.8	25.5	110.3	(4)
			WB	24.8	74.3	1.6	1.1	23.7	75.1	22.7	75.8	21.8	76.4	20.7	77.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	41.1	42.9	52.2	63.0	72.8	81.6	85.8	82.9	76.9	66.6	53.8	45.4
	DBStd	16.64	4.39	5.44	6.74	6.76	6.75	5.93	4.41	4.49	4.59	6.45	5.79	4.06
	HDD50	719	275	211	55	1	0	0	0	0	0	0	25	152
	HDD65	2895	740	620	400	117	14	0	0	0	1	58	338	607
	CDD50	5782	0	11	122	390	707	949	1109	1021	808	516	138	11
	CDD65	2482	0	0	2	56	255	500	644	556	359	109	1	0
	CDH74	29931	0	0	18	477	2540	6352	8975	6986	3658	914	11	0
	CDH80	15401	0	0	0	122	1053	3440	5209	3726	1580	271	0	0
Wind	WSAvg	2.9	2.6	2.4	2.7	2.7	3.0	3.9	4.1	3.8	3.2	2.2	1.7	2.9
Precipitation	PrecAvg	25.5	2.2	3.7	4.9	4.1	2.2	0.9	1.2	1.1	1.0	1.5	1.4	1.3
	PrecMax	36.7	7.4	8.1	10.2	6.6	5.1	2.2	5.1	2.4	4.5	9.9	4.6	5.3
	PrecMin	14.4	0.0	0.4	0.8	0.5	0.3	0.1	0.3	0.1	0.2	0.0	0.0	0.0
	PrecStd	4.4	1.8	2.1	2.4	1.5	1.3	0.6	0.9	0.6	0.8	2.0	1.1	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.7	67.0	76.7	88.4	97.0	102.8	104.8	101.2	95.3	90.8	75.9	61.9
		MCWB	38.3	44.6	51.2	55.5	59.7	63.5	65.6	68.8	62.8	58.3	48.5	41.9
	2%	DB	53.9	60.3	71.6	83.3	93.3	99.6	101.4	98.6	92.8	86.5	71.6	58.5
		MCWB	37.2	43.1	49.1	53.5	58.3	63.0	67.3	69.0	63.5	56.7	46.4	40.1
	5%	DB	51.7	56.4	67.6	79.4	90.1	96.9	99.1	96.5	90.8	82.5	67.8	55.8
		MCWB	36.5	41.0	47.4	53.3	57.9	62.6	67.2	67.7	62.9	55.5	45.5	39.0
	10%	DB	49.3	52.8	64.3	75.6	86.4	94.3	97.0	94.3	88.5	79.0	64.3	53.2
		MCWB	35.7	39.4	46.1	52.9	57.0	61.8	66.7	67.0	62.0	54.2	44.6	37.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.0	48.8	55.0	59.2	63.9	76.2	73.6	73.3	68.9	62.9	52.5	45.1
		MCDB	49.9	57.7	69.0	76.4	85.0	91.4	96.0	92.7	88.2	83.7	61.5	54.6
	2%	WB	40.3	46.2	52.1	57.5	62.1	68.9	71.9	71.8	66.9	60.1	50.2	43.0
		MCDB	47.7	54.5	65.3	74.3	82.9	89.7	94.0	90.8	86.9	78.6	61.4	52.4
	5%	WB	39.0	43.7	49.8	56.2	60.8	66.6	70.7	70.7	65.5	57.8	48.4	41.3
		MCDB	45.9	52.4	62.5	72.3	81.3	88.4	92.5	89.7	85.7	77.2	61.9	50.6
	10%	WB	37.8	41.4	48.1	54.8	59.7	64.5	69.5	69.5	64.2	55.7	46.6	39.8
		MCDB	45.2	50.2	60.5	70.1	79.6	88.2	91.1	88.6	84.0	75.6	60.7	49.7
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.9	16.4	18.7	21.8	22.6	21.7	21.4	22.4	21.1	16.7	13.9
		MCDBR	15.4	18.7	20.7	24.3	25.8	24.5	24.3	23.0	24.2	24.4	20.8	16.9
		MCWBR	7.1	8.4	7.8	7.9	8.5	7.8	8.2	8.3	8.0	8.0	8.9	7.4
	5% WB	MCDBR	12.3	15.4	18.2	20.9	23.2	20.9	21.6	20.6	22.0	22.1	17.9	13.5
MCWBR		7.3	8.4	8.6	8.6	9.5	9.1	8.7	8.4	8.4	7.9	8.7	7.6	
Clear-Sky Solar Irradiance	taub	0.367	0.417	0.471	0.487	0.492	0.527	0.578	0.553	0.474	0.438	0.414	0.368	
	taud	1.991	1.842	1.803	1.868	1.921	1.865	1.779	1.845	1.990	1.995	1.974	2.038	
	Ebn at Noon	252	252	251	255	255	246	232	235	247	243	233	242	
	Edh at Noon	43	56	64	63	61	64	69	64	53	48	44	39	
All-Sky Solar Radiation	RadAvg	804	1023	1432	1803	2077	2289	2175	1984	1731	1365	926	753	
	RadStd	69	133	132	169	179	130	92	136	113	124	106	90	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page