

DROSH, Pakistan

WMO: 415150

Lat: 35.567N

Lon: 71.783E

Elev: 1465

StdP: 84.92

Time Zone: 5.00 (E05)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.5	0.4	-20.5	0.7	11.1	-17.6	0.9	11.3	8.4	7.8	8.2	7.7	0.2	N/A	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	38.2	19.2	36.9	19.1	35.7	18.6	22.2	33.4	21.4	32.7	20.7	32.1	4.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.5	27.8	17.8	15.3	28.5	16.8	14.3	28.8	73.1	33.6	70.2	32.8	67.3	31.9	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.7	7.0	DB	-1.3	40.6	0.9	1.1	-1.9	41.4	-2.5	42.1	-3.0	42.7	-3.6	43.5	(4)
(5)			WB	-4.0	23.5	0.9	0.6	-4.6	24.0	-5.1	24.3	-5.6	24.7	-6.3	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	5.1	6.0	11.2	17.2	22.7	27.6	29.9	28.3	25.0	19.2	12.1	7.5	(6)	
	DBStd	9.24	2.44	3.02	3.74	3.75	3.75	3.30	2.45	2.49	2.55	3.58	3.22	2.25	(7)	
	HDD10.0	399	153	117	31	1	0	0	0	0	0	0	14	84	(8)	
	HDD18.3	1608	411	344	222	65	8	0	0	0	1	32	188	337	(9)	
	CDD10.0	3212	0	6	68	217	393	527	616	567	449	287	77	6	(10)	
	CDD18.3	1379	0	0	1	31	142	278	358	309	199	61	1	0	(11)	
	CDH23.3	16628	0	0	10	265	1411	3529	4986	3881	2032	508	6	0	(12)	
	CDH26.7	8556	0	0	0	68	585	1911	2894	2070	878	151	0	0	(13)	
(14) Wind	WSAvg	1.3	1.2	1.1	1.2	1.2	1.3	1.7	1.8	1.7	1.4	1.0	0.8	1.3	(14)	
(15) Precipitation	PrecAvg	648	56	95	125	103	57	23	30	28	26	37	35	34	(15)	
	PrecMax	931	188	206	260	168	129	55	130	62	114	252	116	134	(16)	
	PrecMin	367	0	11	21	13	8	2	7	3	4	1	0	0	(17)	
	PrecStd	111	45	54	61	39	34	16	24	15	21	50	29	38	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	19.5	24.8	31.3	36.1	39.3	40.4	38.5	35.2	32.7	24.4	16.6	(19)	
		MCWB	3.5	7.0	10.7	13.0	15.4	17.5	18.7	20.5	17.1	14.6	9.1	5.5	(20)	
	2%	DB	12.2	15.7	22.0	28.5	34.1	37.6	38.6	37.0	33.8	30.3	22.0	14.7	(21)	
		MCWB	2.9	6.2	9.5	12.0	14.6	17.2	19.6	20.5	17.5	13.7	8.0	4.5	(22)	
	5%	DB	10.9	13.5	19.8	26.3	32.3	36.0	37.3	35.8	32.6	28.1	19.9	13.2	(23)	
		MCWB	2.5	5.0	8.6	11.9	14.4	17.0	19.5	19.8	17.2	13.0	7.5	3.9	(24)	
	10%	DB	9.6	11.6	17.9	24.2	30.2	34.6	36.1	34.6	31.4	26.1	17.9	11.8	(25)	
		MCWB	2.0	4.1	7.8	11.6	13.9	16.6	19.3	19.4	16.7	12.3	7.0	3.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	9.4	12.8	15.1	17.7	24.5	23.1	23.0	20.5	17.2	11.4	7.3	(27)	
		MCDB	9.9	14.3	20.5	24.6	29.5	33.0	35.6	33.7	31.2	28.7	16.4	12.5	(28)	
	2%	WB	4.6	7.9	11.2	14.2	16.7	20.5	22.2	22.1	19.4	15.6	10.1	6.1	(29)	
		MCDB	8.7	12.5	18.5	23.5	28.3	32.1	34.5	32.7	30.5	25.9	16.3	11.3	(30)	
	5%	WB	3.9	6.5	9.9	13.4	16.0	19.2	21.5	21.5	18.6	14.3	9.1	5.2	(31)	
		MCDB	7.7	11.3	16.9	22.4	27.4	31.4	33.6	32.1	29.9	25.1	16.6	10.4	(32)	
	10%	WB	3.2	5.2	8.9	12.7	15.4	18.1	20.8	20.8	17.9	13.2	8.1	4.4	(33)	
		MCDB	7.3	10.1	15.8	21.2	26.4	31.2	32.8	31.5	28.9	24.2	16.0	9.8	(34)	
(35) Mean Daily Temperature Range	MDBR		7.0	7.2	9.1	10.4	12.1	12.6	12.1	11.9	12.5	11.7	9.3	7.7	(35)	
	5% DB	MCDBR	8.6	10.4	11.5	13.5	14.3	13.6	13.5	12.8	13.5	13.6	11.6	9.4	(36)	
		MCWBR	3.9	4.7	4.3	4.4	4.7	4.3	4.5	4.6	4.4	4.4	4.9	4.1	(37)	
	5% WB	MCDBR	6.8	8.5	10.1	11.6	12.9	11.6	12.0	11.4	12.2	12.3	9.9	7.5	(38)	
		MCWBR	4.0	4.7	4.8	4.8	5.3	5.1	4.8	4.7	4.7	4.4	4.8	4.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.367	0.417	0.471	0.487	0.492	0.527	0.578	0.553	0.474	0.438	0.414	0.368	(40)	
	taud		1.991	1.842	1.803	1.868	1.921	1.865	1.779	1.845	1.990	1.995	1.974	2.038	(41)	
	Ebn at Noon		793	794	790	803	805	775	731	740	780	767	733	764	(42)	
	Edh at Noon		136	178	202	199	192	203	219	202	166	150	138	122	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.53	3.22	4.51	5.68	6.55	7.21	6.86	6.25	5.46	4.30	2.92	2.38	(44)	
	RadStd		0.22	0.42	0.41	0.53	0.56	0.41	0.29	0.43	0.36	0.39	0.34	0.28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page