

SAIDU SHARIF, Pakistan

WMO: 415230

Lat: 34.733N

Lon: 72.350E

Elev: 3120

StdP: 13.11

Time Zone: 5.00 (E05)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.5	35.2	23.7	20.1	49.8	26.0	22.4	47.3	6.3	51.7	4.8	49.8	0.1	N/A	0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	98.7	72.3	96.4	73.1	94.2	73.2	79.5	91.5	78.4	90.2	77.4	88.6	0.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.3	154.6	87.4	75.3	149.1	86.2	74.4	144.5	85.1	45.9	92.2	44.7	89.9	43.6	88.8	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.3	4.9	2.9	31.9	104.4	0.9	3.7	31.2	107.1	30.7	109.2	30.2	111.3	29.5	114.0
			29.4	81.4	2.0	1.3	28.0	82.3	26.8	83.1	25.7	83.8	24.3	84.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.7	46.7	50.4	59.0	67.4	76.6	82.7	83.2	81.0	76.9	68.8	57.2	49.7	(6)
(7)		DBStd	13.82	3.68	5.16	6.46	5.62	5.08	4.41	3.47	3.33	3.55	5.30	3.53	3.76	(7)
(8)		HDD50	229	114	52	8	0	0	0	0	0	0	1	54	(8)	
(9)		HDD65	1953	568	409	204	38	1	0	0	0	24	235	474	(9)	
(10)		CDD50	6327	11	62	285	522	825	982	1028	961	808	582	216	45	(10)
(11)		CDD65	2579	0	0	17	110	361	532	563	496	358	141	1	0	(11)
(12)		CDH74	28448	0	5	198	1046	3879	6496	6755	5384	3325	1336	24	0	(12)
(13)		CDH80	13317	0	0	24	311	1912	3588	3351	2394	1321	415	1	0	(13)
(14)	Wind	WSAvg	0.3	0.1	0.2	0.2	0.5	0.8	0.7	0.5	0.3	0.3	0.1	0.1	(14)	
(15)	Precipitation	PrecAvg	39.0	2.9	5.2	5.0	4.6	2.1	2.5	5.8	4.5	2.7	1.5	1.1	1.4	(15)
(16)		PrecMax	59.1	10.3	11.8	12.4	13.7	7.1	6.7	16.4	11.8	6.4	6.7	3.6	6.2	(16)
(17)		PrecMin	25.2	0.0	0.4	0.0	0.0	0.2	0.0	1.4	1.3	0.5	0.0	0.0	0.0	(17)
(18)		PrecStd	8.5	2.6	3.2	3.1	3.0	1.6	1.8	3.6	2.4	1.6	1.6	0.9	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.9	73.7	82.6	90.8	99.8	102.3	100.5	95.7	92.3	91.3	76.9	68.7	(19)
(20)		0.4%	MCWB	48.4	55.5	60.9	68.2	69.3	70.9	75.1	78.1	73.9	71.2	58.4	50.9	(20)
(21)		2%	DB	61.7	68.2	79.0	86.4	96.1	99.7	97.3	93.5	90.5	87.4	73.4	65.4	(21)
(22)		2%	MCWB	47.7	51.7	59.3	64.8	68.8	72.0	76.5	77.0	72.9	67.8	56.4	49.9	(22)
(23)		5%	DB	59.3	64.7	75.6	83.4	93.3	97.3	94.8	91.7	89.1	84.5	70.7	62.9	(23)
(24)		5%	MCWB	46.3	50.4	57.6	63.6	68.4	71.9	76.7	76.7	72.4	65.5	55.1	48.4	(24)
(25)		10%	DB	56.7	61.6	72.1	80.2	90.2	95.0	92.7	90.0	87.3	81.6	68.1	60.3	(25)
(26)		10%	MCWB	45.3	49.1	56.4	62.4	67.4	71.6	76.2	76.3	71.8	64.0	53.8	47.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.4	56.8	63.0	69.1	72.7	79.7	80.7	80.7	77.4	73.2	60.3	53.0	(27)
(28)		0.4%	MCDWB	60.1	71.1	77.6	87.1	91.0	94.2	93.2	92.0	89.1	86.5	72.9	63.7	(28)
(29)		2%	WB	49.2	53.7	60.5	66.7	70.9	77.6	79.6	79.4	75.6	70.8	58.3	51.1	(29)
(30)		2%	MCDWB	57.6	65.3	75.9	84.1	91.0	92.9	91.9	90.6	87.5	83.0	70.3	62.0	(30)
(31)		5%	WB	47.8	51.7	58.8	64.8	69.6	75.8	78.6	78.3	74.5	68.1	56.6	49.7	(31)
(32)		5%	MCDWB	55.7	62.2	73.7	80.9	89.9	91.4	90.8	88.9	85.9	79.7	67.7	60.8	(32)
(33)		10%	WB	46.3	49.8	57.2	63.4	68.2	74.0	77.7	77.3	73.4	65.7	55.0	48.3	(33)
(34)		10%	MCDWB	54.3	59.3	70.4	78.1	87.2	89.7	89.4	87.2	84.0	78.3	65.6	58.4	(34)
(35)	Mean Daily Temperature Range	MDBR	18.7	18.4	19.5	21.3	24.0	23.2	17.8	17.4	20.4	24.3	22.1	21.9	(35)	
(36)		5% DB	MCDBR	23.8	24.7	25.6	26.7	28.3	25.7	21.2	19.7	22.7	27.8	26.5	25.3	(36)
(37)		5% DB	MCWBR	12.1	11.5	10.7	11.0	9.9	9.2	8.2	8.1	9.5	11.0	12.3	12.2	(37)
(38)		5% WB	MCDWB	20.1	21.8	24.0	24.9	26.7	21.8	17.3	16.8	19.2	24.6	23.1	22.9	(38)
(39)		5% WB	MCWBR	11.6	11.7	10.9	11.1	10.5	10.2	7.3	7.5	8.8	10.9	11.8	12.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.380	0.432	0.449	0.458	0.469	0.536	0.621	0.601	0.507	0.448	0.416	0.377	(40)	
(41)		taud	2.111	1.994	2.012	2.057	2.056	1.909	1.767	1.814	1.984	2.036	2.055	2.131	(41)	
(42)		Ebn at Noon	252	251	259	264	262	244	222	224	239	242	236	244	(42)	
(43)		Edh at Noon	39	49	52	53	53	62	71	66	53	46	41	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	897	1052	1475	1894	2245	2355	2111	1924	1790	1485	1064	868	(44)	
(45)		RadStd	109	163	156	136	140	99	128	135	93	90	77	82	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+1.12	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page