

PESHAWAR, Pakistan

WMO: 415300

Lat: 34.017N

Lon: 71.583E

Elev: 360

StdP: 97.07

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.2	4.5	-3.0	3.1	12.7	-1.2	3.6	10.4	8.3	15.8	6.2	13.4	0.6	230	0.396

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.7	41.8	23.6	40.0	24.3	38.8	24.9	29.5	36.1	28.7	35.3	28.1	34.4	3.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.0	25.2	34.4	27.1	23.9	33.3	26.5	23.0	32.7	101.3	36.4	97.1	35.2	93.7	34.4	32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.2	7.4	5.9	DB	1.0	44.5	1.1	1.8	0.2	45.8	-0.5	46.8	-1.1	47.8	-1.9	49.1	
			WB	-0.3	31.1	0.9	0.7	-1.0	31.7	-1.5	32.1	-2.1	32.5	-2.8	33.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	11.5	14.1	19.3	24.4	29.7	32.5	32.0	30.8	29.2	24.4	17.8	12.9
	DBStd	7.91	2.10	2.72	3.41	3.35	2.97	2.27	2.31	1.94	1.87	2.78	2.19	2.04
	HDD10.0	12	8	2	0	0	0	0	0	0	0	0	0	2
	HDD18.3	568	212	120	31	2	0	0	0	0	0	0	37	167
	CDD10.0	4853	55	117	287	433	611	676	682	645	576	445	233	93
	CDD18.3	2367	0	2	59	184	353	426	423	387	326	187	20	0
	CDH23.3	32182	3	41	578	1999	4996	6744	6413	5421	4041	1744	189	12
Wind	WSAvg	18559	0	4	175	967	3057	4456	4002	3073	2082	724	19	0
	WSAvg	2.0	1.1	1.7	1.9	2.3	2.7	2.9	3.2	2.7	2.1	1.3	0.9	0.9
	PrecAvg	440	34	54	68	55	27	13	40	68	25	12	13	23
	PrecMax	771	150	236	223	189	120	78	162	280	111	94	64	145
	PrecMin	191	0	0	0	8	0	0	0	0	0	0	0	0
	PrecStd	132	35	45	51	44	25	16	37	66	24	18	14	33
	PrecStd	132	35	45	51	44	25	16	37	66	24	18	14	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	23.2	26.8	32.5	38.1	42.8	45.1	41.7	38.9	37.2	35.2	28.8	25.0	
	0.4% MCWB	13.5	14.6	20.3	22.1	22.4	21.8	27.1	28.4	26.2	23.6	17.8	14.3	
	2% DB	21.1	24.4	30.2	36.0	40.9	42.3	40.0	37.5	36.1	33.8	26.9	22.8	
	2% MCWB	12.4	14.2	18.7	21.2	22.2	23.5	27.3	28.1	26.0	23.2	17.1	13.1	
	5% DB	19.4	22.2	28.8	34.0	39.0	40.9	38.8	36.4	35.1	32.2	25.4	21.1	
	5% MCWB	11.4	13.3	18.2	20.6	22.3	24.0	27.4	27.6	25.5	21.8	16.5	12.5	
	10% DB	17.8	20.4	26.8	32.0	37.2	39.1	37.1	35.2	34.2	30.8	24.1	19.7	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10% MCWB	10.8	12.8	17.3	20.0	22.2	24.2	27.2	27.3	25.1	21.0	16.2	12.0	
	0.4% WB	14.6	17.0	21.8	24.0	25.9	29.3	30.6	30.4	28.6	26.1	20.0	15.6	
	0.4% MCDB	20.6	23.9	28.8	33.4	37.7	37.7	37.7	36.1	34.8	32.8	24.9	22.2	
	2% WB	13.4	15.6	20.1	22.6	24.7	28.1	29.6	29.6	27.7	24.9	18.9	14.3	
	2% MCDB	19.5	21.3	27.8	32.7	35.9	37.2	36.7	35.4	33.9	31.1	24.3	20.6	
	5% WB	12.3	14.6	19.0	21.7	23.9	27.0	28.8	28.8	27.0	23.6	17.9	13.3	
	5% MCDB	17.8	20.2	26.6	31.6	35.0	35.5	35.9	34.5	33.1	29.7	23.6	19.5	
Mean Daily Temperature Range	10% WB	11.3	13.7	17.9	20.8	23.1	26.1	28.2	28.1	26.3	22.4	16.9	12.3	
	10% MCDB	16.4	19.3	25.4	30.3	34.5	34.9	34.9	33.6	32.2	28.9	22.3	18.3	
	MDBR	12.6	11.2	11.9	12.6	13.5	12.7	9.4	8.9	10.3	12.3	13.0	14.0	
	5% DB MCDBR	15.5	14.9	14.6	15.3	15.8	15.5	11.5	9.9	11.0	12.7	14.8	16.4	
	5% DB MCWBR	8.9	7.7	6.9	6.3	5.8	5.9	5.7	5.1	5.2	5.5	7.6	8.9	
	5% WB MCDBR	13.7	12.4	13.4	13.8	14.4	11.6	9.5	8.8	9.5	11.3	12.4	14.4	
	5% WB MCWBR	8.5	7.0	7.0	6.3	6.1	6.4	5.7	5.3	5.3	5.4	6.9	8.5	
Clear-Sky Solar Irradiance	taub	0.452	0.512	0.539	0.560	0.586	0.675	0.776	0.747	0.643	0.593	0.532	0.458	
	taud	1.934	1.837	1.813	1.812	1.777	1.627	1.506	1.555	1.693	1.708	1.789	1.921	
	Ebn at Noon	713	714	737	747	733	668	599	605	646	630	623	674	
	Edh at Noon	150	183	203	212	222	258	290	271	227	206	172	144	
All-Sky Solar Radiation	RadAvg	3.02	3.51	4.80	6.15	7.21	7.45	6.52	5.96	5.62	4.73	3.50	2.94	
	RadStd	0.33	0.52	0.47	0.37	0.33	0.23	0.34	0.41	0.26	0.23	0.18	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	+0.62	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page