

NOK KUNDI, Pakistan

WMO: 417100

Lat: 28.817N

Lon: 62.750E

Elev: 683

StdP: 93.38

Time Zone: 5.00 (E05)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	2.8	-16.0	1.0	7.6	-14.6	1.1	7.6	12.9	12.7	10.2	14.7	1.9	310	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	45.1	19.6	44.1	19.2	43.1	19.0	22.3	37.7	20.8	40.1	19.8	41.0	3.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.7	12.9	33.6	13.7	10.6	29.8	11.3	9.0	29.1	69.2	37.4	63.4	40.0	59.7	41.3	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	11.8	9.9	-2.6	46.9	2.6	1.0	-4.5	47.7	-6.0	48.3	-7.4	48.8	-9.3	49.6		
(5)			-6.0	21.9	2.1	1.9	-7.5	23.3	-8.7	24.4	-9.9	25.4	-11.4	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	12.7	15.9	22.1	27.9	33.3	35.8	37.1	34.9	31.3	26.7	19.3	13.5	(6)
(7)		DBStd	9.22	4.01	5.28	4.00	3.94	2.82	2.45	1.83	1.92	2.52	3.24	3.96	3.74	(7)
(8)		HDD10.0	46	20	13	0	0	0	0	0	0	0	0	1	12	(8)
(9)		HDD18.3	479	176	97	13	2	0	0	0	0	0	0	37	154	(9)
(10)		CDD10.0	5859	105	178	376	538	721	774	839	773	640	518	278	120	(10)
(11)		CDD18.3	3251	3	28	131	289	462	524	581	514	390	260	64	4	(11)
(12)		CDH23.3	50881	31	247	1393	3926	7578	9193	10269	8605	5803	3154	632	50	(12)
(13)	CDH26.7	34433	1	58	571	2253	5214	6807	7790	6136	3702	1699	197	5	(13)	
(14)	Wind	WSAvg	2.9	1.8	2.5	2.1	2.5	2.7	4.5	5.1	5.0	3.3	2.0	1.5	1.6	(14)
(15)	Precipitation	PrecAvg	36	12	6	6	3	0	0	2	1	0	0	0	2	(15)
(16)		PrecMax	116	91	36	32	24	5	0	32	26	0	8	2	14	(16)
(17)		PrecMin	3	0	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	28	24	10	9	6	1	0	7	5	0	2	0	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	30.6	36.0	40.7	44.6	46.7	46.2	45.0	41.9	39.4	32.9	26.7	(19)
(20)			MCWB	11.7	14.4	16.9	18.8	19.5	20.1	20.0	19.7	18.4	17.7	14.4	11.5	(20)
(21)		2%	DB	23.9	28.4	33.6	39.0	43.4	45.1	45.2	43.4	40.7	37.8	30.6	24.6	(21)
(22)			MCWB	10.6	13.1	15.8	18.2	19.4	19.6	19.5	19.1	18.1	17.3	13.6	10.6	(22)
(23)		5%	DB	22.1	26.3	31.8	37.3	41.7	44.0	44.2	42.0	39.6	36.1	29.1	22.8	(23)
(24)			MCWB	9.6	12.6	14.8	17.7	18.7	19.2	19.2	18.5	17.7	16.5	13.1	9.7	(24)
(25)		10%	DB	20.3	24.2	30.0	35.7	40.2	42.7	43.2	40.8	38.5	34.2	27.2	20.9	(25)
(26)			MCWB	8.8	11.5	13.9	17.1	18.3	18.8	18.9	18.1	17.3	15.4	12.4	8.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	17.6	18.8	22.9	20.7	24.9	23.6	23.0	21.0	21.2	16.6	12.6	(27)
(28)			MCDWB	22.7	25.0	31.3	35.5	42.0	29.3	37.6	36.8	38.3	36.0	27.2	25.1	(28)
(29)		2%	WB	11.9	14.8	17.2	20.4	19.9	21.9	21.8	20.7	19.0	17.8	14.9	11.1	(29)
(30)			MCDWB	20.6	24.4	29.6	34.8	41.8	38.3	41.0	39.4	38.8	35.5	27.3	23.1	(30)
(31)		5%	WB	10.6	13.6	15.9	18.9	19.1	20.1	20.3	19.3	18.0	16.7	13.9	10.1	(31)
(32)			MCDWB	19.5	23.9	29.0	35.0	40.8	42.8	42.2	40.5	38.9	35.3	27.5	21.1	(32)
(33)		10%	WB	9.5	12.3	14.8	17.7	18.4	19.2	19.4	18.5	17.3	15.7	12.8	9.1	(33)
(34)			MCDWB	18.8	22.7	28.1	34.1	39.5	42.0	41.9	40.2	37.9	33.4	26.4	20.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.9	12.7	12.8	12.4	12.3	12.3	12.0	12.0	13.4	13.7	13.5	13.8	(35)
(36)			MCDBR	14.8	14.1	14.5	14.0	13.6	13.9	13.0	12.7	14.6	14.6	14.9	15.0	(36)
(37)			MCWBR	7.8	6.8	6.4	5.7	4.8	4.9	4.4	4.6	6.0	6.4	7.2	7.6	(37)
(38)		5% WB	MCDWB	13.2	12.5	13.2	12.9	13.1	13.1	12.7	12.2	14.5	14.2	14.0	14.8	(38)
(39)			MCWBR	7.8	6.5	6.7	6.4	4.8	5.0	4.9	5.0	6.1	6.5	7.0	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.356	0.412	0.460	0.520	0.540	0.529	0.558	0.503	0.434	0.415	0.368	0.340	(40)
(41)		taud		2.262	2.085	1.934	1.829	1.790	1.810	1.763	1.869	2.009	2.061	2.224	2.309	(41)
(42)		Ebn at Noon		871	846	827	790	774	778	754	794	839	829	848	871	(42)
(43)		Edh at Noon		115	149	185	212	221	216	226	201	169	150	118	105	(43)
(44)	All-Sky Solar Radiation	RadAvg		3.92	4.60	5.75	6.79	7.48	7.84	7.40	7.22	6.62	5.50	4.38	3.76	(44)
(45)		RadStd		0.23	0.30	0.29	0.27	0.18	0.30	0.29	0.23	0.14	0.12	0.14	0.19	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page