

KHUZDAR, Pakistan

WMO: 417440

Lat: 27.833N

Lon: 66.633E

Elev: 1232

StdP: 87.37

Time Zone: 5.00 (E05)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.4	3.8	-15.3	1.1	16.3	-12.4	1.5	16.6	5.9	15.0	4.4	14.9	0.3	N/A	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.5	39.7	19.3	38.6	18.9	37.6	18.6	24.7	34.2	23.5	32.9	22.7	31.8	1.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	19.6	30.4	21.0	18.2	28.8	20.0	17.1	28.7	82.9	33.3	77.5	33.1	74.1	31.5	34.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.3	4.2	3.4	DB	0.3	41.8	1.8	1.6	-1.1	43.0	-2.1	43.9	-3.1	44.8	-4.5	46.0	(4)
			WB	-3.3	26.9	3.2	5.1	-5.6	30.5	-7.5	33.5	-9.3	36.3	-11.6	40.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	11.5	13.2	18.7	24.5	29.5	31.9	31.4	29.7	28.1	23.7	17.5	13.2
	DBStd	7.80	2.68	3.67	3.81	3.42	2.90	2.09	1.99	2.06	1.81	2.67	2.72	2.94
	HDD10.0	33	16	11	1	0	0	0	0	0	0	0	0	6
	HDD18.3	611	212	146	44	2	0	0	0	0	0	0	46	161
	CDD10.0	4705	62	101	269	436	606	656	663	612	543	426	226	106
	CDD18.3	2242	0	3	54	189	347	406	404	353	293	167	22	3
	CDH23.3	29909	3	62	521	2076	4977	6181	5713	4679	3618	1794	250	35
	CDH26.7	16371	0	5	130	924	2915	3914	3399	2547	1817	687	27	4
Wind	WSAvg	0.8	0.6	0.9	0.8	1.0	1.1	0.9	0.9	0.7	0.5	0.6	0.5	0.5
Precipitation	PrecAvg	265	19	40	27	19	13	16	52	42	11	7	3	16
	PrecMax	586	147	138	85	71	67	135	356	142	53	88	36	108
	PrecMin	63	0	7	0	0	1	0	0	0	1	0	0	0
	PrecStd	127	28	35	26	21	17	28	71	34	15	17	8	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	27.4	31.9	37.1	40.1	41.6	40.1	39.1	37.0	34.7	29.2	26.7
		MCWB	10.8	12.4	15.1	19.5	21.2	19.5	20.5	18.2	17.5	17.1	13.1	13.8
	2%	DB	21.4	25.3	29.8	34.9	38.6	40.1	39.0	37.5	35.7	33.1	27.4	23.8
		MCWB	9.9	12.1	13.9	18.2	19.1	18.6	19.5	18.0	17.7	17.3	13.0	12.2
	5%	DB	20.0	23.4	28.0	33.0	37.3	39.0	38.0	36.3	34.7	31.9	26.0	21.8
		MCWB	9.0	11.3	13.3	16.9	17.9	18.5	19.3	18.0	17.6	16.4	12.6	10.6
	10%	DB	18.4	21.2	26.3	31.5	36.1	37.8	36.9	35.3	33.6	30.4	24.8	20.2
		MCWB	8.5	10.3	12.4	15.7	17.7	18.6	19.3	18.1	17.2	15.5	12.0	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.1	14.2	17.2	21.9	25.6	25.4	29.4	24.4	22.2	21.6	15.8	16.5
		MCDB	20.8	22.0	26.8	35.7	38.3	37.4	33.8	32.8	31.3	31.5	25.3	25.2
	2%	WB	11.2	13.1	15.7	20.3	22.2	24.2	25.1	23.2	21.4	19.9	14.5	13.6
		MCDB	18.8	22.7	25.9	32.6	35.3	35.5	32.7	31.3	30.5	29.0	24.8	21.7
	5%	WB	10.0	12.3	14.6	18.8	20.6	23.1	23.7	22.4	20.5	18.4	13.6	11.5
		MCDB	17.6	21.8	24.6	29.9	33.8	33.4	32.3	30.2	29.8	28.4	24.1	19.9
	10%	WB	9.1	11.2	13.5	17.2	19.2	22.2	22.8	21.7	19.7	17.1	12.7	10.1
		MCDB	17.3	19.9	24.1	28.5	32.8	32.2	31.3	29.4	29.3	28.3	23.0	19.0
Mean Daily Temperature Range	5% DB	MDBR	12.6	13.0	11.7	11.3	11.6	11.5	10.9	10.3	11.1	12.7	12.9	13.2
		MCDBR	14.8	15.8	13.6	13.4	12.3	12.9	12.0	11.8	12.3	13.3	14.4	15.1
		MCWBR	7.5	7.1	5.4	5.5	4.3	4.2	3.9	4.0	4.2	5.0	5.8	7.7
	5% WB	MCDBR	13.9	14.1	13.0	13.9	13.9	12.6	11.2	10.6	11.6	13.7	13.9	14.3
		MCWBR	8.1	7.2	5.7	6.7	6.4	5.6	5.2	4.1	4.7	6.9	6.7	8.5
Clear-Sky Solar Irradiance	taub	0.333	0.370	0.416	0.476	0.497	0.562	0.682	0.603	0.472	0.398	0.377	0.333	
	taud	2.310	2.209	2.053	1.917	1.873	1.757	1.582	1.720	1.962	2.098	2.142	2.297	
	Ebn at Noon	905	895	873	828	809	753	666	718	808	851	841	885	
	Edh at Noon	110	133	165	195	204	228	271	235	178	146	130	107	
All-Sky Solar Radiation	RadAvg	4.07	4.84	6.05	6.83	7.43	7.47	6.78	6.57	6.39	5.74	4.59	3.94	
	RadStd	0.23	0.36	0.33	0.36	0.24	0.34	0.39	0.35	0.27	0.17	0.19	0.20	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page