

JIWANI, Pakistan

WMO: 417560

Lat: 25.068N

Lon: 61.805E

Elev: 58

StdP: 100.63

Time Zone: 5.00 (E05)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 12.1	(c) 14.0	(d) -9.8	(e) 1.6	(f) 21.0	(g) -4.5	(h) 2.6	(i) 20.4	(j) 8.8	(k) 19.3	(l) 7.6	(m) 22.0	(n) 1.6	(o) 0	(p) 0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 5.9	(c) 36.8	(d) 24.5	(e) 35.5	(f) 24.8	(g) 34.4	(h) 25.3	(i) 28.9	(j) 32.5	(k) 28.4	(l) 32.0	(m) 28.1	(n) 31.6	(o) 3.3	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.1	24.4	30.8	27.6	23.7	30.6	27.2	23.1	30.4	95.0	32.7	92.8	31.9	90.9	31.0	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.4	(b) 6.2	(c) 5.3	(e) 9.3	(f) 42.2	(g) 2.7	(h) 3.2	(i) 7.3	(j) 44.5	(k) 5.7	(l) 46.3	(m) 4.2	(n) 48.1	(o) 2.2	(p) 50.4		
(a) 7.4	(b) 6.2	(c) 5.3	(e) 3.6	(f) 29.5	(g) 2.4	(h) 0.7	(i) 1.8	(j) 30.0	(k) 0.4	(l) 30.4	(m) -0.9	(n) 30.8	(o) -2.7	(p) 31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	20.0	21.2	24.5	28.3	30.7	31.1	29.9	28.9	28.8	28.5	25.1	21.5
	DBStd	4.14	1.98	2.38	2.12	1.81	1.65	1.42	1.21	0.91	1.08	1.32	1.89	2.31
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	20	9	6	0	0	0	0	0	0	0	0	0	5
	CDD10.0	6046	310	313	449	548	642	634	618	587	563	572	454	356
	CDD18.3	3025	61	86	191	298	383	384	359	328	313	314	204	103
	CDH23.3	34302	209	366	1386	3329	5278	5485	4782	3988	3714	3514	1697	554
	CDH26.7	15027	6	37	357	1419	2844	3094	2310	1554	1434	1422	491	57
Wind	WSAvg	2.2	2.0	2.1	2.3	2.6	2.6	2.6	2.7	2.5	1.9	1.7	1.8	1.9
Precipitation	PrecAvg	82	21	10	14	6	0	2	6	1	0	0	4	18
	PrecMax	246	199	89	120	73	0	92	99	13	7	4	47	120
	PrecMin	0	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	56	34	18	27	15	0	13	17	3	1	1	10	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	29.8	33.9	36.2	40.2	39.8	35.4	33.5	35.5	36.5	33.1	29.9
		MCWB	17.0	19.5	18.9	21.2	24.3	24.7	27.9	27.5	22.3	21.0	18.5	16.7
	2%	DB	26.0	27.7	31.3	34.8	37.1	36.6	33.8	32.2	33.2	34.5	31.4	28.0
		MCWB	18.3	19.5	19.8	22.0	24.5	26.7	27.8	26.6	25.1	21.7	20.0	18.7
	5%	DB	25.2	26.4	29.8	33.5	35.5	35.1	33.0	31.6	32.2	33.0	30.3	27.0
		MCWB	18.2	19.2	20.4	22.4	24.9	27.4	27.4	26.2	25.6	22.7	20.5	18.8
	10%	DB	24.5	25.4	28.5	32.3	34.3	33.9	32.3	31.0	31.2	31.8	29.3	26.2
		MCWB	17.9	18.8	20.7	22.8	25.5	27.6	27.1	25.9	25.5	23.8	20.5	18.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.0	23.8	24.9	27.2	29.0	29.7	29.1	28.4	27.7	27.8	25.4	23.5
		MCDB	25.5	26.8	28.5	30.0	31.9	33.2	32.8	32.0	30.6	31.1	28.5	26.4
	2%	WB	21.0	22.3	23.8	26.6	28.2	29.1	28.5	27.6	27.1	27.1	24.6	22.2
		MCDB	24.5	25.3	27.1	29.7	31.6	32.7	32.3	30.8	30.3	30.1	28.0	25.4
	5%	WB	20.2	21.6	23.2	26.0	27.9	28.7	28.0	27.1	26.7	26.6	24.0	21.5
		MCDB	23.8	24.7	26.6	29.2	31.4	32.2	31.8	30.4	29.9	29.6	27.6	24.9
	10%	WB	19.5	20.8	22.6	25.3	27.5	28.2	27.6	26.6	26.4	26.1	23.3	20.7
		MCDB	23.1	24.0	26.2	28.7	31.1	31.8	31.4	30.0	29.6	29.1	26.9	24.4
Mean Daily Temperature Range	5% DB	MDBR	8.8	8.2	8.0	8.1	7.3	5.9	4.5	4.4	5.6	7.7	8.7	9.2
		MCDBR	9.3	8.9	9.5	9.7	9.8	7.9	5.3	5.0	6.9	10.0	9.4	9.7
		MCWBR	5.4	4.4	4.2	3.9	3.7	2.7	1.8	1.8	2.4	4.7	4.5	5.5
	5% WB	MCDBR	8.8	8.0	7.7	7.9	7.5	6.5	5.2	5.0	6.0	7.6	8.0	8.2
		MCWBR	5.6	4.5	3.9	3.9	2.9	2.4	2.0	2.1	2.2	3.3	3.8	5.3
Clear-Sky Solar Irradiance	taub	0.405	0.452	0.504	0.550	0.603	0.688	0.757	0.685	0.591	0.498	0.430	0.410	
	taud	2.226	2.081	1.935	1.857	1.772	1.639	1.557	1.672	1.810	1.972	2.151	2.191	
	Ebn at Noon	838	823	799	772	729	665	620	664	718	767	804	813	
	Edh at Noon	125	155	189	208	227	257	278	248	211	171	134	125	
All-Sky Solar Radiation	RadAvg	4.35	5.18	6.20	7.00	7.46	7.13	6.21	6.00	6.05	5.62	4.69	4.13	
	RadStd	0.18	0.21	0.25	0.22	0.12	0.33	0.37	0.33	0.22	0.13	0.14	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page