

PASNI, Pakistan

WMO: 417590

Lat: 25.290N

Lon: 63.344E

Elev: 12

StdP: 14.69

Time Zone: 5.00 (E05)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 52.8	(c) 55.3	(d) 20.4	(e) 15.3	(f) 64.9	(g) 26.1	(h) 20.0	(i) 66.2	(j) 23.5	(k) 71.6	(l) 20.4	(m) 69.8	(n) 2.8	(o) 0	(p) 0.333

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 11.7	(c) 99.1	(d) 77.5	(e) 96.2	(f) 77.8	(g) 94.2	(h) 79.0	(i) 85.7	(j) 92.2	(k) 84.6	(l) 90.9	(m) 83.9	(n) 90.2	(o) 8.4	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
84.2	179.5	89.9	83.1	173.2	88.9	82.4	168.6	88.2	50.5	92.4	49.2	91.5	48.3	90.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.7	(b) 18.0	(c) 14.2	(e) 48.2	(f) 108.5	(g) 2.6	(h) 4.7	(i) 46.3	(j) 111.9	(k) 44.8	(l) 114.6	(m) 43.3	(n) 117.3	(o) 41.4	(p) 120.7		
(a) 40.3	(b) 88.3	(c) 3.4	(e) 40.3	(f) 88.3	(g) 3.4	(h) 3.5	(i) 37.8	(j) 90.8	(k) 35.8	(l) 92.9	(m) 33.8	(n) 94.9	(o) 31.3	(p) 97.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.2	66.7	68.9	75.5	82.2	86.8	88.2	86.6	84.7	83.8	82.2	75.3	69.0
	DBStd	7.97	3.18	4.11	3.67	3.19	3.00	2.28	1.68	1.41	2.11	2.75	3.78	3.52
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	41	20	12	0	0	0	0	0	0	0	0	0	9
	CDD50	10664	518	530	791	965	1141	1146	1133	1077	1015	999	760	589
	CDD65	5231	73	122	326	515	676	696	668	612	565	534	310	134
	CDH74	61468	320	711	2626	5691	9193	9941	9065	7581	6558	5966	2934	882
	CDH80	27965	8	101	830	2470	4882	5629	4605	3193	2632	2554	952	109
Wind	WSAvg	4.9	4.1	4.6	5.2	5.6	6.3	5.9	5.3	5.2	5.3	4.1	3.4	4.0
Precipitation	PrecAvg	3.9	1.0	0.5	0.6	0.1	0.1	0.4	0.3	0.1	0.0	0.0	0.1	0.7
	PrecMax	9.4	5.8	2.2	2.8	1.3	0.7	5.4	2.2	0.9	0.7	1.0	0.8	4.1
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.6	1.3	0.7	0.8	0.3	0.1	1.4	0.6	0.2	0.2	0.2	0.2	1.1
	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.0	87.1	94.8	99.0	106.0	104.4	94.6	92.2	98.7	98.7	92.7
MCWB			65.7	68.7	69.4	74.2	83.5	78.4	82.4	80.3	71.4	70.8	68.2	64.7
2%		DB	78.9	83.3	90.2	95.3	100.0	97.5	93.0	90.8	93.5	95.2	89.4	82.6
		MCWB	65.9	66.7	70.3	73.8	80.4	82.0	82.5	80.6	76.7	70.3	69.5	66.1
5%		DB	77.3	80.5	86.8	92.7	96.1	94.8	91.9	89.9	90.8	92.4	87.2	80.4
		MCWB	65.4	66.2	69.8	75.0	79.9	83.3	82.2	80.5	78.4	72.5	69.8	65.9
10%		DB	75.7	78.4	84.3	90.2	93.4	93.3	90.8	89.0	89.0	89.9	85.2	78.5
		MCWB	64.6	65.8	69.9	75.5	80.8	83.2	81.8	80.2	78.5	74.9	70.2	65.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.8	75.0	78.6	83.7	89.6	87.3	85.1	84.3	82.6	82.3	79.6	73.8
		MCDB	77.4	80.4	85.5	88.9	98.8	93.7	91.5	89.3	88.5	87.4	84.4	79.7
	2%	WB	70.3	73.0	75.6	81.4	85.9	86.0	84.1	82.9	81.6	80.9	77.3	71.7
		MCDB	76.2	78.2	82.9	87.5	93.5	92.0	90.2	88.1	87.6	86.8	83.5	78.4
	5%	WB	68.7	71.1	74.3	80.2	84.4	85.0	83.3	81.9	80.8	80.0	75.9	69.9
		MCDB	74.9	76.9	81.5	86.2	91.0	91.2	89.5	87.3	86.9	85.8	82.6	77.1
	10%	WB	67.2	69.3	73.1	79.1	83.3	84.3	82.7	81.1	80.1	79.1	74.4	68.4
		MCDB	73.6	75.8	80.1	85.4	89.8	90.7	89.0	86.6	86.0	84.6	81.4	75.7
Mean Daily Temperature Range	5% DB	MDBR	18.2	18.8	18.7	17.3	15.2	11.7	8.7	9.5	12.7	17.4	20.2	19.4
		MCDBR	19.9	21.4	22.4	21.1	20.0	14.2	9.9	10.5	15.2	22.0	22.1	22.3
		MCWBR	12.5	11.5	10.5	8.5	8.4	5.1	3.3	3.2	5.2	9.3	10.9	12.3
	5% WB	MCDBR	18.3	18.9	19.0	15.9	16.1	12.6	9.7	9.7	13.4	15.3	17.9	19.0
		MCWBR	13.7	12.2	11.3	8.1	7.9	5.6	3.8	4.0	4.9	7.4	10.7	12.8
Clear-Sky Solar Irradiance	taub	0.406	0.449	0.502	0.563	0.626	0.707	0.774	0.698	0.602	0.510	0.431	0.417	
	taud	2.215	2.092	1.937	1.832	1.734	1.616	1.538	1.649	1.784	1.930	2.140	2.164	
	Ebn at Noon	265	262	254	242	226	207	193	208	225	239	254	255	
	Edh at Noon	40	49	60	68	75	83	90	80	69	56	43	41	
All-Sky Solar Radiation	RadAvg	1377	1667	2000	2255	2402	2312	1957	1918	1955	1806	1499	1313	
	RadStd	74	73	75	72	31	104	129	90	70	37	45	61	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page