

DHAKA HAZRAT SHAHJALAL INTL, Bangladesh

WMO: 419220

Lat: 23.843N

Lon: 90.398E

Elev: 9

StdP: 101.22

Time Zone: 6.00 (E06)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	13.9	7.2	6.3	24.0	9.0	7.1	22.6	5.5	21.0	5.3	20.9	1.4	300	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.7	36.1	26.0	35.2	26.2	34.3	26.2	28.7	33.1	28.3	32.4	28.0	31.7	4.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.8	23.8	31.7	27.2	22.9	31.1	27.0	22.7	31.0	93.4	33.4	90.9	32.9	89.3	32.4	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.6	6.4	5.7	11.1	38.4	2.0	1.8	9.7	39.7	8.5	40.8	7.3	41.8	5.9	43.1
			DB				8.8	30.7	7.7	31.2	6.6	31.8	5.2	32.5
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.0	19.6	23.4	27.3	29.6	29.9	29.6	29.7	29.7	28.6	25.5	21.1	(6)	
(7)		DBStd	4.01	2.12	2.18	2.28	2.47	2.01	1.66	1.36	1.22	1.30	1.72	1.74	2.17	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	17	13	0	0	0	0	0	0	0	0	0	0	4	(9)
(10)		CDD10.0	6200	299	376	537	588	608	597	607	610	589	577	466	346	(10)
(11)		CDD18.3	3174	53	142	278	338	350	347	349	352	339	319	216	91	(11)
(12)		CDH23.3	36334	232	1012	2956	4320	4444	4479	4391	4478	4249	3656	1696	421	(12)
(13)		CDH26.7	16142	15	287	1320	2280	2212	2144	1944	2023	1889	1489	489	50	(13)
(14)	Wind	WSAvg	2.6	1.8	2.0	2.4	3.5	3.5	3.6	3.7	3.3	2.7	1.8	1.2	1.4	(14)
(15)	Precipitation	PrecAvg	2065	6	18	56	144	298	366	394	317	287	159	33	10	(15)
(16)		PrecMax	3016	49	66	195	318	707	850	694	552	687	427	172	86	(16)
(17)		PrecMin	1540	0	0	0	0	95	132	136	59	110	38	0	0	(17)
(18)		PrecStd	301	11	18	53	91	151	163	145	137	117	90	48	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	32.9	36.0	38.2	36.9	36.1	35.1	35.0	35.1	35.0	32.2	29.1	(19)
(20)		0.4%	MCWB	18.6	21.2	22.6	24.4	26.7	27.9	27.8	27.4	27.2	26.6	23.1	20.0	(20)
(21)		2%	DB	26.9	31.0	34.6	36.8	35.9	35.1	34.0	33.9	34.1	33.8	31.2	28.0	(21)
(22)		2%	MCWB	18.6	20.4	22.2	25.0	26.7	27.7	27.5	27.6	27.2	26.1	22.9	20.1	(22)
(23)		5%	DB	25.9	29.9	33.2	35.2	34.9	34.1	33.0	33.0	33.1	32.9	30.2	27.0	(23)
(24)		5%	MCWB	17.7	19.7	22.1	25.3	26.8	27.6	27.2	27.3	27.0	25.6	22.5	19.6	(24)
(25)		10%	DB	24.8	28.5	32.2	34.1	33.9	33.1	32.1	32.1	32.1	31.9	29.2	25.9	(25)
(26)		10%	MCWB	17.6	19.3	21.9	25.3	26.7	27.4	27.0	27.0	26.8	25.2	21.9	18.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	23.9	26.4	28.6	29.2	29.5	29.0	28.9	28.7	28.2	25.5	22.3	(27)
(28)		0.4%	MCDWB	25.0	28.1	32.1	33.6	34.5	34.2	33.1	32.8	32.8	31.9	28.9	25.5	(28)
(29)		2%	WB	19.7	22.9	25.4	27.6	28.4	28.7	28.2	28.2	28.1	27.4	24.6	21.2	(29)
(30)		2%	MCDWB	24.1	27.1	30.6	32.8	33.4	33.1	31.7	31.8	31.9	31.0	28.4	25.2	(30)
(31)		5%	WB	19.0	22.0	24.7	27.0	27.8	28.2	27.8	27.8	27.6	26.8	24.0	20.6	(31)
(32)		5%	MCDWB	23.7	26.5	29.8	32.5	32.5	32.1	31.0	31.1	31.1	30.3	28.0	24.9	(32)
(33)		10%	WB	18.2	21.0	24.1	26.6	27.3	27.8	27.4	27.4	27.2	26.5	23.4	20.0	(33)
(34)		10%	MCDWB	23.1	26.4	29.4	32.0	31.8	31.4	30.6	30.6	30.5	29.9	27.3	24.4	(34)
(35)	Mean Daily Temperature Range		MDBR	10.2	10.6	10.2	9.0	7.7	5.7	4.8	4.9	5.3	6.4	8.1	9.0	(35)
(36)		5% DB	MCDBR	11.3	11.2	10.8	9.6	8.7	7.1	6.0	5.9	6.3	7.2	8.4	9.6	(36)
(37)			MCWBR	4.9	4.1	4.3	3.9	3.9	3.1	2.6	2.6	2.7	2.9	3.3	4.1	(37)
(38)			5% WB	MCDWB	10.1	9.4	9.5	8.9	8.0	6.2	5.2	5.1	5.5	6.1	7.5	8.8
(39)		MCWBR		5.2	4.4	4.7	4.3	4.2	3.4	2.7	2.6	2.8	2.9	3.5	4.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.604	0.576	0.600	0.658	0.691	0.644	0.539	0.518	0.534	0.547	0.576	0.594	(40)	
(41)		taud	1.703	1.795	1.785	1.735	1.709	1.824	2.106	2.182	2.111	2.018	1.840	1.773	(41)	
(42)		Ebn at Noon	647	715	724	694	668	695	772	790	768	732	669	636	(42)	
(43)		Edh at Noon	215	209	220	236	241	214	161	149	157	165	186	195	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.58	4.62	5.33	5.49	5.13	4.33	4.30	4.49	4.31	4.32	4.11	3.48	(44)	
(45)		RadStd	0.23	0.28	0.40	0.40	0.48	0.35	0.41	0.37	0.28	0.25	0.24	0.34	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)	
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)	

Nomenclature: See separate page