

LILABARI, India

WMO: 423090

Lat: 27.295N

Lon: 94.098E

Elev: 101

StdP: 100.12

Time Zone: 5.50 (IND)

Period: 91-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.9	(c) 9.9	(d) 8.0	(e) 6.7	(f) 9.6	(g) 8.9	(h) 7.2	(i) 10.6	(j) 4.2	(k) 20.9	(l) 3.4	(m) 20.8	(n) 0.1	(o) 50	(p) 0.268

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 6.1	(c) 35.5	(d) 29.0	(e) 34.6	(f) 28.7	(g) 33.6	(h) 28.2	(i) 29.7	(j) 33.6	(k) 29.4	(l) 33.2	(m) 29.0	(n) 32.6	(o) 1.8	(p) 90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
28.8	25.6	32.2	28.4	25.0	31.9	28.0	24.5	31.7	99.8	33.9	98.3	33.7	96.0	32.7	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.8	(b) 4.0	(c) 3.3	(e) 6.5	(f) 37.2	(g) 2.7	(h) 1.2	(i) 4.6	(j) 38.0	(k) 3.0	(l) 38.7	(m) 1.5	(n) 39.4	(o) -0.5	(p) 40.3		
(a) 4.8	(b) 4.0	(c) 3.3	(e) 6.9	(f) 30.2	(g) 0.9	(h) 0.6	(i) 6.3	(j) 30.7	(k) 5.8	(l) 31.0	(m) 5.3	(n) 31.3	(o) 4.7	(p) 31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.9	17.0	19.3	21.9	23.6	26.3	27.8	28.5	28.7	28.1	26.2	21.5	18.1		
	DBStd	4.52	1.59	1.93	2.14	2.11	2.27	2.01	1.64	1.84	1.79	2.15	1.94	1.60		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	85	46	12	2	0	0	0	0	0	0	0	1	24		
	CDD10.0	5082	218	259	368	408	504	534	573	579	542	502	344	250		
	CDD18.3	2126	5	38	112	158	246	284	315	321	292	244	96	16		
	CDH23.3	21050	132	311	802	1023	2204	2979	3641	3775	3134	2169	696	184		
(14) Wind	WSAvg	0.9	0.7	0.8	1.1	1.1	1.1	1.1	1.2	1.1	0.9	0.7	0.6	0.6		
	PrecAvg	3628	31	63	100	212	416	734	665	611	529	181	30	17		
	PrecMax	4367	113	133	220	388	746	1095	1047	1066	820	482	72	54		
	PrecMin	2586	2	8	33	44	199	426	444	317	291	42	7	2		
	PrecStd	402	25	34	59	80	140	175	141	170	168	102	20	14		
	DB	27.4	30.0	32.9	34.2	35.2	36.4	35.9	36.6	35.8	35.0	31.5	27.7			
	MCWB	19.1	20.5	22.6	24.0	27.6	28.9	29.1	29.9	29.4	29.0	24.2	21.0			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	26.2	28.1	31.0	32.2	33.9	34.7	34.8	35.2	34.6	33.3	29.9	26.5			
	2% MCWB	18.7	19.6	21.8	24.1	27.2	28.8	29.1	29.3	28.9	27.8	23.1	19.8			
	5% DB	24.9	26.8	29.5	30.6	32.6	33.1	33.5	34.1	33.4	32.2	28.6	25.5			
	5% MCWB	18.2	19.3	21.2	23.9	26.7	28.4	28.8	29.1	28.4	26.9	22.3	19.1			
	10% DB	23.3	25.3	27.8	28.9	31.3	31.6	32.2	32.8	32.1	30.8	27.3	24.3			
	10% MCWB	17.6	18.8	20.7	23.4	26.3	28.0	28.5	28.7	28.0	25.8	21.5	18.7			
	WB	20.0	21.8	24.1	26.2	28.9	29.6	30.1	30.2	29.9	29.7	25.1	21.7			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	25.3	26.8	30.3	30.9	33.7	33.6	33.9	34.6	34.0	33.9	29.9	26.1			
	2% WB	19.3	20.8	23.0	25.2	27.8	29.2	29.6	29.7	29.4	28.5	23.9	20.7			
	2% MCDB	24.6	26.2	29.2	30.1	32.2	33.2	33.3	33.7	33.3	32.3	28.7	25.3			
	5% WB	18.6	20.0	22.1	24.4	27.2	28.7	29.2	29.4	28.8	27.5	23.0	19.8			
	5% MCDB	23.8	25.1	27.6	29.0	31.6	32.4	32.6	33.2	32.5	31.1	27.5	24.3			
	10% WB	17.9	19.2	21.2	23.7	26.5	28.2	28.6	28.9	28.3	26.7	22.2	19.1			
	10% MCDB	22.7	23.9	26.2	27.7	30.5	31.4	31.6	32.2	31.4	29.9	26.2	23.3			
(35) Mean Daily Temperature Range	MDBR	13.9	12.3	10.9	8.0	7.3	5.8	5.7	6.1	6.5	9.0	12.5	13.6			
	5% DB	16.5	15.3	14.8	12.7	10.3	8.7	8.4	8.9	9.3	10.5	13.6	14.7			
	5% WB	9.5	7.7	6.9	5.8	5.0	4.0	3.7	4.1	4.6	5.3	7.3	8.5			
	MCDBR	15.3	14.1	13.2	10.5	9.4	7.6	7.4	7.9	8.2	9.5	12.4	13.4			
	MCWBR	9.4	7.7	6.8	5.5	4.9	3.9	3.8	4.0	4.4	5.2	7.2	8.4			
(40) Clear-Sky Solar Irradiance	taub	0.565	0.629	0.712	0.688	0.576	0.520	0.457	0.469	0.469	0.438	0.458	0.482			
	taud	1.786	1.682	1.561	1.672	1.961	2.168	2.361	2.314	2.293	2.334	2.175	2.055			
	Ebn at Noon	658	654	631	668	748	786	836	826	817	821	764	720			
	Edh at Noon	191	229	272	250	187	151	124	130	129	117	128	141			
(44) All-Sky Solar Radiation	RadAvg	3.40	3.62	3.91	3.93	4.28	3.98	4.12	4.20	3.98	4.11	3.81	3.45			
	RadStd	0.36	0.40	0.40	0.37	0.52	0.41	0.42	0.49	0.40	0.35	0.33	0.24			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page