

DIBRUGARH, India

WMO: 423140

Lat: 27.484N

Lon: 95.017E

Elev: 110

StdP: 100.01

Time Zone: 5.50 (IND)

Period: 95-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.0	11.0	8.2	6.8	15.1	8.9	7.2	15.2	4.5	18.1	4.2	19.0	0.1	50	0.288

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	35.1	27.8	34.2	27.5	33.4	27.2	29.0	33.3	28.5	32.6	28.1	31.9	2.4	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.8	24.1	31.7	27.4	23.6	31.2	27.0	23.1	30.7	95.7	33.6	93.4	32.8	91.3	32.0	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.5	4.0	7.8	37.0	1.6	1.1	6.7	37.8	5.7	38.4	4.9	39.0	3.7	39.8		
			7.3	29.6	1.4	0.5	6.3	30.0	5.5	30.3	4.7	30.6	3.7	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.0	17.1	19.2	22.3	23.5	26.2	27.8	28.5	28.4	28.1	26.1	21.7	18.3
	DBStd	4.46	1.59	2.01	1.95	2.36	2.39	2.10	1.79	1.86	2.09	1.96	1.82	1.60
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	78	43	12	1	0	0	0	0	0	0	0	1	21
	CDD10.0	5096	222	258	381	406	504	534	574	571	542	498	350	257
	CDD18.3	2132	6	37	123	156	246	284	316	312	292	239	101	19
	CDH23.3	21201	74	244	801	1028	2289	3138	3781	3686	3277	2143	607	132
CDH26.7	7859	1	35	234	353	862	1185	1517	1469	1316	754	124	9	
Wind	WSAvg	1.3	0.7	1.2	1.6	2.1	1.7	1.8	1.7	1.5	1.4	0.9	0.7	0.6
Precipitation	PrecAvg	2535	28	55	108	235	294	398	513	427	317	118	23	15
	PrecMax	3202	86	147	251	565	742	914	768	774	668	357	137	61
	PrecMin	1881	0	5	19	38	87	149	250	139	54	7	0	0
	PrecStd	367	22	35	63	98	138	141	107	146	132	77	27	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.6	29.5	32.3	33.8	35.3	36.1	35.8	35.7	35.7	34.0	30.4	27.9
		MCWB	17.6	18.7	20.9	22.9	26.3	28.6	28.1	28.1	28.2	26.8	22.1	20.1
	2%	DB	25.2	27.6	30.8	32.1	33.8	34.0	34.7	34.5	34.4	32.8	29.1	25.9
		MCWB	17.0	18.1	20.4	22.9	25.9	27.8	28.0	28.3	27.7	26.3	21.2	18.3
	5%	DB	24.0	26.1	29.2	30.5	32.5	33.0	33.6	33.5	33.5	31.5	28.2	24.7
		MCWB	16.4	17.8	19.9	22.7	25.5	27.5	27.9	28.0	27.4	25.2	20.7	17.6
	10%	DB	22.6	24.7	27.8	28.7	31.1	31.8	32.3	32.3	32.3	30.4	27.0	23.6
		MCWB	16.1	17.4	19.5	22.1	25.2	27.2	27.6	27.6	27.1	24.4	20.2	17.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.2	20.6	23.2	24.9	27.9	29.2	29.3	29.5	29.1	28.1	23.3	20.7
		MCDB	24.3	25.9	28.2	29.9	32.8	34.2	33.8	33.9	34.2	32.6	28.7	26.4
	2%	WB	18.0	19.5	21.9	24.1	27.0	28.5	28.7	28.9	28.5	27.0	22.2	19.4
		MCDB	23.2	24.7	27.1	29.3	31.7	32.8	32.9	32.9	33.0	31.2	27.0	24.5
	5%	WB	17.1	18.7	21.1	23.4	26.3	27.9	28.2	28.4	27.9	26.2	21.5	18.5
		MCDB	22.1	23.6	26.7	28.4	30.7	31.8	32.1	32.1	32.1	30.1	26.1	23.1
	10%	WB	16.4	18.0	20.4	22.7	25.7	27.5	27.8	27.9	27.4	25.5	20.9	17.7
		MCDB	21.2	22.9	25.6	27.3	29.7	30.9	31.3	31.3	31.2	28.9	25.4	22.1
Mean Daily Temperature Range	5% DB	MDBR	11.7	10.8	9.9	7.4	6.7	5.5	5.4	5.3	6.4	8.3	10.7	11.9
		MCDBR	14.2	13.9	13.5	11.4	9.6	7.8	7.9	7.7	8.6	9.7	12.5	13.1
		MCWBR	6.7	5.7	5.1	4.4	3.9	3.3	3.2	3.2	3.6	4.2	5.5	6.2
	5% WB	MCDBR	12.5	11.4	10.9	9.4	8.1	6.9	6.8	6.9	7.7	8.3	10.6	11.6
		MCWBR	6.4	5.3	4.9	4.3	3.8	3.4	3.1	3.2	3.5	4.0	5.0	6.0
Clear-Sky Solar Irradiance	taub	0.540	0.608	0.706	0.667	0.558	0.507	0.448	0.462	0.459	0.422	0.425	0.452	
	taud	1.834	1.714	1.561	1.703	2.000	2.201	2.382	2.328	2.312	2.364	2.276	2.133	
	Ebn at Noon	680	670	634	682	762	796	844	832	825	836	799	752	
	Edh at Noon	182	221	272	242	180	146	122	128	126	114	116	130	
All-Sky Solar Radiation	RadAvg	3.48	3.75	4.07	4.05	4.45	4.18	4.21	4.33	4.15	4.25	3.89	3.53	
	RadStd	0.34	0.40	0.46	0.41	0.55	0.46	0.42	0.50	0.42	0.36	0.30	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page