

JAISALMER, India

WMO: 423280

Lat: 26.900N

Lon: 70.917E

Elev: 758

StdP: 14.30

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.2	48.6	16.5	13.0	70.2	21.2	16.3	67.8	15.3	70.7	12.5	65.8	2.8	50	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	25.0	110.8	74.4	108.6	74.1	106.3	74.3	82.6	95.8	81.7	94.6	80.9	93.8	7.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.9	159.9	86.8	79.0	155.1	86.6	78.2	150.4	86.5	47.4	95.9	46.4	94.0	45.6	93.5	94.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.5	18.6	16.9	40.3	114.2	3.5	2.3	37.8	115.8	35.8	117.2	33.9	118.4	31.3	120.1		
(5)			35.8	85.0	2.9	1.7	33.7	86.2	32.0	87.3	30.4	88.2	28.3	89.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	61.6	68.6	79.4	89.0	94.3	93.9	90.9	88.0	87.7	85.2	75.0	65.0	(6)
(7)		DBStd	11.86	4.76	6.15	6.57	4.86	3.81	3.64	3.30	2.82	3.28	3.99	4.79	5.14	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	224	127	30	2	0	0	0	0	0	0	0	1	64	(9)
(10)		CDD50	11535	360	521	912	1170	1372	1317	1268	1179	1132	1090	749	465	(10)
(11)		CDD65	6283	22	130	449	720	907	867	803	714	682	625	300	64	(11)
(12)		CDH74	90503	230	1286	5411	10926	15268	14287	12254	10009	9541	7987	2730	574	(12)
(13)		CDH80	56186	22	439	2927	7078	10870	9995	7823	5661	5530	4567	1153	121	(13)
(14)	Wind	WSAvg	6.1	3.5	4.0	4.4	5.6	9.2	10.7	10.6	8.5	6.7	3.7	3.1	3.2	(14)
(15)	Precipitation	PrecAvg	8.7	0.1	0.2	0.2	0.3	0.4	0.7	2.4	2.8	1.3	0.1	0.0	0.1	(15)
(16)		PrecMax	20.6	0.9	1.5	1.7	2.0	5.2	3.3	9.4	17.0	4.8	0.7	0.5	1.4	(16)
(17)		PrecMin	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	4.4	0.2	0.4	0.4	0.5	1.0	0.9	2.6	3.5	1.6	0.2	0.1	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.7	93.0	104.1	110.7	114.7	113.7	108.4	103.1	104.5	103.5	94.4	87.0	(19)
(20)			MCWB	59.6	65.2	68.9	73.3	75.1	74.0	79.6	78.6	73.5	70.2	65.3	62.9	(20)
(21)		2%	DB	79.2	89.3	100.4	107.7	111.7	110.2	105.0	100.6	102.1	101.2	91.6	83.5	(21)
(22)			MCWB	57.8	63.1	67.4	71.7	73.7	75.9	79.3	78.4	74.3	70.3	65.3	60.6	(22)
(23)		5%	DB	76.6	85.5	96.9	105.1	109.4	107.6	102.5	98.6	99.9	98.7	89.5	80.4	(23)
(24)			MCWB	56.9	61.6	66.1	71.0	73.2	76.1	79.4	78.4	74.7	70.3	64.7	58.9	(24)
(25)		10%	DB	73.5	82.0	93.5	102.4	107.2	105.1	100.5	96.6	97.5	96.5	87.1	77.0	(25)
(26)			MCWB	55.3	59.6	65.1	69.4	72.8	76.9	79.4	78.3	75.1	69.0	63.6	56.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.5	68.8	74.7	81.5	82.6	83.5	83.7	83.4	82.3	79.1	71.7	66.0	(27)
(28)			MCD B	75.5	86.3	96.2	101.9	102.4	100.0	97.3	93.7	93.6	95.3	86.5	79.4	(28)
(29)		2%	WB	60.5	66.1	71.4	76.9	80.5	81.8	82.5	81.9	80.6	76.9	69.1	63.2	(29)
(30)			MCD B	74.5	83.7	92.5	99.9	99.8	96.5	95.4	91.9	91.5	91.4	84.9	78.1	(30)
(31)		5%	WB	58.4	63.7	69.1	74.6	79.2	80.8	81.7	81.1	79.6	75.0	67.1	61.0	(31)
(32)			MCD B	72.7	79.1	89.4	96.5	96.8	95.7	94.7	90.8	90.3	89.0	84.5	76.3	(32)
(33)		10%	WB	56.7	61.6	67.1	72.7	78.0	80.0	80.9	80.4	78.6	73.2	65.1	58.9	(33)
(34)			MCD B	70.1	77.1	88.0	94.7	95.2	95.1	94.1	90.0	89.2	87.8	82.9	74.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.0	23.1	23.3	23.9	25.0	21.4	18.0	16.3	18.7	22.4	22.4	22.6	(35)
(36)			MCDBR	24.6	25.6	25.9	26.4	27.0	25.0	20.7	19.1	21.7	23.7	24.0	25.0	(36)
(37)			MCWBR	11.7	10.5	9.9	9.5	7.9	6.4	4.0	3.9	5.9	8.7	10.4	11.8	(37)
(38)		5% WB	MCD BR	21.8	22.8	23.7	25.3	25.9	20.8	18.0	15.8	16.9	20.8	21.7	22.3	(38)
(39)			MCWBR	11.4	10.1	11.0	10.4	7.3	5.5	4.9	4.6	5.5	9.3	11.0	11.8	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.426	0.447	0.500	0.580	0.639	0.701	0.742	0.663	0.563	0.516	0.497	0.451	(40)
(41)		taud		1.993	1.967	1.844	1.703	1.624	1.568	1.539	1.676	1.841	1.831	1.827	1.927	(41)
(42)		Ebn at Noon		252	259	253	237	223	208	199	214	233	234	227	237	(42)
(43)		Edh at Noon		49	54	65	77	83	88	90	78	64	61	57	50	(43)
(44)	All-Sky Solar Radiation	RadAvg		1293	1580	1935	2165	2263	2120	1899	1866	1868	1715	1368	1223	(44)
(45)		RadStd		57	62	64	57	50	77	99	99	92	62	66	50	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page