

JAISALMER, India

WMO: 423280

Lat: 26.900N

Lon: 70.917E

Elev: 231

StdP: 98.58

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.9	9.2	-8.6	1.9	21.2	-6.0	2.3	19.9	6.8	21.5	5.6	18.8	1.3	50	0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.9	43.8	23.6	42.6	23.4	41.3	23.5	28.1	35.4	27.6	34.8	27.2	34.3	3.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.8	30.4	26.1	22.2	30.3	25.6	21.5	30.3	92.4	35.5	90.1	34.4	88.1	34.2	34.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 9.6	(b) 8.3	(c) 7.5	(e) 4.6	(f) 45.6	(g) 1.9	(h) 1.3	(i) 3.2	(j) 46.6	(k) 2.1	(l) 47.3	(m) 1.0	(n) 48.0	(o) -0.4	(p) 49.0		
			DB													
			WB													
				2.1		29.4	1.6	1.0	1.0	30.1	0.0	30.7	-0.9	31.2	-2.0	31.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	16.4	20.3	26.3	31.7	34.6	34.4	32.7	31.1	31.0	29.5	23.9	18.3
	DBStd	6.59	2.65	3.42	3.65	2.70	2.12	2.02	1.84	1.56	1.82	2.22	2.66	2.85
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	124	71	17	1	0	0	0	0	0	0	0	1	36
	CDD10.0	6408	200	289	507	650	762	732	704	655	629	606	416	258
	CDD18.3	3491	12	72	249	400	504	482	446	397	379	347	167	36
	CDH23.3	50279	128	714	3006	6070	8482	7937	6808	5561	5301	4437	1517	319
CDH26.7	31214	12	244	1626	3932	6039	5553	4346	3145	3072	2537	641	67	
Wind	WSAvg	2.7	1.6	1.8	2.0	2.5	4.1	4.8	4.7	3.8	3.0	1.7	1.4	1.4
Precipitation	PrecAvg	220	2	5	5	8	11	18	62	72	32	3	1	2
	PrecMax	523	22	37	43	50	131	83	239	433	123	19	13	36
	PrecMin	34	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	112	4	10	11	13	26	22	67	89	40	5	3	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.2	33.9	40.0	43.7	45.9	45.4	42.5	39.5	40.3	39.7	34.7	30.6
		MCWB	15.3	18.4	20.5	23.0	23.9	23.3	26.5	25.9	23.1	21.2	18.5	17.2
	2%	DB	26.2	31.8	38.0	42.0	44.3	43.4	40.6	38.1	38.9	38.4	33.1	28.6
		MCWB	14.3	17.3	19.7	22.0	23.2	24.4	26.3	25.8	23.5	21.3	18.5	15.9
	5%	DB	24.8	29.7	36.0	40.6	43.0	42.0	39.2	37.0	37.7	37.1	31.9	26.9
		MCWB	13.8	16.4	19.0	21.7	22.9	24.5	26.3	25.8	23.7	21.3	18.2	15.0
	10%	DB	23.1	27.8	34.2	39.1	41.8	40.6	38.0	35.9	36.4	35.8	30.6	25.0
		MCWB	13.0	15.4	18.4	20.8	22.7	24.9	26.3	25.7	24.0	20.6	17.6	13.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.5	20.4	23.7	27.5	28.1	28.6	28.7	28.6	27.9	26.1	22.0	18.9
		MCDB	24.2	30.2	35.7	38.8	39.1	37.8	36.3	34.3	34.2	35.2	30.3	26.4
	2%	WB	15.8	18.9	21.9	24.9	27.0	27.7	28.0	27.7	27.0	24.9	20.6	17.3
		MCDB	23.6	28.7	33.6	37.7	37.7	35.9	35.2	33.3	33.1	33.0	29.4	25.6
	5%	WB	14.7	17.6	20.6	23.6	26.2	27.1	27.6	27.3	26.4	23.9	19.5	16.1
		MCDB	22.6	26.2	31.9	35.9	36.0	35.4	34.8	32.7	32.4	31.7	29.1	24.6
	10%	WB	13.7	16.5	19.5	22.6	25.6	26.7	27.2	26.9	25.9	22.9	18.4	14.9
		MCDB	21.2	25.1	31.1	34.8	35.1	35.1	34.5	32.2	31.8	31.0	28.3	23.3
Mean Daily Temperature Range	5% DB	MDBR	12.2	12.9	12.9	13.3	13.9	11.9	10.0	9.0	10.4	12.4	12.5	12.6
		MCDBR	13.7	14.2	14.4	14.7	15.0	13.9	11.5	10.6	12.1	13.2	13.3	13.9
		MCWBR	6.5	5.8	5.5	5.3	4.4	3.6	2.2	2.2	3.3	4.8	5.8	6.6
	5% WB	MCDBR	12.1	12.7	13.2	14.1	14.4	11.5	10.0	8.8	9.4	11.6	12.0	12.4
		MCWBR	6.3	5.6	6.1	5.8	4.1	3.0	2.7	2.6	3.0	5.2	6.1	6.5
Clear-Sky Solar Irradiance	taub		0.426	0.447	0.500	0.580	0.639	0.701	0.742	0.663	0.563	0.516	0.497	0.451
	taud		1.993	1.967	1.844	1.703	1.624	1.568	1.539	1.676	1.841	1.831	1.827	1.927
	Ebn at Noon		796	817	797	746	702	656	628	676	734	739	715	746
	Edh at Noon		154	171	205	242	262	276	283	246	203	193	181	159
All-Sky Solar Radiation	RadAvg		4.08	4.98	6.10	6.83	7.13	6.68	5.99	5.88	5.89	5.41	4.31	3.85
	RadStd		0.18	0.20	0.20	0.18	0.16	0.24	0.31	0.31	0.29	0.20	0.21	0.16

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page