

JODHPUR, India

WMO: 423390

Lat: 26.2573N

Lon: 73.0408E

Elev: 717

StdP: 14.32

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.7	49.8	16.8	13.2	75.2	21.6	16.7	72.1	9.9	69.8	7.7	67.4	1.4	50	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	20.7	109.0	71.1	106.7	71.3	104.4	71.6	82.0	91.2	81.1	90.2	80.4	89.6	4.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.1	160.5	85.9	79.1	155.3	85.1	78.3	151.2	84.7	46.8	91.4	45.7	90.1	44.9	89.3	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	9.9	7.6	42.3	112.5	2.7	2.4	40.4	114.2	38.8	115.7	37.3	117.0	35.4	118.8
			36.4	84.3	2.1	1.3	34.9	85.3	33.7	86.0	32.6	86.8	31.1	87.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	63.5	69.5	79.9	89.3	94.7	93.7	88.8	85.6	86.1	83.6	74.6	66.5	(6)
(7)		DBStd	10.94	4.05	5.45	5.58	4.57	4.11	4.34	4.00	2.92	3.14	3.58	4.07	4.30	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	130	77	18	0	0	0	0	0	0	0	0	0	35	(9)
(10)		CDD50	11449	420	547	928	1179	1384	1312	1202	1104	1084	1042	737	510	(10)
(11)		CDD65	6105	32	146	463	729	919	862	737	639	634	577	287	80	(11)
(12)		CDH74	85158	350	1437	5589	11126	15337	14052	10645	8247	8325	6880	2535	635	(12)
(13)		CDH80	51013	40	500	3048	7219	10944	9778	6258	3950	4285	3822	1056	113	(13)
(14)	Wind	WSAvg	2.5	1.9	2.3	2.4	3.0	4.2	4.4	3.6	2.7	2.1	1.0	1.1	1.6	(14)
(15)	Precipitation	PrecAvg	13.7	0.1	0.2	0.1	0.2	0.5	1.6	4.8	5.1	2.0	0.2	0.1	0.0	(15)
(16)		PrecMax	29.8	0.9	1.3	1.0	1.5	4.6	7.4	14.0	16.7	14.5	2.5	2.3	1.2	(16)
(17)		PrecMin	2.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	6.5	0.2	0.4	0.2	0.4	0.9	1.6	3.2	3.8	2.7	0.5	0.4	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.7	92.9	103.2	109.0	112.7	112.0	105.0	98.9	102.2	102.8	93.6	86.4	(19)
(20)		0.4%	MCWB	60.1	62.5	65.2	68.0	70.2	74.9	78.1	77.9	72.7	67.6	64.1	61.3	(20)
(21)		2%	DB	80.7	89.5	99.8	106.4	109.7	107.9	101.4	96.1	99.5	99.4	91.2	82.9	(21)
(22)		2%	MCWB	58.3	62.1	64.2	67.7	70.4	75.1	78.1	78.3	73.1	68.7	64.0	60.1	(22)
(23)		5%	DB	78.1	86.0	96.7	104.0	107.6	105.4	99.0	94.0	97.0	97.2	89.1	80.4	(23)
(24)		5%	MCWB	57.4	60.5	64.1	67.1	70.3	75.3	78.0	78.2	74.2	68.3	63.6	59.3	(24)
(25)		10%	DB	75.2	82.4	93.6	101.8	105.3	102.9	96.8	92.0	94.5	95.1	86.7	77.6	(25)
(26)		10%	MCWB	55.8	59.6	63.1	66.7	71.0	76.0	77.9	78.1	75.2	68.0	63.0	58.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.4	67.1	70.8	76.0	80.4	82.8	83.5	83.1	82.5	79.1	72.7	65.5	(27)
(28)		0.4%	MCDWB	76.1	83.8	91.4	96.5	98.6	96.8	92.8	90.3	91.6	89.2	79.4	78.9	(28)
(29)		2%	WB	61.5	64.7	68.5	73.1	78.6	81.0	82.0	81.8	80.7	76.7	68.9	63.2	(29)
(30)		2%	MCDWB	75.0	81.5	90.1	95.0	96.8	94.8	90.4	89.3	88.4	86.3	84.4	77.4	(30)
(31)		5%	WB	59.6	62.9	66.9	71.1	77.3	80.0	81.0	80.9	79.5	74.3	66.9	61.4	(31)
(32)		5%	MCDWB	73.3	79.9	88.6	94.6	95.0	94.2	89.6	88.0	87.6	87.7	83.4	76.4	(32)
(33)		10%	WB	57.6	61.2	65.3	69.5	76.1	79.2	80.3	80.1	78.5	72.3	64.9	59.7	(33)
(34)		10%	MCDWB	71.8	78.5	87.5	93.9	94.7	93.9	89.1	87.1	87.0	87.8	81.8	74.8	(34)
(35)	Mean Daily Temperature Range		MDBR	23.4	24.2	24.6	23.5	20.7	17.2	13.2	11.5	15.3	24.0	25.1	24.1	(35)
(36)		5% DB	MCDBR	26.8	28.0	27.6	25.3	22.0	19.5	16.2	14.4	19.5	25.9	27.3	26.7	(36)
(37)		5% DB	MCWBR	12.0	10.7	9.5	8.2	7.5	5.7	3.9	4.1	5.9	8.1	11.0	12.2	(37)
(38)		5% WB	MCDWB	23.4	23.8	23.9	21.7	19.3	16.9	13.7	11.8	13.4	19.0	23.3	24.3	(38)
(39)		5% WB	MCWBR	11.8	10.4	9.7	8.9	7.4	5.4	4.8	4.6	5.3	6.9	10.6	12.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.400	0.417	0.465	0.536	0.604	0.672	0.704	0.625	0.543	0.494	0.471	0.425	(40)	
(41)		taud	2.106	2.091	1.968	1.834	1.728	1.642	1.618	1.786	1.938	1.938	1.936	2.035	(41)	
(42)		Ebn at Noon	264	270	264	248	231	214	207	223	239	243	237	248	(42)	
(43)		Edh at Noon	44	48	57	68	75	81	83	70	59	56	52	45	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1345	1649	2009	2248	2327	2125	1747	1682	1821	1754	1408	1268	(44)	
(45)		RadStd	58	59	65	51	51	97	132	118	105	48	82	52	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page