

JODHPUR, India

WMO: 423390

Lat: 26.2573N

Lon: 73.0408E

Elev: 219

StdP: 98.73

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.7	9.9	-8.4	1.9	24.0	-5.8	2.4	22.3	4.4	21.0	3.5	19.7	0.6	50	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.5	42.8	21.7	41.5	21.9	40.2	22.0	27.8	32.9	27.3	32.3	26.9	32.0	2.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.9	30.0	26.2	22.2	29.5	25.7	21.6	29.3	91.1	33.0	88.5	32.3	86.6	31.8	33.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.5	4.4	3.4	5.7	44.7	1.5	1.3	4.7	45.7	3.8	46.5	3.0	47.2	1.9	48.2		
			2.5	29.1	1.1	0.7	1.6	29.6	1.0	30.0	0.3	30.4	-0.5	31.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.4	17.5	20.9	26.6	31.8	34.8	34.3	31.5	29.8	30.1	28.7	23.6	19.1
	DBStd	6.08	2.25	3.03	3.10	2.54	2.29	2.41	2.22	1.62	1.74	1.99	2.26	2.39
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	72	43	10	0	0	0	0	0	0	0	0	0	19
	CDD10.0	6361	233	304	516	655	769	729	668	613	602	579	409	283
	CDD18.3	3392	18	81	257	405	511	479	409	355	352	321	159	44
	CDH23.3	47310	194	798	3105	6181	8521	7807	5914	4582	4625	3822	1408	353
	CDH26.7	28341	22	278	1693	4011	6080	5432	3477	2194	2381	2123	587	63
Wind	WSAvg	1.1	0.9	1.0	1.1	1.3	1.9	2.0	1.6	1.2	0.9	0.4	0.5	0.7
Precipitation	PrecAvg	349	2	5	2	5	13	41	122	129	51	6	3	1
	PrecMax	756	23	32	26	37	117	187	356	424	369	63	59	30
	PrecMin	60	0	0	0	0	0	0	0	7	0	0	0	0
	PrecStd	166	5	9	6	9	22	40	81	96	68	12	11	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.7	33.8	39.6	42.8	44.8	44.4	40.5	37.2	39.0	39.3	34.2	30.2
		MCWB	15.6	16.9	18.4	20.0	21.2	23.8	25.6	25.5	22.6	19.8	17.8	16.3
	2%	DB	27.0	31.9	37.6	41.3	43.2	42.2	38.5	35.6	37.5	37.4	32.9	28.3
		MCWB	14.6	16.7	17.9	19.8	21.3	23.9	25.6	25.7	22.8	20.4	17.8	15.6
	5%	DB	25.6	30.0	36.0	40.0	42.0	40.8	37.2	34.5	36.1	36.2	31.7	26.9
		MCWB	14.1	15.8	17.9	19.5	21.3	24.1	25.6	25.7	23.5	20.2	17.6	15.2
	10%	DB	24.0	28.0	34.2	38.8	40.7	39.4	36.0	33.3	34.7	35.1	30.4	25.3
		MCWB	13.2	15.3	17.3	19.3	21.7	24.4	25.5	25.6	24.0	20.0	17.2	14.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.0	19.5	21.6	24.5	26.9	28.2	28.6	28.4	28.1	26.2	22.6	18.6
		MCDB	24.5	28.8	33.0	35.8	37.0	36.0	33.8	32.4	33.1	31.8	26.3	26.1
	2%	WB	16.4	18.2	20.3	22.8	25.9	27.2	27.8	27.7	27.0	24.8	20.5	17.3
		MCDB	23.9	27.5	32.3	35.0	36.0	34.9	32.4	31.8	31.3	30.2	29.1	25.2
	5%	WB	15.4	17.2	19.4	21.7	25.2	26.7	27.2	27.2	26.4	23.5	19.4	16.3
		MCDB	22.9	26.6	31.4	34.8	35.0	34.5	32.0	31.1	30.9	31.0	28.6	24.7
	10%	WB	14.2	16.2	18.5	20.8	24.5	26.2	26.8	26.7	25.9	22.4	18.3	15.4
		MCDB	22.1	25.9	30.8	34.4	34.8	34.4	31.7	30.6	30.6	31.0	27.6	23.8
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.4	13.7	13.1	11.5	9.6	7.3	6.4	8.5	13.3	13.9	13.4
		MCDBR	14.9	15.5	15.3	14.0	12.2	10.9	9.0	8.0	10.8	14.4	15.2	14.9
	5% WB	MCWBR	6.7	6.0	5.3	4.5	4.2	3.2	2.2	2.3	3.3	4.5	6.1	6.8
		MCWBR	13.0	13.2	13.3	12.0	10.7	9.4	7.6	6.6	7.4	10.6	12.9	13.5
Clear-Sky Solar Irradiance	taub		0.400	0.417	0.465	0.536	0.604	0.672	0.704	0.625	0.543	0.494	0.471	0.425
		taud	2.106	2.091	1.968	1.834	1.728	1.642	1.618	1.786	1.938	1.938	1.936	2.035
	Ebn at Noon		832	851	831	782	728	675	653	704	753	765	748	783
		Edh at Noon	139	152	181	213	236	256	262	220	185	175	164	143
All-Sky Solar Radiation	RadAvg		4.24	5.20	6.33	7.09	7.34	6.70	5.51	5.30	5.74	5.53	4.44	4.00
	RadStd		0.18	0.18	0.20	0.16	0.16	0.31	0.42	0.37	0.33	0.15	0.26	0.16

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page