

GUWAHATI INTL, India

WMO: 424100

Lat: 26.106N

Lon: 91.586E

Elev: 162

StdP: 14.61

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.8	53.5	47.1	48.1	68.3	49.6	52.8	64.4	11.3	74.5	9.8	73.8	0.2	180	0.291

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.0	95.4	82.1	93.9	81.7	92.6	81.2	85.1	91.9	84.4	91.0	83.6	89.8	6.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
83.8	177.9	88.8	82.7	171.5	87.9	82.2	168.9	87.5	49.9	92.0	48.9	91.1	48.1	90.3	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.1	10.4	9.1	DB	48.3	99.2	1.8	1.9	47.0	100.6	45.9	101.7	44.9	102.8	43.5	104.2	
			WB	47.8	86.4	1.8	1.3	46.5	87.3	45.5	88.1	44.5	88.9	43.2	89.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.2	64.0	68.5	74.8	78.4	81.6	84.1	85.0	85.4	83.9	80.4	73.5	66.7
	DBStd	7.90	3.04	3.55	3.55	3.82	3.18	2.85	2.47	2.44	2.57	3.06	3.31	2.85
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	78	55	9	0	0	0	0	0	0	0	0	0	14
	CDD50	9940	433	517	769	853	979	1023	1087	1097	1018	941	705	518
	CDD65	4543	23	106	304	403	514	573	622	632	568	476	255	67
	CDH74	48149	178	801	2691	3636	5429	6891	7769	7907	6564	4445	1508	330
	CDH80	19041	6	151	1045	1485	2112	2845	3394	3533	2573	1553	327	17
(14) Wind	WSAvg	2.5	1.5	2.1	3.2	3.9	3.4	2.7	2.6	2.7	2.2	2.1	1.7	1.5
(15) Precipitation	PrecAvg	66.6	0.4	0.7	2.0	6.5	9.3	12.3	12.8	10.1	7.1	3.8	0.7	0.2
	PrecMax	96.3	3.0	3.8	6.0	21.5	22.4	22.6	25.5	23.4	14.6	13.9	3.5	1.9
	PrecMin	43.2	0.0	0.0	0.2	0.6	2.4	3.7	5.2	2.6	1.0	0.1	0.0	0.0
	PrecStd	10.0	0.5	0.7	1.5	4.0	4.3	4.4	4.4	4.1	3.2	3.0	0.8	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.7	87.1	93.7	97.5	95.9	96.9	96.5	97.0	95.3	93.6	88.0	82.0
		MCWB	66.4	68.2	69.8	74.3	80.3	84.5	83.7	85.0	83.7	82.8	75.9	70.2
	2%	DB	78.2	84.1	90.8	93.3	93.3	93.9	93.9	94.7	93.4	91.1	85.6	79.7
		MCWB	65.2	67.3	69.8	74.7	79.9	83.1	83.6	84.2	82.8	80.8	74.5	68.6
	5%	DB	75.6	81.7	88.2	90.7	91.2	91.8	92.0	92.9	91.6	89.2	83.7	77.6
		MCWB	63.9	66.4	69.1	74.6	79.4	82.3	83.1	83.5	82.1	79.4	73.4	67.2
	10%	DB	73.4	79.1	85.9	88.0	89.2	89.9	90.2	91.1	89.8	87.3	81.8	75.5
		MCWB	63.2	65.2	68.4	74.6	78.9	81.8	82.6	82.8	81.6	78.5	72.4	66.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.1	72.3	76.4	80.1	83.7	85.5	86.0	86.2	85.5	83.7	77.8	72.0
		MCDB	76.9	81.8	86.0	88.5	91.3	92.8	92.5	93.5	91.8	91.2	84.9	78.7
	2%	WB	66.8	69.4	73.8	78.3	82.0	84.4	84.7	85.0	84.3	82.0	75.8	70.0
		MCDB	74.9	79.4	84.3	86.9	88.9	91.3	91.0	92.1	90.8	88.4	83.0	77.3
	5%	WB	65.1	67.7	72.4	77.2	80.8	83.4	83.9	84.2	83.3	80.8	74.6	68.5
		MCDB	73.3	77.9	82.6	85.8	87.7	89.6	89.8	91.0	89.2	86.8	81.4	75.5
	10%	WB	63.8	66.5	70.9	76.1	79.8	82.5	83.2	83.4	82.4	79.6	73.5	67.1
		MCDB	71.7	76.5	80.7	84.4	86.4	88.1	88.6	89.4	87.7	85.0	79.7	73.7
(35) Mean Daily Temperature Range	5% DB	MDBR	20.3	22.1	22.3	16.4	13.7	10.7	10.0	11.0	11.2	13.9	17.3	19.5
		MCDBR	23.4	25.2	25.9	22.3	17.1	13.9	12.9	13.8	14.3	15.7	18.3	21.4
		MCWBR	11.5	10.5	9.0	8.1	6.8	6.0	5.2	5.6	6.1	6.9	8.5	10.9
	5% WB	MCDBR	21.9	22.8	21.1	17.4	14.9	12.7	11.5	12.9	13.1	14.3	16.6	19.7
		MCWBR	12.0	10.9	9.3	8.2	6.8	6.1	5.4	5.8	6.3	7.0	8.4	11.2
(40) Clear-Sky Solar Irradiance	taub		0.557	0.581	0.631	0.658	0.634	0.579	0.494	0.499	0.514	0.487	0.519	0.522
	taud		1.799	1.773	1.703	1.720	1.808	1.973	2.237	2.220	2.151	2.174	1.975	1.941
	Ebn at Noon		213	222	220	219	224	235	256	255	247	246	225	218
	Edh at Noon		61	67	75	76	69	58	45	45	47	44	50	51
(44) All-Sky Solar Radiation	RadAvg		1184	1401	1592	1590	1541	1334	1343	1391	1315	1372	1309	1166
(45)	RadStd		83	97	125	161	123	119	122	128	80	104	76	54

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.99	N/A	+1.49	+1.44	+1.39	+1.40	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	+0.99	N/A	+1.49	+1.44	+1.39	+1.40	N/A	N/A	N/A	N/A

Nomenclature: See separate page