

TEZPUR, India

WMO: 424150

Lat: 26.617N

Lon: 92.783E

Elev: 79

StdP: 100.38

Time Zone: 5.50 (IND)

Period: 95-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	12.1	9.2	7.3	17.2	10.1	7.7	16.1	2.5	19.2	2.3	19.4	0.0	N/A	0.259

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	34.6	27.6	33.9	27.4	33.1	27.2	29.0	32.8	28.6	32.2	28.2	31.6	0.5	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.1	24.5	31.3	27.7	23.9	30.9	27.3	23.4	30.5	95.7	33.0	93.7	32.4	92.0	31.9	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
2.5	2.2	1.7	9.5	36.9	1.0	1.0	8.7	37.6	8.1	38.2	7.6	38.7	6.9	39.4		
			9.1	29.7	1.0	0.3	8.4	29.9	7.8	30.1	7.3	30.3	6.6	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	17.8	20.4	23.6	24.9	27.0	28.2	28.9	29.0	28.5	26.5	22.5	19.1	
	DBStd	4.19	1.48	1.92	1.95	2.13	2.02	1.76	1.49	1.55	1.57	1.81	1.59	1.49	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	41	28	4	0	0	0	0	0	0	0	0	0	9	
	CDD10.0	5370	242	291	422	448	526	545	584	589	554	511	376	282	
	CDD18.3	2369	11	62	163	198	268	295	326	331	304	253	126	33	
	CDH23.3	23629	76	352	1202	1491	2637	3336	3961	4047	3444	2244	687	152	
	CDH26.7	8674	2	56	418	524	975	1237	1598	1673	1284	762	138	8	
Wind	WSAvg	0.2	0.2	0.3	0.5	0.5	0.3	0.2	0.2	0.1	0.2	0.2	0.2	0.2	
Precipitation	PrecAvg	1947	12	28	60	159	268	359	332	319	266	118	27	8	
	PrecMax	2568	72	97	149	331	396	673	509	560	498	307	170	80	
	PrecMin	1146	0	6	9	3	143	113	176	111	121	20	4	0	
	PrecStd	412	15	22	38	73	74	143	89	113	91	71	37	17	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.7	30.1	33.4	35.2	35.1	35.1	35.0	35.5	35.0	33.9	30.5	27.6	
		MCWB	18.0	20.0	20.8	23.0	27.2	27.8	28.4	28.6	28.2	27.8	22.8	20.2	
	2%	DB	25.2	28.4	31.9	32.9	33.7	33.7	33.9	34.2	33.8	32.5	29.3	26.1	
		MCWB	17.9	19.1	20.9	23.3	26.5	27.9	28.2	28.6	28.0	26.7	22.4	19.2	
	5%	DB	24.0	27.0	30.5	31.2	32.5	32.6	32.9	33.2	32.8	31.5	28.3	25.0	
		MCWB	17.5	18.7	20.6	23.1	26.0	27.6	28.0	28.4	27.7	25.9	21.9	18.6	
	10%	DB	22.6	25.6	29.2	29.7	31.3	31.6	32.0	32.1	31.8	30.4	27.2	23.9	
		MCWB	17.0	18.3	20.3	22.7	25.7	27.4	27.9	28.0	27.5	25.4	21.3	18.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	21.6	23.9	25.7	28.2	28.7	29.4	29.6	29.2	28.6	24.1	20.9
			MCDB	24.1	26.9	29.7	30.4	33.2	32.7	33.2	33.5	33.3	32.4	28.6	25.8
		2%	WB	18.7	20.3	22.7	24.7	27.3	28.3	28.7	29.1	28.6	27.6	23.2	20.0
			MCDB	23.0	26.0	28.5	29.6	32.0	32.1	32.3	32.7	32.4	31.2	27.8	24.8
5%		WB	17.9	19.6	21.7	24.1	26.7	28.0	28.4	28.7	28.1	26.8	22.6	19.3	
		MCDB	22.5	25.1	27.7	29.0	30.9	31.6	31.8	32.0	31.6	30.0	26.9	23.6	
10%		WB	17.2	18.9	21.1	23.4	26.2	27.6	28.0	28.2	27.7	26.1	21.9	18.6	
		MCDB	21.7	24.2	27.2	28.0	30.1	30.8	31.3	31.3	30.8	29.2	26.0	22.7	
Mean Daily Temperature Range		5% DB	MDBR	10.9	11.1	10.8	8.2	7.1	5.5	5.2	5.4	5.9	7.8	9.8	10.7
			MCDBR	12.9	13.1	13.5	11.5	9.3	7.3	6.9	7.1	7.8	8.9	11.0	11.8
	MCWBR		6.2	5.0	4.9	4.1	3.6	2.8	2.6	2.8	3.1	3.8	4.8	5.5	
	5% WB	MCDBR	11.7	11.4	11.4	9.0	8.2	6.4	6.3	6.5	6.9	7.8	9.6	10.6	
		MCWBR	6.2	5.0	5.0	4.1	3.6	2.8	2.7	2.9	3.1	3.7	4.5	5.3	
Clear-Sky Solar Irradiance	taub	0.552	0.580	0.633	0.644	0.587	0.539	0.467	0.474	0.481	0.454	0.484	0.484	0.500	
	taud	1.812	1.778	1.701	1.747	1.921	2.095	2.324	2.297	2.254	2.280	2.076	1.996		
	Ebn at Noon	675	698	690	699	740	771	828	823	808	808	740	706		
	Edh at Noon	188	209	237	232	195	163	129	132	135	125	143	150		
All-Sky Solar Radiation	RadAvg	3.58	4.20	4.72	4.75	4.82	4.38	4.46	4.48	4.25	4.26	4.01	3.57		
	RadStd	0.26	0.31	0.36	0.44	0.38	0.34	0.39	0.42	0.29	0.32	0.25	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	+0.55	N/A	+0.83	+0.80	+0.77	+0.78	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page