

GAYA, India

WMO: 425910

Lat: 24.744N

Lon: 84.951E

Elev: 116

StdP: 99.94

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.1	8.5	2.0	4.4	27.0	3.8	5.0	22.8	7.7	21.4	6.8	21.6	0.9	140	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.3	43.0	22.8	41.7	23.0	40.2	23.2	28.6	33.6	28.2	32.9	28.0	32.4	5.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.9	30.5	27.2	23.3	30.0	27.0	23.0	29.8	94.2	33.8	92.3	33.1	90.8	32.5	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	6.7	5.7	5.0	44.6	1.7	1.0	3.8	45.3	2.8	45.9	1.9	46.5	0.7	47.2		
			4.4	29.7	1.4	0.5	3.4	30.1	2.6	30.4	1.9	30.7	0.8	31.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	15.7	19.9	25.2	31.1	33.1	32.9	29.8	29.4	29.1	26.3	21.8	17.4
	DBStd	6.15	2.60	2.53	2.88	2.24	2.31	2.79	1.60	1.23	1.32	1.93	2.08	2.36
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	144	86	11	0	0	0	0	0	0	0	0	1	46
	CDD10.0	5840	179	277	471	632	716	686	614	602	574	506	356	228
	CDD18.3	2941	6	55	212	382	458	436	356	343	324	247	106	16
	CDH23.3	39076	67	559	2541	5742	7319	6697	4585	4261	3910	2374	873	148
	CDH26.7	21397	4	154	1367	3728	4948	4333	2168	1844	1684	931	224	11
Wind	WSAvg	1.8	1.3	1.6	2.0	2.3	2.6	2.6	2.3	2.0	1.8	1.1	0.8	1.1
Precipitation	PrecAvg	1037	19	17	10	7	28	149	275	310	166	55	8	4
	PrecMax	1378	91	55	38	48	105	397	540	526	416	186	63	40
	PrecMin	565	3	2	0	0	0	5	115	162	43	2	0	0
	PrecStd	207	21	16	10	12	27	109	116	90	92	52	18	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.2	32.8	39.1	43.2	44.2	44.6	37.1	35.2	35.2	34.1	31.2	28.0
		MCWB	17.4	19.6	20.4	22.1	22.8	23.6	27.2	28.0	27.3	25.7	21.6	18.9
	2%	DB	25.1	30.1	36.7	41.9	43.0	43.1	35.6	34.2	34.3	33.0	30.1	26.2
		MCWB	16.1	19.1	20.4	21.3	22.5	23.8	27.4	27.8	27.2	25.2	20.9	17.6
	5%	DB	23.6	28.5	35.0	40.5	41.8	41.2	34.4	33.4	33.6	32.1	29.1	25.0
		MCWB	15.4	18.5	20.1	21.4	23.1	24.8	27.5	27.7	27.1	24.9	20.4	16.9
	10%	DB	22.1	26.9	33.4	39.2	40.5	39.2	33.4	32.6	32.7	31.1	28.0	23.8
		MCWB	14.9	17.7	19.8	21.6	23.4	25.6	27.5	27.5	27.0	24.3	19.9	16.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.7	22.1	23.8	27.3	28.6	29.0	29.1	29.1	28.7	27.6	24.1	20.9
		MCDB	23.5	28.4	33.0	37.3	37.5	35.9	33.5	33.1	32.9	31.8	28.5	25.6
	2%	WB	18.2	20.6	22.6	25.8	27.8	28.2	28.5	28.5	28.2	26.9	22.9	19.4
		MCDB	22.0	27.3	32.1	35.0	36.6	34.7	32.7	32.3	32.1	30.9	27.5	24.1
	5%	WB	17.2	19.6	21.6	24.8	27.1	27.8	28.1	28.1	27.7	26.3	22.0	18.3
		MCDB	20.9	26.1	31.3	34.1	35.4	34.0	32.2	31.7	31.5	29.9	26.6	23.0
	10%	WB	16.2	18.7	20.7	23.9	26.4	27.5	27.7	27.8	27.5	25.7	21.1	17.2
		MCDB	20.2	25.2	30.6	33.6	34.7	33.4	31.6	31.1	31.1	29.0	26.0	21.8
Mean Daily Temperature Range	5% DB	MDBR	12.2	13.6	15.2	15.4	13.3	9.9	6.2	6.0	6.8	9.6	13.2	13.0
		MCDBR	14.6	15.4	16.8	17.1	15.5	13.2	8.0	7.3	8.2	10.4	13.0	14.1
		MCWBR	6.7	6.3	5.5	5.6	4.6	3.7	2.4	2.4	2.6	3.8	5.0	6.3
	5% WB	MCDBR	11.1	13.6	15.2	14.4	12.3	9.6	6.9	6.5	7.0	8.2	11.5	12.0
	MCWBR	6.0	6.3	5.7	5.6	4.4	3.2	2.6	2.6	2.7	3.3	5.1	6.2	
Clear-Sky Solar Irradiance	taub	0.557	0.516	0.526	0.591	0.678	0.703	0.612	0.585	0.582	0.592	0.643	0.626	
	taud	1.744	1.886	1.892	1.794	1.660	1.647	1.852	1.939	1.925	1.824	1.639	1.645	
	Ebn at Noon	681	763	781	741	677	655	717	736	727	688	603	598	
	Edh at Noon	204	189	197	222	253	255	208	190	189	199	226	219	
All-Sky Solar Radiation	RadAvg	3.56	4.68	5.81	6.55	6.45	5.43	4.42	4.58	4.59	4.55	3.95	3.39	
	RadStd	0.30	0.29	0.21	0.33	0.29	0.41	0.39	0.20	0.33	0.38	0.19	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page