

AHMEDABAD, India

WMO: 426470

Lat: 23.0766N

Lon: 72.6276E

Elev: 58

StdP: 100.63

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	12.1	-2.6	3.1	24.7	-0.1	3.8	24.5	6.7	22.7	6.0	22.6	1.2	50	0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.4	43.1	23.0	41.9	22.9	40.5	22.8	28.6	33.8	28.0	32.8	27.6	32.3	3.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.2	30.3	27.0	22.9	30.0	26.5	22.1	29.6	93.2	33.7	90.7	33.3	88.7	32.8	34.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.6	5.9	5.3	DB	8.1	44.8	1.8	1.7	6.8	46.1	5.8	47.1	4.7	48.0	3.4	49.3	
			WB	5.1	30.2	1.5	1.2	4.0	31.1	3.1	31.8	2.2	32.5	1.1	33.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	20.3	23.2	28.2	32.4	34.7	33.3	29.9	28.9	29.5	29.0	25.2	21.6
	DBStd	4.86	2.12	2.79	2.61	2.06	1.72	2.51	2.07	1.48	1.59	1.88	2.04	2.11
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	10	6	2	0	0	0	0	0	0	0	0	0	2
	CDD10.0	6580	321	369	563	671	767	698	616	586	584	588	457	361
	CDD18.3	3548	68	138	305	421	508	448	358	327	334	329	207	103
	CDH23.3	47092	711	1522	4003	6362	7976	6693	4537	3851	4145	4082	2177	1033
	CDH26.7	26514	186	684	2367	4153	5511	4320	2148	1531	1918	2259	1088	349
Wind	WSAvg	2.3	1.9	1.9	2.0	2.4	3.4	3.7	3.2	2.8	2.2	1.3	1.4	1.7
Precipitation	PrecAvg	782	2	1	1	2	10	88	293	243	111	8	7	2
	PrecMax	1328	16	13	26	24	231	302	821	613	485	96	100	29
	PrecMin	263	0	0	0	0	0	1	36	18	0	0	0	0
	PrecStd	296	3	3	5	5	33	76	161	147	117	18	20	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	36.1	41.8	43.9	45.2	44.2	39.0	35.8	38.0	39.1	36.0	33.0
		MCWB	19.3	19.6	20.8	21.9	23.5	25.1	26.6	27.3	26.3	23.1	21.1	19.0
	2%	DB	30.1	34.1	39.3	42.1	43.9	41.9	36.9	34.1	36.1	37.8	34.8	31.2
		MCWB	17.9	18.8	19.9	21.4	23.2	25.4	26.6	26.8	26.2	23.2	20.7	18.2
	5%	DB	28.9	32.8	37.8	41.0	42.3	40.0	35.0	33.0	34.8	36.5	33.2	30.0
		MCWB	17.2	18.5	19.5	21.1	23.2	25.7	26.5	26.5	26.3	22.8	20.2	17.9
	10%	DB	27.2	31.0	36.0	39.3	41.0	38.2	33.2	32.0	33.2	35.1	32.2	28.9
		MCWB	16.6	17.9	19.3	21.0	23.1	25.9	26.5	26.3	26.0	22.4	19.9	17.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	22.1	23.7	26.4	28.5	29.2	28.9	28.7	29.6	28.2	25.8	21.4
		MCDB	28.4	31.1	34.5	33.2	35.6	35.5	33.5	32.7	34.2	33.4	32.1	28.4
	2%	WB	19.8	20.7	22.2	25.1	27.5	28.3	28.1	27.9	28.4	27.0	24.1	20.1
		MCDB	27.1	30.7	33.5	33.0	34.8	35.2	32.1	31.1	32.6	32.3	29.2	28.3
	5%	WB	18.7	19.7	21.1	24.3	26.8	27.7	27.6	27.4	27.6	26.2	22.7	19.2
		MCDB	26.0	29.5	32.9	32.9	34.4	34.6	31.5	30.6	31.4	31.1	29.7	27.4
	10%	WB	17.6	18.8	20.3	23.5	26.2	27.2	27.2	27.0	27.0	25.4	21.3	18.3
		MCDB	25.2	28.7	32.4	33.5	34.1	34.0	31.0	30.2	30.8	30.5	29.3	26.7
Mean Daily Temperature Range	5% DB	MDBR	14.3	15.1	15.2	14.6	13.4	9.8	6.2	5.8	7.6	12.8	14.7	14.7
		MCDBR	15.8	16.6	17.2	15.9	14.9	12.1	8.6	7.3	9.8	14.3	15.3	15.9
		MCWBR	6.8	6.0	6.0	5.3	5.0	3.8	2.9	3.1	4.1	4.7	5.8	6.6
	5% WB	MCDBR	13.7	14.7	14.6	14.1	13.0	9.9	6.6	6.1	7.7	9.8	13.1	13.9
		MCWBR	6.6	6.3	6.3	5.6	4.7	3.7	3.1	3.1	4.0	4.3	6.5	6.4
Clear-Sky Solar Irradiance	taub	0.422	0.428	0.484	0.539	0.579	0.689	0.719	0.656	0.591	0.531	0.522	0.462	
	taud	2.123	2.122	1.977	1.889	1.849	1.668	1.629	1.754	1.878	1.940	1.908	2.011	
	Ebn at Noon	828	855	822	783	748	665	645	687	724	747	721	767	
	Edh at Noon	141	151	182	203	210	250	260	229	199	179	175	153	
All-Sky Solar Radiation	RadAvg	4.52	5.44	6.47	7.21	7.38	5.97	4.16	4.14	5.05	5.49	4.62	4.24	
	RadStd	0.15	0.12	0.18	0.14	0.23	0.41	0.36	0.39	0.43	0.23	0.25	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.48	N/A	N/A	+0.88	N/A	N/A	N/A	N/A	+173	+172
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page