

JABALPUR, India

WMO: 426750

Lat: 23.178N

Lon: 80.052E

Elev: 1624

StdP: 13.85

Time Zone: 5.50 (IND)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 47.0	(c) 49.3	(d) 29.8	(e) 25.3	(f) 89.4	(g) 33.5	(h) 29.8	(i) 84.2	(j) 8.2	(k) 71.0	(l) 7.4	(m) 70.3	(n) 0.1	(o) 50	(p) 0.307

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 22.6	(c) 108.4	(d) 69.5	(e) 106.3	(f) 69.3	(g) 104.1	(h) 69.4	(i) 80.0	(j) 87.8	(k) 79.2	(l) 86.6	(m) 78.6	(n) 85.7	(o) 4.5	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.1	155.4	83.0	77.4	151.5	82.2	76.9	149.1	81.7	45.2	88.0	44.4	86.8	43.7	85.8	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.3	(b) 7.7	(c) 6.8	(e) 42.7	(f) 111.9	(g) 2.7	(h) 2.1	(i) 40.8	(j) 113.5	(k) 39.2	(l) 114.7	(m) 37.6	(n) 115.9	(o) 35.7	(p) 117.5		
(a) 9.3	(b) 7.7	(c) 6.8	(e) 40.2	(f) 82.5	(g) 2.7	(h) 1.6	(i) 38.3	(j) 83.6	(k) 36.8	(l) 84.5	(m) 35.3	(n) 85.4	(o) 33.3	(p) 86.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.7	63.3	69.7	78.9	88.6	94.0	90.0	81.7	80.4	81.5	79.0	71.8	65.2
	DBStd	10.13	4.45	4.87	5.17	4.11	3.47	6.09	3.69	2.61	2.46	3.50	3.71	3.96
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	148	88	13	0	0	0	0	0	0	0	0	1	46
	CDD50	10475	413	551	895	1157	1365	1199	983	942	945	898	655	472
	CDD65	5148	36	144	430	707	900	749	518	477	495	433	206	53
	CDH74	62807	326	1333	4876	10430	14652	10844	5244	4321	4899	3940	1510	432
	CDH80	33267	36	413	2584	6665	10252	6777	1794	1115	1669	1543	375	44
Wind	WSAvg	2.0	1.3	1.7	1.9	2.5	2.9	3.2	2.6	2.3	1.9	1.4	0.9	0.9
Precipitation	PrecAvg	48.0	0.7	0.8	0.7	0.4	0.6	5.8	14.4	14.1	8.5	1.4	0.3	0.3
	PrecMax	64.2	2.6	3.5	2.5	1.4	2.3	13.6	21.7	20.7	21.7	7.8	2.8	3.7
	PrecMin	35.9	0.0	0.0	0.0	0.0	0.0	2.1	6.3	8.1	1.8	0.0	0.0	0.0
	PrecStd	7.9	0.7	0.9	0.7	0.4	0.5	3.5	3.4	3.4	4.5	1.5	0.6	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.7	90.8	101.3	107.8	111.1	110.1	97.8	91.5	93.0	93.5	88.0	83.8
		MCWB	63.0	64.9	66.0	66.2	68.8	70.7	76.6	78.7	76.0	71.2	67.2	64.0
	2%	DB	80.5	87.9	97.9	105.8	109.1	107.6	93.3	89.2	91.0	91.3	85.9	80.9
		MCWB	62.2	64.0	65.1	66.3	69.2	71.5	76.8	78.1	76.2	72.3	67.5	62.7
	5%	DB	78.0	84.9	95.5	103.8	107.5	104.7	90.3	87.5	89.4	89.6	84.2	78.5
		MCWB	61.3	63.1	64.7	66.0	69.4	72.8	77.4	77.8	76.1	71.8	66.3	61.3
	10%	DB	75.1	82.3	92.7	101.6	105.4	101.6	88.0	85.7	87.8	87.8	82.2	76.2
		MCWB	59.9	62.7	64.8	66.3	69.4	73.3	77.6	77.6	76.1	71.2	65.3	60.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.2	69.6	71.8	78.4	77.3	80.8	81.3	80.4	79.9	78.2	74.6	68.1
		MCDB	77.2	83.3	89.9	94.9	97.4	92.4	88.9	86.9	87.0	86.6	82.8	76.8
	2%	WB	64.8	67.3	69.7	73.6	75.8	79.5	80.0	79.4	79.0	77.2	72.5	66.0
		MCDB	75.8	81.0	87.7	92.2	97.0	90.5	86.7	85.6	86.1	85.4	80.2	75.4
	5%	WB	63.1	65.8	68.3	71.0	74.5	78.5	79.1	78.7	78.2	76.1	70.5	64.2
		MCDB	73.6	79.6	86.4	92.1	96.1	89.1	85.4	84.7	85.0	83.7	78.2	74.4
	10%	WB	61.6	64.3	66.9	69.1	73.2	77.8	78.4	78.1	77.6	75.1	68.4	62.3
		MCDB	71.7	77.6	85.0	91.7	94.9	88.0	84.3	83.4	84.0	82.0	77.1	72.7
Mean Daily Temperature Range	5% DB	MDBR	22.4	23.3	24.6	25.3	22.6	16.7	9.8	8.7	11.7	18.5	22.7	23.9
		MCDBR	25.3	26.0	27.5	27.0	24.3	20.6	14.2	12.2	14.6	19.5	23.6	25.7
		MCWBR	11.1	9.6	8.4	7.2	6.6	5.4	4.4	4.0	4.2	5.8	8.4	10.6
	5% WB	MCDBR	20.9	22.2	23.7	23.8	21.1	15.7	11.4	10.4	11.9	14.2	17.0	21.4
		MCWBR	10.9	9.7	8.8	8.6	7.1	5.1	4.7	4.3	4.5	5.7	7.6	10.2
Clear-Sky Solar Irradiance	taub	0.442	0.442	0.478	0.532	0.592	0.646	0.598	0.550	0.523	0.511	0.498	0.452	
	taud	2.058	2.102	2.026	1.917	1.819	1.763	1.882	2.032	2.075	2.013	1.955	2.049	
	Ebn at Noon	256	266	263	250	234	220	231	243	247	243	236	246	
	Edh at Noon	48	49	55	62	69	72	64	55	52	53	53	47	
All-Sky Solar Radiation	RadAvg	1356	1660	1976	2207	2210	1719	1253	1213	1510	1620	1421	1316	
	RadStd	105	86	98	75	63	194	165	152	175	108	79	48	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page