

JABALPUR, India

WMO: 426750

Lat: 23.178N

Lon: 80.052E

Elev: 495

StdP: 95.52

Time Zone: 5.50 (IND)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.3	(c) 9.6	(d) -1.2	(e) 3.6	(f) 31.9	(g) 0.8	(h) 4.3	(i) 29.0	(j) 3.7	(k) 21.7	(l) 3.3	(m) 21.3	(n) 0.1	(o) 50	(p) 0.307

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 12.6	(c) 42.4	(d) 20.8	(e) 41.3	(f) 20.7	(g) 40.1	(h) 20.8	(i) 26.6	(j) 31.0	(k) 26.2	(l) 30.3	(m) 25.9	(n) 29.8	(o) 2.0	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	22.2	28.3	25.2	21.6	27.9	25.0	21.3	27.6	87.3	31.1	85.3	30.5	83.8	29.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.2	(b) 3.4	(c) 3.1	(e) 5.9	(f) 44.4	(g) 1.5	(h) 1.2	(i) 4.9	(j) 45.3	(k) 4.0	(l) 46.0	(m) 3.1	(n) 46.6	(o) 2.0	(p) 47.5		
(a) 4.2	(b) 3.4	(c) 3.1	(e) 4.6	(f) 28.0	(g) 1.5	(h) 0.9	(i) 3.5	(j) 28.7	(k) 2.6	(l) 29.2	(m) 1.8	(n) 29.7	(o) 0.7	(p) 30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	17.4	20.9	26.0	31.4	34.5	32.2	27.6	26.9	27.5	26.1	22.1	18.5
	DBStd	5.63	2.47	2.71	2.87	2.28	1.93	3.38	2.05	1.45	1.37	1.94	2.06	2.20
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	82	49	7	0	0	0	0	0	0	0	0	1	26
	CDD10.0	5819	229	306	497	643	758	666	546	523	525	499	364	262
	CDD18.3	2860	20	80	239	393	500	416	288	265	275	241	114	29
	CDH23.3	34893	181	741	2709	5794	8140	6024	2913	2401	2722	2189	839	240
CDH26.7	18482	20	229	1436	3703	5696	3765	997	619	927	857	208	24	
Wind	WSAvg	0.9	0.6	0.7	0.9	1.1	1.3	1.4	1.2	1.0	0.9	0.6	0.4	0.4
Precipitation	PrecAvg	1220	18	20	18	10	15	148	365	358	217	36	7	7
	PrecMax	1631	65	89	63	36	58	345	550	525	552	197	72	94
	PrecMin	912	0	0	0	0	0	54	160	207	46	0	0	0
	PrecStd	201	19	22	17	9	13	88	86	87	114	38	16	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.7	32.7	38.5	42.1	43.9	43.4	36.5	33.1	33.9	34.1	31.1	28.8
		MCWB	17.2	18.3	18.9	19.0	20.5	21.5	24.8	26.0	24.4	21.8	19.5	17.8
	2%	DB	27.0	31.0	36.6	41.0	42.9	42.0	34.1	31.8	32.8	33.0	30.0	27.2
		MCWB	16.8	17.8	18.4	19.0	20.7	22.0	24.9	25.6	24.6	22.4	19.7	17.0
	5%	DB	25.6	29.4	35.3	39.9	41.9	40.4	32.4	30.9	31.9	32.0	29.0	25.8
		MCWB	16.3	17.3	18.1	18.9	20.8	22.7	25.2	25.4	24.5	22.1	19.1	16.3
	10%	DB	23.9	27.9	33.7	38.7	40.8	38.6	31.1	29.9	31.0	31.0	27.9	24.5
		MCWB	15.5	17.0	18.2	19.1	20.8	23.0	25.3	25.3	24.5	21.8	18.5	15.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.9	22.1	25.8	25.2	27.1	27.4	26.9	26.6	25.7	23.6	20.0
		MCDB	25.1	28.5	32.1	35.0	36.3	33.5	31.6	30.5	30.6	30.3	28.2	24.9
	2%	WB	18.2	19.6	20.9	23.1	24.3	26.4	26.7	26.3	26.1	25.1	22.5	18.9
		MCDB	24.3	27.2	30.9	33.4	36.1	32.5	30.4	29.8	30.1	29.7	26.8	24.1
	5%	WB	17.3	18.8	20.2	21.7	23.6	25.8	26.2	26.0	25.7	24.5	21.4	17.9
		MCDB	23.1	26.4	30.2	33.4	35.6	31.7	29.7	29.3	29.5	28.7	25.6	23.6
	10%	WB	16.4	17.9	19.4	20.6	22.9	25.4	25.8	25.6	25.3	23.9	20.2	16.9
		MCDB	22.1	25.4	29.4	33.2	34.9	31.1	29.0	28.6	28.9	27.8	25.1	22.6
Mean Daily Temperature Range	5% DB	MDBR	12.5	12.9	13.7	14.1	12.6	9.3	5.4	4.9	6.5	10.3	12.6	13.3
		MCDBR	14.1	14.4	15.3	15.0	13.5	11.5	7.9	6.8	8.1	10.9	13.1	14.3
		MCWBR	6.2	5.3	4.7	4.0	3.7	3.0	2.4	2.2	2.3	3.2	4.7	5.9
	5% WB	MCDBR	11.6	12.4	13.2	13.2	11.7	8.7	6.3	5.8	6.6	7.9	9.4	11.9
MCWBR		6.0	5.4	4.9	4.8	4.0	2.8	2.6	2.4	2.5	3.1	4.2	5.7	
Clear-Sky Solar Irradiance	taub	0.442	0.442	0.478	0.532	0.592	0.646	0.598	0.550	0.523	0.511	0.498	0.452	
	taud	2.058	2.102	2.026	1.917	1.819	1.763	1.882	2.032	2.075	2.013	1.955	2.049	
	Ebn at Noon	806	840	828	789	738	694	727	765	779	765	743	777	
	Edh at Noon	151	154	174	197	216	227	201	173	163	166	166	147	
All-Sky Solar Radiation	RadAvg	4.28	5.23	6.23	6.96	6.97	5.42	3.95	3.82	4.76	5.11	4.48	4.15	
	RadStd	0.33	0.27	0.31	0.24	0.20	0.61	0.52	0.48	0.55	0.34	0.25	0.15	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page