

AGARTALA, India

WMO: 427240

Lat: 23.887N

Lon: 91.240E

Elev: 14

StdP: 101.16

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.7	10.9	7.3	6.3	18.1	8.7	7.0	15.7	3.5	22.5	3.1	22.9	0.0	50	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.9	35.1	27.0	34.4	27.0	33.8	26.9	29.0	33.1	28.5	32.5	28.1	31.9	1.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.0	24.1	31.6	27.4	23.4	30.9	27.1	22.9	30.5	94.9	33.0	92.8	32.8	90.9	32.2	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
4.7	3.7	3.2	DB	7.6	36.6	1.3	0.9	6.7	37.2	5.9	37.8	5.1	38.3	4.2	38.9
			WB	7.2	29.6	1.4	0.5	6.2	29.9	5.3	30.2	4.6	30.5	3.6	30.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	17.9	21.3	25.6	28.1	28.5	28.7	28.7	28.8	28.6	27.2	23.5	19.6	(6)
	DBStd	4.25	2.05	2.56	2.49	2.20	1.98	1.59	1.29	1.18	1.27	1.71	1.86	2.02	(7)
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD18.3	46	32	3	0	0	0	0	0	0	0	0	0	11	(9)
	CDD10.0	5682	245	318	483	543	573	562	578	583	559	534	405	298	(10)
	CDD18.3	2686	18	88	224	293	315	312	320	324	309	276	155	51	(11)
	CDH23.3	28909	196	768	2259	3383	3627	3628	3660	3751	3436	2718	1136	347	(12)
	CDH26.7	11407	13	211	987	1623	1674	1469	1356	1418	1283	1011	321	40	(13)
(14) Wind	WSAvg	0.9	0.4	0.7	1.0	1.4	1.2	1.3	1.5	1.2	0.9	0.6	0.4	0.3	(14)
(15) Precipitation	PrecAvg	2039	11	28	67	155	316	407	346	273	219	159	34	9	(15)
	PrecMax	2864	51	183	200	382	610	667	762	413	529	352	147	120	(16)
	PrecMin	1472	4	3	0	5	90	155	109	152	96	63	4	0	(17)
	PrecStd	378	11	36	60	93	132	141	179	74	99	85	45	25	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	32.1	35.1	36.3	36.0	35.2	34.6	34.9	34.9	34.2	32.0	29.0	(19)
		MCWB	19.2	22.0	23.0	25.6	27.4	28.8	28.7	28.7	28.3	27.7	24.9	20.6	(20)
	2%	DB	26.7	30.3	33.8	35.1	35.0	34.2	33.3	33.7	33.6	33.1	30.7	27.9	(21)
		MCWB	18.5	20.9	23.2	25.8	27.4	28.3	27.8	28.2	28.0	27.1	23.9	20.3	(22)
	5%	DB	25.5	29.1	32.8	34.1	34.1	33.3	32.5	32.8	32.7	32.2	29.7	26.8	(23)
		MCWB	17.8	20.2	23.2	25.9	27.4	28.0	27.5	27.8	27.5	26.5	23.3	19.7	(24)
	10%	DB	24.2	27.9	31.7	33.1	33.1	32.2	31.6	31.9	31.8	31.2	28.7	25.5	(25)
		MCWB	17.3	19.7	23.0	25.8	27.1	27.6	27.2	27.4	27.2	26.1	22.7	19.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	24.2	26.3	28.2	29.2	29.5	29.3	29.3	29.2	28.6	26.3	23.0	(27)
		MCDB	24.8	28.8	31.3	33.8	34.1	34.0	33.3	33.3	33.1	32.7	30.4	26.3	(28)
	2%	WB	20.0	23.4	25.5	27.6	28.5	28.7	28.4	28.6	28.5	27.7	25.2	21.6	(29)
		MCDB	24.4	27.3	30.5	32.7	33.1	32.8	32.0	32.4	32.2	31.5	28.7	25.3	(30)
	5%	WB	18.9	22.5	25.0	27.1	28.0	28.3	27.9	28.1	28.0	27.2	24.5	20.7	(31)
		MCDB	23.6	26.3	29.8	31.7	32.4	32.1	31.1	31.6	31.5	30.7	27.9	24.8	(32)
	10%	WB	18.1	21.3	24.5	26.6	27.5	27.8	27.5	27.7	27.5	26.7	23.8	20.0	(33)
		MCDB	22.9	25.6	29.0	31.0	31.7	31.3	30.5	30.9	30.8	30.0	27.1	24.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	13.4	12.1	10.0	8.5	6.2	5.6	5.9	6.3	7.7	10.8	12.1	(35)
		MCDBR	14.7	14.1	12.6	10.7	9.7	7.8	7.0	7.4	7.7	8.7	11.2	13.2	(36)
	5% WB	MCWBR	7.2	5.9	4.6	3.8	3.9	3.2	2.7	2.9	3.1	3.6	5.1	6.4	(37)
		MCWBR	13.2	11.0	10.5	9.6	9.0	7.3	6.3	6.7	7.0	7.9	9.3	11.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.566	0.558	0.604	0.651	0.674	0.614	0.512	0.500	0.514	0.514	0.528	0.541	(40)
		taud	1.774	1.827	1.780	1.748	1.740	1.891	2.192	2.232	2.167	2.108	1.944	1.876	(41)
	Ebn at Noon		680	730	721	698	680	716	793	804	786	762	712	684	(42)
		Edh at Noon	200	202	222	233	234	200	148	142	149	151	168	175	(43)
(44) All-Sky Solar Radiation	RadAvg		3.93	4.86	5.38	5.44	5.03	4.36	4.47	4.62	4.44	4.43	4.35	3.77	(44)
	RadStd		0.24	0.26	0.39	0.45	0.50	0.40	0.45	0.36	0.30	0.24	0.26	0.28	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
											(47)

Nomenclature: See separate page