

RAJKOT, India

WMO: 427370

Lat: 22.309N

Lon: 70.780E

Elev: 134

StdP: 99.72

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	13.3	-4.0	2.7	24.5	-1.7	3.3	23.1	7.9	24.8	7.1	24.7	1.4	50	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.3	41.4	22.1	40.2	22.0	39.1	22.5	27.7	32.7	27.2	31.6	26.9	31.0	5.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.8	22.8	29.0	26.4	22.3	28.7	26.1	21.8	28.4	89.9	32.9	87.7	31.6	86.2	31.0	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.3	7.5	9.6	43.4	1.9	1.0	8.2	44.1	7.1	44.7	6.1	45.3	4.7	46.0		
(5)			4.9	29.3	1.9	0.9	3.6	30.0	2.5	30.5	1.4	31.0	0.1	31.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	21.1	23.8	28.1	31.5	33.3	32.1	29.0	28.0	28.6	29.6	26.5	22.6
	DBStd	4.08	2.20	2.67	2.40	1.67	1.21	1.94	1.75	1.25	1.26	1.52	2.02	2.28
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	4	3	1	0	0	0	0	0	0	0	0	0	1
	CDD10.0	6528	345	387	562	644	722	662	591	559	559	609	495	392
	CDD18.3	3492	89	155	304	394	464	412	332	301	309	351	245	134
	CDH23.3	42558	798	1529	3649	5448	6789	5754	3896	3184	3437	4355	2539	1178
	CDH26.7	22089	217	677	2116	3398	4346	3379	1563	1021	1408	2323	1234	408
Wind	WSAvg	3.5	2.4	2.7	3.2	4.0	5.2	5.0	4.7	4.3	3.5	2.3	1.9	2.3
Precipitation	PrecAvg	659	0	1	2	1	3	120	208	202	87	9	18	1
	PrecMax	1529	8	7	32	7	26	422	456	1063	301	46	114	25
	PrecMin	296	0	0	0	0	0	0	21	13	0	0	0	0
	PrecStd	300	2	2	6	2	6	112	113	214	75	13	32	5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	36.1	40.3	42.2	43.2	41.9	36.5	34.1	36.4	38.4	35.8	33.3
		MCWB	18.2	19.0	20.0	20.6	21.6	24.6	25.8	25.5	23.9	21.8	19.9	19.2
	2%	DB	30.5	34.1	38.6	40.8	41.8	39.7	34.8	32.8	34.7	37.1	34.6	31.7
		MCWB	17.2	18.5	19.4	20.4	22.1	25.5	25.8	25.3	24.8	21.8	19.9	18.3
	5%	DB	29.2	32.6	37.1	39.7	40.7	38.2	33.6	31.9	33.5	36.2	33.6	30.4
		MCWB	16.8	18.0	19.2	20.6	22.6	25.8	25.9	25.3	24.8	21.7	19.7	17.8
	10%	DB	27.7	30.8	35.5	38.5	39.4	36.8	32.4	31.0	32.5	35.2	32.6	29.2
		MCWB	16.3	17.5	18.9	20.7	23.1	25.9	25.9	25.3	24.9	21.8	19.4	17.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	22.0	23.6	25.7	27.9	28.6	28.1	27.2	27.6	27.0	25.4	22.9
		MCDB	27.5	29.9	33.2	33.1	35.2	34.4	31.3	30.1	31.3	32.2	29.8	29.9
	2%	WB	19.5	20.8	22.5	24.8	27.0	27.9	27.4	26.7	27.0	26.2	24.2	21.1
		MCDB	26.4	28.2	29.3	30.9	33.2	33.7	30.4	29.5	30.5	30.8	28.3	27.6
	5%	WB	18.4	20.0	21.7	24.2	26.5	27.5	27.0	26.3	26.4	25.6	22.7	19.8
		MCDB	25.6	27.1	28.3	29.8	32.4	32.7	29.9	29.0	29.8	30.1	28.6	26.9
	10%	WB	17.5	19.1	21.0	23.7	26.1	27.1	26.7	26.0	26.0	25.1	21.5	18.7
		MCDB	25.0	26.7	28.3	29.3	31.7	31.8	29.5	28.6	29.2	29.6	28.5	26.2
Mean Daily Temperature Range	5% DB	MDBR	13.2	13.6	14.2	14.6	13.3	9.3	5.6	5.4	7.7	11.2	12.3	13.1
		MCDBR	14.1	15.0	15.7	15.6	14.9	11.6	7.8	7.1	9.5	12.6	12.7	13.7
		MCWBR	5.7	5.0	4.3	4.3	4.1	2.3	1.6	1.5	2.1	3.8	4.1	5.6
	5% WB	MCDBR	12.6	13.0	13.9	14.2	12.6	9.3	5.9	5.3	6.9	9.4	10.1	11.8
		MCWBR	5.9	5.1	4.9	4.3	3.2	2.4	2.1	1.9	2.5	3.1	4.4	5.8
Clear-Sky Solar Irradiance	taub	0.406	0.418	0.479	0.524	0.568	0.687	0.727	0.656	0.582	0.536	0.522	0.442	
	taud	2.182	2.164	2.003	1.934	1.882	1.679	1.624	1.757	1.898	1.921	1.906	2.073	
	Ebn at Noon	850	868	829	796	756	666	640	688	733	746	725	793	
	Edh at Noon	134	145	178	194	203	247	261	229	195	183	176	145	
All-Sky Solar Radiation	RadAvg	4.64	5.53	6.53	7.18	7.34	5.82	4.11	4.13	5.04	5.49	4.68	4.34	
	RadStd	0.14	0.14	0.16	0.12	0.27	0.44	0.35	0.32	0.37	0.22	0.24	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	+1.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page