

INDORE INTL, India

WMO: 427540

Lat: 22.722N

Lon: 75.801E

Elev: 1850

StdP: 13.74

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.4	51.8	28.2	23.7	79.5	31.1	27.1	76.9	18.3	75.9	16.5	74.1	3.9	50	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	23.6	105.5	69.6	103.5	68.8	101.5	68.5	78.1	87.0	77.4	85.3	76.8	84.2	11.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.3	147.1	80.9	75.6	143.4	80.1	75.1	141.0	79.6	43.4	87.3	42.6	85.5	41.9	84.2	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.3	19.7	18.2	DB	45.0	108.6	2.8	1.7	43.0	109.8	41.4	110.8	39.8	111.8	37.8	113.1	(4)
(5)			WB	41.2	80.4	3.4	1.3	38.7	81.3	36.7	82.1	34.8	82.9	32.4	83.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.9	65.4	71.0	79.4	87.0	90.9	86.0	79.5	77.4	78.9	78.6	73.2	67.7
	DBStd	8.27	4.44	5.03	4.78	3.45	2.92	4.75	3.38	2.11	2.55	2.99	3.21	3.92
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	81	50	11	0	0	0	0	0	0	0	0	0	20
	CDD50	10194	479	589	911	1111	1267	1079	913	848	866	887	697	547
	CDD65	4799	63	180	446	661	802	629	448	383	416	422	247	102
	CDH74	54817	668	1887	5517	9741	12544	8118	3609	2145	3167	4245	2250	926
CDH80	28125	127	718	3039	6115	8247	4418	1099	371	1095	1961	759	176	
Wind	WSAvg	8.1	5.6	6.5	7.5	9.2	11.9	12.5	12.0	10.1	7.2	4.8	4.3	4.9
Precipitation	PrecAvg	37.8	0.3	0.1	0.2	0.1	0.5	5.3	11.3	11.6	6.4	1.4	0.6	0.3
	PrecMax	72.3	2.6	1.7	1.9	0.8	2.4	16.9	30.3	25.2	24.5	9.1	6.0	4.3
	PrecMin	20.0	0.0	0.0	0.0	0.0	0.0	0.0	1.2	3.8	0.2	0.0	0.0	0.0
	PrecStd	9.2	0.5	0.3	0.3	0.2	0.5	3.7	5.6	4.8	4.6	1.8	1.3	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.4	93.4	101.8	106.7	108.6	106.8	94.8	87.9	93.5	94.8	90.6	86.4
		MCWB	62.3	63.4	67.4	66.6	70.4	72.4	74.4	76.6	72.6	68.3	64.4	64.1
	2%	DB	83.5	90.1	98.6	104.4	106.2	102.6	91.1	85.7	91.1	92.8	88.5	84.1
		MCWB	61.3	62.8	64.6	66.4	70.1	72.7	75.5	76.2	72.5	68.3	65.3	63.6
	5%	DB	80.8	87.5	96.2	102.3	104.4	99.5	88.5	83.8	88.7	91.0	86.6	82.0
		MCWB	60.7	62.4	64.3	66.1	69.6	73.1	75.5	75.8	73.5	67.5	65.1	62.9
	10%	DB	77.9	84.7	93.7	100.2	102.6	96.3	86.0	82.1	86.2	89.3	84.7	79.5
		MCWB	59.8	61.4	63.4	65.5	69.4	73.4	75.5	75.4	74.0	66.5	64.6	62.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.7	68.4	70.8	72.4	78.1	79.5	79.0	78.2	78.1	76.4	73.2	68.8
		MCDB	78.3	81.4	96.8	97.8	96.7	90.3	86.0	84.0	84.8	84.7	82.3	79.0
	2%	WB	64.0	65.9	68.4	69.7	75.7	78.2	77.8	77.3	77.2	74.8	71.7	66.7
		MCDB	75.8	82.1	92.1	96.0	93.4	89.1	84.2	82.6	83.4	82.7	79.9	78.1
	5%	WB	62.4	64.5	66.5	68.2	74.4	77.3	77.1	76.6	76.3	73.6	69.9	64.9
		MCDB	74.9	80.9	89.6	96.2	93.1	88.2	83.2	81.4	82.3	81.7	76.7	76.8
	10%	WB	61.0	63.0	65.1	67.0	73.1	76.5	76.4	76.0	75.6	72.4	67.9	63.3
		MCDB	73.9	79.8	87.7	95.4	93.3	87.1	82.0	80.4	81.3	80.8	76.6	75.0
Mean Daily Temperature Range	5% DB	MDBR	23.7	25.1	26.1	26.1	23.6	17.1	10.1	8.9	14.0	21.7	23.4	23.7
		MCDBR	26.8	27.8	28.7	28.0	25.0	21.8	15.3	12.0	18.8	23.5	25.4	26.6
		MCWBR	10.3	10.2	10.1	9.4	8.2	6.3	4.4	4.7	5.8	6.9	8.3	9.8
	5% WB	MCDBR	22.0	22.9	25.0	25.2	22.5	17.1	11.0	10.1	12.6	16.2	16.4	20.8
		MCWBR	10.4	10.6	10.7	9.9	8.4	5.8	4.5	4.7	5.4	6.0	7.7	10.1
Clear-Sky Solar Irradiance	taub	0.430	0.432	0.465	0.508	0.551	0.633	0.617	0.569	0.532	0.501	0.496	0.455	
	taud	2.083	2.104	2.033	1.969	1.911	1.784	1.833	1.960	2.026	2.016	1.967	2.021	
	Ebn at Noon	260	270	267	257	244	223	226	238	245	246	237	246	
	Edh at Noon	47	49	55	59	62	70	67	59	55	53	52	48	
All-Sky Solar Radiation	RadAvg	1409	1699	2021	2238	2292	1797	1222	1192	1514	1684	1450	1348	
	RadStd	74	65	82	62	63	188	167	141	143	87	86	57	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	+4.36	N/A	+0.59	+0.79	N/A	N/A	N/A	N/A

Nomenclature: See separate page