

INDORE INTL, India

WMO: 427540

Lat: 22.722N

Lon: 75.801E

Elev: 564

StdP: 94.73

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.7	11.0	-2.1	3.4	26.4	-0.5	3.9	25.0	8.2	24.4	7.4	23.4	1.7	50	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.1	40.8	20.9	39.7	20.4	38.6	20.3	25.6	30.5	25.2	29.6	24.9	29.0	5.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	21.0	27.2	24.2	20.5	26.7	23.9	20.1	26.4	83.0	30.7	81.2	29.7	79.7	29.0	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.5	8.8	8.1	DB	7.2	42.6	1.5	1.0	6.1	43.2	5.2	43.8	4.3	44.3	3.2	45.0	
			WB	5.1	26.9	1.9	0.7	3.7	27.4	2.6	27.8	1.6	28.3	0.2	28.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.5	18.6	21.7	26.3	30.6	32.7	30.0	26.4	25.2	26.0	25.9	22.9	19.8	
	DBStd	4.60	2.47	2.79	2.66	1.92	1.62	2.64	1.88	1.17	1.42	1.66	1.78	2.18	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	45	28	6	0	0	0	0	0	0	0	0	0	11	
	CDD10.0	5663	266	327	506	617	704	599	507	471	481	493	387	304	
	CDD18.3	2666	35	100	248	367	446	349	249	213	231	234	137	57	
	CDH23.3	30454	371	1048	3065	5412	6969	4510	2005	1192	1759	2358	1250	514	
	CDH26.7	15625	71	399	1688	3397	4582	2454	611	206	608	1089	422	98	
Wind	WSAvg	3.6	2.5	2.9	3.4	4.1	5.3	5.6	5.3	4.5	3.2	2.1	1.9	2.2	
Precipitation	PrecAvg	960	7	3	4	3	12	135	287	295	163	36	16	7	
	PrecMax	1837	66	44	49	21	60	430	769	640	623	230	153	109	
	PrecMin	508	0	0	0	0	0	1	30	96	6	0	0	0	
	PrecStd	234	13	7	8	5	13	94	141	123	118	45	32	17	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.2	34.1	38.8	41.5	42.6	41.5	34.9	31.1	34.1	34.9	32.5	30.2	
		MCWB	16.8	17.5	19.7	19.2	21.4	22.5	23.5	24.8	22.6	20.2	18.0	17.8	
	2%	DB	28.6	32.3	37.0	40.2	41.2	39.2	32.8	29.8	32.8	33.8	31.4	29.0	
		MCWB	16.3	17.1	18.1	19.1	21.2	22.6	24.2	24.5	22.5	20.2	18.5	17.6	
	5%	DB	27.1	30.8	35.7	39.1	40.2	37.5	31.4	28.8	31.5	32.8	30.3	27.8	
		MCWB	15.9	16.9	17.9	18.9	20.9	22.8	24.2	24.3	23.0	19.7	18.4	17.2	
	10%	DB	25.5	29.3	34.3	37.9	39.2	35.7	30.0	27.9	30.1	31.9	29.3	26.4	
		MCWB	15.4	16.3	17.5	18.6	20.8	23.0	24.2	24.1	23.3	19.2	18.1	16.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.7	20.2	21.6	22.4	25.6	26.4	26.1	25.6	25.6	24.7	22.9	20.4
			MCDB	25.7	27.5	36.0	36.6	35.9	32.4	30.0	28.9	29.3	29.3	27.9	26.1
2%		WB	17.8	18.9	20.2	20.9	24.3	25.6	25.4	25.2	25.1	23.8	22.1	19.3	
		MCDB	24.4	27.8	33.4	35.6	34.1	31.7	29.0	28.1	28.6	28.2	26.6	25.6	
5%		WB	16.9	18.1	19.2	20.1	23.6	25.2	25.1	24.8	24.6	23.1	21.1	18.3	
		MCDB	23.9	27.2	32.0	35.7	34.0	31.2	28.4	27.5	28.0	27.6	24.8	24.9	
10%		WB	16.1	17.2	18.4	19.4	22.8	24.7	24.7	24.4	24.2	22.4	20.0	17.4	
		MCDB	23.3	26.6	31.0	35.2	34.1	30.6	27.8	26.9	27.4	27.1	24.8	23.9	
Mean Daily Temperature Range	5% DB	MDBR	13.2	13.9	14.5	14.5	13.1	9.5	5.6	4.9	7.8	12.1	13.0	13.1	
		MCDBR	14.9	15.4	16.0	15.5	13.9	12.1	8.5	6.7	10.4	13.1	14.1	14.8	
		MCWBR	5.7	5.7	5.6	5.2	4.6	3.5	2.5	2.6	3.2	3.9	4.6	5.4	
	5% WB	MCDBR	12.2	12.7	13.9	14.0	12.5	9.5	6.1	5.6	7.0	9.0	9.1	11.5	
		MCWBR	5.8	5.9	6.0	5.5	4.7	3.2	2.5	2.6	3.0	3.3	4.3	5.6	
Clear-Sky Solar Irradiance	taub	0.430	0.432	0.465	0.508	0.551	0.633	0.617	0.569	0.532	0.501	0.496	0.455		
	taud	2.083	2.104	2.033	1.969	1.911	1.784	1.833	1.960	2.026	2.016	1.967	2.021		
	Ebn at Noon	821	851	841	809	769	703	714	751	772	775	748	776		
	Edh at Noon	148	154	173	187	197	222	212	186	172	166	165	152		
All-Sky Solar Radiation	RadAvg	4.44	5.36	6.37	7.06	7.22	5.66	3.85	3.76	4.77	5.31	4.57	4.25		
	RadStd	0.23	0.21	0.26	0.20	0.20	0.59	0.53	0.45	0.45	0.27	0.27	0.18		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	+2.42	N/A	+0.33	+0.44	N/A	N/A	N/A	N/A

Nomenclature: See separate page