

HYDERABAD INTL, India

WMO: 431285

Lat: 17.233N

Lon: 78.417E

Elev: 2024

StdP: 13.65

Time Zone: 5.50 (IND)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	55.2	58.6	30.3	26.3	79.6	34.0	30.9	83.1	14.4	78.5	13.3	78.3	3.8	110	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	22.5	104.0	70.4	102.1	70.5	100.2	70.2	79.6	88.9	78.3	87.2	77.4	85.6	9.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	153.7	82.5	76.8	150.7	81.6	75.5	144.0	79.8	45.1	85.7	43.6	89.0	42.5	85.4	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	18.6	16.5	49.8	106.8	4.4	3.4	46.7	109.2	44.1	111.2	41.7	113.0	38.5	115.5		
(5)			44.5	80.6	4.0	4.1	41.7	83.5	39.3	86.0	37.1	88.3	34.2	91.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.4	71.7	76.9	82.9	87.5	89.9	83.6	79.3	78.5	78.4	77.8	74.4	71.6
	DBStd	6.33	3.06	3.34	3.29	3.27	3.68	3.82	3.03	2.38	2.08	2.43	2.72	3.49
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	3	2	0	0	0	0	0	0	0	0	0	0	1
	CDD50	10726	672	753	1021	1126	1237	1008	909	884	852	863	732	669
	CDD65	5254	209	333	556	676	772	558	444	419	402	398	282	205
	CDH74	55502	1805	3433	6909	9417	11430	6395	3582	3046	2798	3129	1985	1573
(13)	CDH80	26923	497	1598	3923	5703	7268	3084	1149	845	809	1118	553	376
(14)	Wind	WSAvg	7.6	5.8	6.2	6.1	6.2	8.1	11.5	12.3	10.0	7.8	5.9	5.5
(15) Precipitation	PrecAvg	33.8	0.2	0.3	0.7	1.2	1.2	4.5	6.9	7.5	7.2	3.3	0.8	0.1
	PrecMax	47.8	1.6	2.4	6.3	3.9	5.5	8.9	15.0	16.8	16.9	11.5	3.5	1.2
	PrecMin	23.1	0.0	0.0	0.0	0.2	0.0	0.9	2.4	2.4	2.8	0.0	0.0	0.0
	PrecStd	6.8	0.5	0.6	1.3	0.9	1.5	2.2	3.0	3.4	2.9	3.0	0.9	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	96.7	100.8	105.8	109.1	101.9	93.4	91.0	91.2	91.7	88.0	89.6
		MCWB	63.4	66.2	68.9	68.3	75.5	74.7	73.2	72.8	75.7	71.6	69.2	66.2
	2%	DB	86.4	93.4	99.0	102.6	105.5	98.4	90.8	88.1	88.1	89.6	86.2	86.1
		MCWB	63.9	64.4	68.7	69.3	72.0	73.8	73.9	73.1	75.1	71.3	68.5	66.2
	5%	DB	84.5	91.3	97.2	100.8	103.0	95.2	88.0	86.3	86.3	87.8	84.6	84.0
		MCWB	63.9	64.2	68.2	69.2	71.0	73.3	74.1	73.8	74.7	70.4	67.7	65.6
	10%	DB	82.7	89.2	95.2	98.9	100.8	92.8	86.1	84.5	84.5	86.0	83.9	82.1
		MCWB	63.2	65.0	66.3	68.9	71.1	73.3	74.0	74.0	74.4	70.6	67.6	64.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.5	76.7	80.3	78.5	82.8	82.7	78.1	78.3	79.8	79.6	76.8	73.6
		MCDB	82.6	86.2	92.4	92.6	97.1	93.7	85.4	83.1	84.4	84.3	83.2	81.5
	2%	WB	70.9	72.6	75.7	76.6	79.4	78.5	77.2	77.4	78.5	77.9	74.5	71.7
		MCDB	78.0	82.2	87.5	90.0	95.2	88.5	83.9	82.2	84.1	83.4	81.4	79.0
	5%	WB	68.7	70.2	73.5	75.1	77.6	77.3	76.4	76.7	77.3	76.6	73.3	70.3
		MCDB	76.4	79.1	84.7	87.9	93.6	87.0	82.6	81.4	82.2	81.5	79.5	77.4
	10%	WB	66.8	68.4	71.9	73.8	76.1	76.3	75.6	75.9	76.2	75.3	72.2	68.8
		MCDB	75.2	79.0	84.6	87.5	91.7	85.5	81.2	80.2	80.9	79.6	77.4	76.3
(35) Mean Daily Temperature Range	5% DB	MDBR	23.1	23.9	24.2	23.6	22.5	16.5	12.4	12.2	13.1	16.6	18.6	21.7
		MCDBR	25.1	26.2	26.9	25.4	24.2	20.4	15.7	15.0	15.7	19.5	20.4	23.5
		MCWBR	8.9	8.0	8.0	8.1	7.5	5.7	4.6	4.9	5.8	7.1	7.9	8.5
	5% WB	MCDBR	22.4	23.4	25.4	23.1	22.8	16.3	12.6	11.5	13.2	14.7	16.3	18.8
		MCWBR	11.1	10.5	10.5	8.7	8.4	6.4	4.9	5.1	6.6	7.4	7.5	8.8
(40) Clear-Sky Solar Irradiance	taub		0.441	0.452	0.519	0.559	0.594	0.568	0.528	0.511	0.504	0.522	0.469	0.448
	taud		2.101	2.088	1.930	1.879	1.804	1.908	2.034	2.094	2.108	2.014	2.100	2.098
	Ebn at Noon		266	270	255	245	233	237	247	254	256	246	255	259
	Edh at Noon		48	51	62	65	70	62	55	52	51	55	48	47
(44) All-Sky Solar Radiation	RadAvg		1546	1814	1974	2100	2076	1663	1410	1415	1530	1584	1529	1469
	RadStd		70	69	96	75	70	150	122	82	105	86	108	79

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.41	N/A	N/A	+1.31	N/A	N/A	N/A	N/A	+252	+250

Nomenclature: See separate page