

KURNOOL, India

WMO: 432130

Lat: 15.8055N

Lon: 78.0399E

Elev: 922

StdP: 14.21

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	62.7	64.8	40.2	37.9	89.8	43.7	43.4	88.2	5.6	82.7	5.4	82.6	0.2	90	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	20.0	106.9	73.4	105.1	73.6	103.2	73.3	79.3	92.8	78.4	91.3	77.8	90.1	2.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.5	142.9	83.3	75.7	139.0	82.4	75.1	136.2	81.8	43.8	93.3	42.8	91.6	42.1	90.0	89.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.3	7.5	58.7	109.7	1.9	1.6	57.3	110.8	56.2	111.8	55.1	112.7	53.8	113.8		
(5)			53.0	83.0	1.9	2.3	51.6	84.7	50.6	86.1	49.5	87.4	48.2	89.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	84.0	77.1	82.2	88.4	92.7	93.4	87.4	84.3	83.0	82.8	82.3	78.9	76.2	(6)
(7)		DBStd	6.13	2.61	2.96	3.42	3.33	3.91	3.62	2.82	2.58	2.65	2.52	2.65	2.58	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	12428	839	900	1189	1282	1347	1121	1064	1023	983	1000	868	812	(10)
(11)		CDD65	6953	374	480	724	832	882	671	599	558	533	535	418	347	(11)
(12)		CDH74	87410	3374	5586	10417	13130	14015	9282	7204	6288	5933	5652	3722	2807	(12)
(13)		CDH80	47158	1366	2935	6383	8868	9617	5187	3273	2568	2389	2285	1355	932	(13)
(14)	Wind	WSAvg	2.2	1.0	1.3	1.4	1.7	3.0	4.7	4.8	3.8	2.4	1.1	0.9	0.8	(14)
(15)	Precipitation	PrecAvg	27.4	0.0	0.1	0.3	0.8	2.0	3.8	4.4	4.8	6.3	3.6	0.9	0.3	(15)
(16)		PrecMax	40.6	0.6	1.2	1.5	2.7	8.5	8.5	10.2	11.7	18.4	13.7	3.9	3.3	(16)
(17)		PrecMin	16.1	0.0	0.0	0.0	0.0	0.0	1.1	0.7	0.1	0.2	0.0	0.0	0.0	(17)
(18)		PrecStd	6.9	0.1	0.3	0.5	0.7	2.3	1.7	2.1	3.5	4.6	3.1	1.0	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.4	99.9	105.1	108.6	109.5	105.2	97.4	95.4	96.1	95.4	91.7	90.6	(19)
(20)			MCWB	67.0	68.4	71.4	73.3	72.7	75.7	74.8	74.9	74.7	72.0	70.6	68.3	(20)
(21)		2%	DB	90.7	97.2	103.1	106.5	107.7	101.2	95.3	93.3	93.6	92.9	89.8	88.2	(21)
(22)			MCWB	66.3	67.7	71.3	73.0	73.3	76.0	75.0	74.7	74.4	72.4	70.6	68.0	(22)
(23)		5%	DB	88.8	95.2	101.4	104.8	105.8	98.4	93.6	91.7	91.6	91.3	88.2	86.5	(23)
(24)			MCWB	66.0	67.6	70.6	72.9	74.3	75.6	75.0	74.7	74.8	72.4	70.7	67.6	(24)
(25)		10%	DB	87.0	93.0	99.5	103.0	103.8	96.0	91.7	90.0	89.7	89.7	86.8	85.0	(25)
(26)			MCWB	66.0	67.3	70.0	72.7	74.5	75.4	75.0	74.8	74.9	73.0	70.5	67.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	74.5	78.6	80.5	80.9	80.0	78.3	78.7	78.8	78.5	76.4	74.0	(27)
(28)			MCDWB	82.9	87.3	92.3	96.4	96.1	92.5	87.2	86.3	86.5	86.5	84.4	82.4	(28)
(29)		2%	WB	71.6	73.0	76.2	78.8	79.3	78.7	77.3	77.6	77.9	77.4	75.4	72.7	(29)
(30)			MCDWB	82.2	85.8	90.8	93.9	95.7	92.2	87.2	85.4	85.9	85.1	83.5	81.1	(30)
(31)		5%	WB	70.3	71.8	74.8	77.4	78.3	77.8	76.7	76.9	77.3	76.8	74.6	71.5	(31)
(32)			MCDWB	81.0	85.3	89.8	93.3	95.0	91.0	86.9	85.0	85.4	84.3	82.5	80.3	(32)
(33)		10%	WB	69.0	70.7	73.7	76.4	77.4	77.0	76.1	76.3	76.7	76.1	73.8	70.4	(33)
(34)			MCDWB	80.3	84.6	89.3	93.0	94.0	90.1	86.4	84.7	84.8	83.4	81.5	79.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	21.0	22.3	22.3	20.8	20.0	16.2	13.9	13.1	13.2	14.8	16.9	19.4	(35)
(36)			MCDBR	22.8	24.5	23.2	21.8	21.4	19.1	16.3	15.6	16.1	17.7	18.4	20.8	(36)
(37)			MCWBR	6.3	7.3	7.3	7.1	7.0	4.8	3.8	3.7	4.2	5.0	5.2	6.0	(37)
(38)		5% WB	MCDWB	18.0	20.1	20.6	20.3	19.6	17.0	14.0	12.9	13.0	13.3	13.8	15.9	(38)
(39)			MCWBR	6.1	7.2	7.9	7.7	6.7	5.1	4.1	4.2	4.5	4.7	4.6	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.463	0.471	0.544	0.583	0.616	0.561	0.539	0.523	0.519	0.545	0.491	0.485	(40)	
(41)		taud	2.075	2.070	1.895	1.847	1.786	1.954	2.024	2.080	2.089	1.983	2.078	2.038	(41)	
(42)		Ebn at Noon	261	266	249	239	228	239	245	251	252	242	250	250	(42)	
(43)		Edh at Noon	50	53	64	68	71	59	56	53	52	57	50	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1595	1870	2019	2111	2045	1656	1435	1461	1555	1559	1510	1479	(44)	
(45)		RadStd	64	69	77	68	75	129	114	63	114	114	94	74	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+0.41	N/A	N/A	+1.31	+0.52	N/A	N/A	N/A	+252	+250

Nomenclature: See separate page