

KURNOOL, India

WMO: 432130

Lat: 15.8055N

Lon: 78.0399E

Elev: 281

StdP: 97.99

Time Zone: 5.50 (IND)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 17.1	(c) 18.2	(d) 4.6	(e) 5.4	(f) 32.1	(g) 6.5	(h) 6.2	(i) 31.2	(j) 2.5	(k) 28.2	(l) 2.4	(m) 28.1	(n) 0.1	(o) 90	(p) 0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 11.1	(c) 41.6	(d) 23.0	(e) 40.6	(f) 23.1	(g) 39.6	(h) 23.0	(i) 26.3	(j) 33.8	(k) 25.8	(l) 33.0	(m) 25.4	(n) 32.3	(o) 1.3	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.7	20.4	28.5	24.3	19.9	28.0	23.9	19.5	27.6	83.9	34.1	81.6	33.1	80.0	32.2	32.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 5.1	(b) 4.1	(c) 3.3	(e) 14.8	(f) 43.2	(g) 1.1	(h) 0.9	(i) 14.1	(j) 43.8	(k) 13.4	(l) 44.3	(m) 12.9	(n) 44.8	(o) 12.1	(p) 45.5		
			DB													
			WB													
				11.7	28.3	1.0	1.3	10.9	29.3	10.3	30.0	9.7	30.8	9.0	31.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	25.0	27.9	31.3	33.7	34.1	30.8	29.1	28.3	28.2	27.9	26.1	24.6		
	DBStd	3.40	1.45	1.65	1.90	1.85	2.17	2.01	1.57	1.44	1.47	1.40	1.47	1.44		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6904	466	500	661	712	748	623	591	568	546	556	482	451		
	CDD18.3	3863	208	267	402	462	490	373	333	310	296	297	232	193		
	CDH23.3	48561	1874	3103	5787	7294	7786	5157	4002	3493	3296	3140	2068	1559		
	CDH26.7	26199	759	1631	3546	4927	5343	2882	1818	1427	1327	1269	753	518		
(14) Wind	WSAvg	1.0	0.4	0.6	0.6	0.7	1.3	2.1	2.1	1.7	1.1	0.5	0.4	0.4		
(15) Precipitation	PrecAvg	695	1	3	7	21	50	96	113	123	159	91	24	7		
	PrecMax	1032	15	31	38	68	216	216	260	297	467	349	99	85		
	PrecMin	410	0	0	0	0	0	29	17	2	5	0	0	0		
	PrecStd	175	3	8	12	19	58	44	54	88	116	79	25	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	37.7	40.6	42.6	43.1	40.6	36.3	35.2	35.6	35.2	33.2	32.6		
		MCWB	19.5	20.2	21.9	23.0	22.6	24.3	23.8	23.8	23.7	22.2	21.5	20.2		
	2%	DB	32.6	36.2	39.5	41.4	42.0	38.4	35.2	34.1	34.2	33.8	32.1	31.2		
		MCWB	19.0	19.8	21.8	22.8	22.9	24.5	23.9	23.7	23.6	22.5	21.5	20.0		
	5%	DB	31.5	35.1	38.6	40.5	41.0	36.9	34.2	33.2	33.1	32.9	31.2	30.3		
		MCWB	18.9	19.8	21.5	22.7	23.5	24.2	23.9	23.7	23.8	22.5	21.5	19.8		
	10%	DB	30.6	33.9	37.5	39.4	39.9	35.6	33.2	32.2	32.1	32.0	30.5	29.5		
		MCWB	18.9	19.6	21.1	22.6	23.6	24.1	23.9	23.8	23.8	22.8	21.4	19.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	23.6	25.9	26.9	27.2	26.7	25.7	26.0	26.0	25.8	24.7	23.3		
		MCDB	28.3	30.7	33.5	35.8	35.6	33.6	30.7	30.2	30.3	30.3	29.1	28.0		
	2%	WB	22.0	22.8	24.5	26.0	26.3	25.9	25.2	25.3	25.5	25.2	24.1	22.6		
		MCDB	27.9	29.9	32.7	34.4	35.4	33.4	30.7	29.7	29.9	29.5	28.6	27.3		
	5%	WB	21.3	22.1	23.8	25.2	25.7	25.4	24.8	24.9	25.2	24.9	23.7	22.0		
		MCDB	27.2	29.6	32.1	34.1	35.0	32.8	30.5	29.4	29.6	29.1	28.1	26.8		
	10%	WB	20.6	21.5	23.2	24.7	25.2	25.0	24.5	24.6	24.8	24.5	23.2	21.3		
		MCDB	26.8	29.2	31.9	33.9	34.4	32.3	30.2	29.3	29.3	28.6	27.5	26.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	12.4	12.4	11.6	11.1	9.0	7.7	7.3	7.3	8.2	9.4	10.8		
		MCDBR	12.7	13.6	12.9	12.1	11.9	10.6	9.1	8.7	8.9	9.8	10.2	11.6		
		MCWBR	3.5	4.0	4.0	4.0	3.9	2.6	2.1	2.0	2.3	2.8	2.9	3.3		
	5% WB	MCDBR	10.0	11.2	11.4	11.3	10.9	9.5	7.8	7.2	7.2	7.4	7.7	8.8		
		MCWBR	3.4	4.0	4.4	4.3	3.7	2.8	2.3	2.4	2.5	2.6	2.5	3.0		
(40) Clear-Sky Solar Irradiance	taub		0.463	0.471	0.544	0.583	0.616	0.561	0.539	0.523	0.519	0.545	0.491	0.485		
	taud		2.075	2.070	1.895	1.847	1.786	1.954	2.024	2.080	2.089	1.983	2.078	2.038		
	Ebn at Noon		822	837	786	755	720	753	771	791	796	762	789	787		
	Edh at Noon		158	166	203	213	224	187	175	167	165	179	157	160		
(44) All-Sky Solar Radiation	RadAvg		5.03	5.89	6.37	6.65	6.45	5.22	4.53	4.61	4.90	4.91	4.76	4.66		
	RadStd		0.20	0.22	0.24	0.21	0.23	0.41	0.36	0.20	0.36	0.36	0.30	0.23		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.23	N/A	N/A	+0.73	+0.29	N/A	N/A	N/A	+140	+139

Nomenclature: See separate page