

HONNAVAR, IndiaWMO: **432260**Lat: **14.283N**Lon: **74.450E**Elev: **30**StdP: **14.68**Time Zone: **5.50 (IND)**Period: **05-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	66.6	68.1	50.6	54.7	80.4	53.6	61.2	79.8	7.8	83.0	7.1	83.1	2.1	90	0.290

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.3	93.5	76.2	92.6	76.8	91.7	77.2	82.4	89.2	81.8	88.3	81.3	87.7	3.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	159.3	86.1	80.0	155.9	85.5	79.6	153.6	85.0	46.2	89.3	45.6	88.9	45.1	88.0	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.5	5.4	62.2	97.7	2.8	1.7	60.2	98.9	58.5	99.9	57.0	100.9	54.9	102.1		
(5)			56.5	84.3	2.2	1.3	54.9	85.2	53.7	86.0	52.5	86.7	50.9	87.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	79.6	79.9	82.1	84.6	85.2	80.8	79.4	79.3	79.9	81.6	82.2	81.5
	DBStd	2.85	2.50	2.00	2.15	1.83	2.10	2.62	1.99	1.84	1.58	2.11	2.22	2.47
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11443	917	837	996	1037	1092	924	911	910	896	981	965	977
	CDD65	5968	452	417	531	587	627	474	446	445	446	516	515	512
	CDH74	62605	4343	4173	6095	7656	8340	4678	3830	3686	3981	5266	5396	5161
	CDH80	23952	1944	1838	2605	3608	4053	1330	645	587	869	1908	2311	2254
Wind	WSAvg	2.0	1.9	1.8	1.9	2.0	2.0	2.4	2.4	1.9	1.8	1.8	1.9	2.3
Precipitation	PrecAvg	148.0	0.0	0.0	0.4	0.7	6.0	37.9	48.7	28.5	16.0	7.0	2.1	0.3
	PrecMax	184.4	1.0	0.7	3.9	4.4	23.2	56.9	69.8	46.8	33.9	12.8	8.9	3.0
	PrecMin	113.1	0.0	0.0	0.0	0.1	0.6	17.8	28.0	9.9	4.1	0.4	0.0	0.0
	PrecStd	20.2	0.2	0.2	0.9	0.9	5.9	9.6	13.7	10.6	8.0	3.5	2.7	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.1	93.7	93.4	93.5	93.6	90.9	86.6	86.4	87.9	93.5	94.3	94.1
		MCWB	71.9	69.7	75.1	80.1	81.2	80.9	80.5	80.4	79.7	76.8	75.6	72.6
	2%	DB	92.1	91.4	91.4	92.5	92.6	89.1	85.4	85.3	86.6	91.5	92.6	92.4
		MCWB	71.8	72.5	78.3	80.5	80.8	80.7	80.3	80.0	79.3	77.6	75.2	72.6
	5%	DB	90.3	89.9	90.3	91.5	91.7	87.4	84.5	84.3	85.6	89.7	91.3	91.1
		MCWB	72.0	73.8	78.2	80.4	80.6	80.6	80.0	79.7	79.0	78.5	75.3	73.0
	10%	DB	88.8	88.6	89.3	90.5	90.8	86.0	83.4	83.3	84.5	88.1	90.0	89.7
		MCWB	72.1	74.3	78.1	80.0	80.4	80.3	79.5	79.2	78.7	78.8	75.6	73.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.9	79.8	81.9	82.8	83.5	82.5	81.7	81.6	81.6	81.9	81.3	79.9
		MCDB	87.2	87.6	89.0	90.7	90.9	87.5	85.1	84.9	85.6	88.1	88.4	88.2
	2%	WB	77.2	78.4	80.9	81.9	82.5	81.7	80.9	80.7	80.4	81.0	80.1	78.4
		MCDB	86.2	86.5	88.6	89.8	89.9	86.6	84.3	84.3	84.6	87.2	87.4	86.8
	5%	WB	75.9	77.4	80.1	81.4	81.8	81.0	80.3	80.0	79.8	80.3	79.2	77.3
		MCDB	85.5	85.8	87.9	89.1	89.1	85.8	83.6	83.3	83.8	86.5	86.6	85.7
	10%	WB	74.6	76.3	79.3	80.8	81.3	80.6	79.7	79.3	79.1	79.6	78.3	76.2
		MCDB	84.5	84.9	87.0	88.4	88.4	85.3	82.7	82.4	83.0	85.6	85.6	84.6
Mean Daily Temperature Range	5% DB	MDBR	20.2	19.0	15.3	12.9	11.3	8.2	6.6	6.9	8.7	12.9	16.7	18.2
		MCDBR	21.5	20.4	16.0	13.3	12.0	10.3	8.1	8.5	10.7	16.1	18.6	19.1
		MCWBR	10.3	9.3	7.0	5.3	4.6	4.6	4.9	4.7	5.1	6.8	8.4	9.0
	5% WB	MCDBR	19.2	17.6	14.1	12.5	11.3	9.4	7.7	7.9	9.2	13.1	14.8	16.5
		MCWBR	10.1	9.0	6.6	5.7	5.1	5.0	5.0	4.8	5.2	6.4	7.1	8.5
Clear-Sky Solar Irradiance	taub		0.445	0.473	0.552	0.599	0.580	0.577	0.618	0.570	0.507	0.545	0.492	0.453
	taud		2.249	2.177	1.993	1.904	1.961	1.985	1.867	1.993	2.189	2.055	2.182	2.245
	Ebn at Noon		269	267	248	236	237	234	226	239	256	243	253	263
	Edh at Noon		43	48	59	64	59	57	65	58	48	53	45	42
All-Sky Solar Radiation	RadAvg		1784	2009	2150	2182	1963	1262	1171	1313	1586	1646	1665	1678
	RadStd		58	51	69	65	131	102	145	108	158	108	97	62